



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 21.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 20-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	63298	67188	50710	24339	2859	208394
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1325	1584	1240	498	52	4700
Hydro Gen (MU)	107	44	85	24	13	272
Wind Gen (MU)	4	44	69	-	-	118
Solar Gen (MU)*	185.58	159.00	163.86	3.21	0.88	513
Energy Shortage (MU)	0.20	0.00	0.00	0.00	0.00	0.20
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71684	81395	62421	25157	2970	241056
Time Of Maximum Demand Met	10:09	09:41	09:22	18:18	17:48	09:41

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.00	1.98	1.98	76.13	21.90

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9681	0	172.3	74.3	-3.4	391	0.00
	Haryana	9519	0	173.9	112.6	-0.9	357	0.00
	Rajasthan	18982	0	342.0	122.2	-4.3	529	0.00
	Delhi	5233	0	87.6	81.2	-2.5	427	0.00
	UP	20866	0	389.0	79.9	0.8	468	0.00
	Uttarakhand	2509	0	47.3	38.3	0.5	149	0.13
	HP	2201	0	39.5	33.4	-0.6	145	0.00
	J&K(UT) & Ladakh(UT)	3104	0	64.8	61.1	-1.2	109	0.07
	Chandigarh	296	0	4.6	4.6	0.0	16	0.00
	Railways_NR ISTS	223	0	4.3	3.7	0.5	56	0.00
WR	Chhattisgarh	5815	0	114.6	60.2	-0.5	364	0.00
	Gujarat	23823	0	438.6	201.5	-3.2	794	0.00
	MP	19410	0	350.1	219.4	0.0	481	0.00
	Maharashtra	29548	0	596.8	173.6	-12.9	964	0.00
	Goa	712	0	14.0	12.0	1.9	41	0.00
	DNHDDPDCL	1361	0	31.0	30.8	0.2	38	0.00
	AMNSIL	864	0	19.7	12.7	0.0	307	0.00
	BALCO	603	0	14.4	14.5	-0.1	17	0.00
	RIL JAMNAGAR	235	0	5.2	5.3	-0.1	0	0.00
	Andhra Pradesh	12202	0	225.0	63.3	0.6	608	0.00
SR	Telangana	15469	0	273.9	108.2	0.8	1149	0.00
	Karnataka	17091	0	311.7	108.4	-2.7	415	0.00
	Kerala	4570	0	85.0	64.5	1.8	526	0.00
	Tamil Nadu	17383	0	336.5	195.0	-5.8	655	0.00
	Puducherry	391	0	8.2	7.8	-0.2	25	0.00
	Bihar	6043	0	107.9	87.7	-0.5	227	0.00
ER	DVC	3184	0	69.8	-28.4	0.8	405	0.00
	Jharkhand	2073	0	39.4	32.5	-0.1	290	0.00
	Odisha	5777	0	111.7	32.6	-2.2	357	0.00
	West Bengal	8100	0	166.5	47.7	-2.4	119	0.00
	Sikkim	116	0	2.0	1.9	0.1	16	0.00
	Railways_ER ISTS	29	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	188	0	3.3	3.2	0.0	27	0.00
	Assam	1636	0	29.7	25.2	0.3	94	0.00
	Manipur	271	0	4.0	3.9	0.0	33	0.00
	Meghalaya	356	0	6.2	5.6	-0.2	58	0.00
	Mizoram	164	0	2.3	2.2	-0.2	22	0.00
	Nagaland	179	0	2.9	2.6	0.2	19	0.00
	Tripura	237	0	4.1	5.9	0.6	85	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-16.9	-9.2	-14.0	-17.6
Day Peak (MW)	-1038.3	-719.4	-617.3	-783.1

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	224.9	-230.5	136.1	-142.5	12.0	0.0
Actual(MU)	215.6	-222.3	120.5	-138.4	10.6	-14.0
O/D/U/D(MU)	-9.3	8.2	-15.6	4.2	-1.5	-14.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6709	9609	5708	3917	604	26546	50
State Sector	6444	9924	5665	4229	205	26467	50
Total	13153	19532	11373	8146	809	53013	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	805	1596	703	698	13	3815	75
Lignite	23	21	53	0	0	96	2
Hydro	107	44	85	24	13	272	5
Nuclear	53	48	66	0	0	166	3
Gas, Naptha & Diesel	12	13	10	0	20	55	1
RES (Wind, Solar, Biomass & Others)	215	207	273	7	1	704	14
Total	1214	1928	1190	729	48	5109	100

Share of RES in total generation (%)	17.71	10.75	22.96	0.99	1.89	13.77
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.87	15.47	35.66	4.23	28.82	22.36

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.010
Based on State Max Demands	1.038

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	241056	9:41	0
Non-Solar hr	215411	18:42	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godha (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 21-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	364	1345	0.0	18.3	-18.3
4	765 kV	SASARAM-FATEHPUR	1	98	686	0.0	9.5	-9.5
5	765 kV	GAYA-BALIA	1	0	781	0.0	10.5	-10.5
6	400 kV	PUSAULI-VARANASI	1	20	98	0.0	0.9	-0.9
7	400 kV	PUSAULI-ALLAHABAD	1	2	113	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	492	597	0.0	3.7	-3.7
9	400 kV	PATNA-BALIA	2	86	835	0.0	11.8	-11.8
10	400 kV	NAUBATPUR-BALIA	2	171	191	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	431	169	2.1	0.0	2.1
12	400 kV	MOTIHARI-GORAKHPUR	2	73	554	0.0	7.5	-7.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	155	439	0.0	5.0	-5.0
14	220 kV	SAHUPURI-KARAMNANA	1	24	15	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	34	0.0	0.6	-0.6
ER-NR						2.2	77.0	-74.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1588	0.0	21.4	-21.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1246	616	5.8	0.0	5.8
3	765 kV	JHARSUGUDA-DURG	2	0	1174	0.0	18.1	-18.1
4	400 kV	JHARSUGUDA-RAIGARH	4	360	275	0.0	0.0	0.0
5	400 kV	RANCHI-SIPAT	2	359	238	0.7	0.0	0.7
6	400 kV	JEYPORE-JAGDALPUR	2	126	298	0.0	2.0	-2.0
7	220 kV	BUDHIPADAR-RAIGARH	1	23	99	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	101	140	0.0	0.1	-0.1
ER-WR						6.5	42.7	-36.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	119	0.0	2.8	-2.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1377	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1621	0.0	25.4	-25.4
4	400 kV	TALCHER-I/C	2	0	687	0.0	4.6	-4.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	64.4	-64.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOIN	2	124	277	0.5	1.6	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAOIN	2	333	227	2.1	0.0	2.1
3	220 kV	ALIPURDUAR-SALAKATI	2	48	63	0.1	0.0	0.1
ER-NER						2.7	1.6	1.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	567	0	13.5	0.0	13.5
NER-NR						13.5	0.0	13.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3015	0.0	70.6	-70.6
2	HVDC	VINDHYACHAL B/B	-	94	256	0.3	5.3	-5.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1925	0.0	39.9	-39.9
4	765 kV	GWALIOR-AGRA	2	234	2405	0.5	22.2	-21.7
5	765 kV	GWALIOR-PHAGI	2	276	1899	0.5	24.2	-23.7
6	765 kV	JABALPUR-ORAI	2	87	1127	0.0	26.0	-26.0
7	765 kV	GWALIOR-ORAI	1	920	0	14.8	0.0	14.8
8	765 kV	SATNA-ORAI	1	0	1106	0.0	18.5	-18.5
9	765 kV	BANASKANTHA-CHITTOORGARH	2	2533	445	29.9	0.6	29.4
10	765 kV	VINDHYACHAL VARANASI	2	85	2114	0.0	25.9	-25.9
11	400 kV	ZERDA-KANKROLI	1	398	0	5.9	0.0	5.9
12	400 kV	ZERDA BHINMAL	1	274	0	4.1	0.0	4.1
13	400 kV	VINDHYACHAL -RIHAND	1	470	0	0.0	9.8	-9.8
14	400 kV	RAPP-SHUJALPUR	2	831	294	6.6	0.8	5.9
15	400 kV	NEEMUCH-Chittorgarh	2	715	521	3.8	2.6	1.1
16	220 kV	BHANPURA-RANPUR	1	0	126	0.0	2.3	-2.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	131	17	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	100	32	0.7	0.1	0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						68.2	250.1	-182.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	23.5	-23.5
2	HVDC	RAIGARH-PUGALUR	2	0	4014	0.0	72.3	-72.3
3	765 kV	SOLAPUR-RAICHUR	2	2258	1047	17.4	4.0	13.4
4	765 kV	WARDHA-NIZAMABAD	2	1052	2106	2.0	20.2	-18.2
5	765 kV	WARORA-WARANGAL(NEW)	2	676	2598	0.7	28.4	-27.7
6	400 kV	KOLHAPUR-KUDGI	2	1850	0	30.3	0.0	30.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	0.0	2.1	2.1
WR-SR						52.5	148.4	-95.9

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-302	67	-213	-5.12	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-313	161	-159	-3.82	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-290	-198	-258	-6.20	
	NER	132kV GELEPHU-SALAKATI	-67	-39	-55	-1.33	
	NER	132kV MOTANGA-RANGIA	-33	-8	-19	-0.45	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-26	-0.63	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-52	-1.24	
	ER	NEPAL IMPORT (FROM BIHAR)	-134	-75	-113	-2.72	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-492	-79	-193	-4.63	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-472	-462	-467	-11.21	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-783	-561	-735	-17.64	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-145	0	-116	-2.78	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 21-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	18.11	0.00	0.00	0.00	0.00	0.00	18.42
Nepal	2.74	1.75	0.00	0.00	0.00	2.97	0.00	0.00	7.46
Bangladesh	11.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.74
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	14.48	2.06	18.11	0.00	0.00	0.00	2.97	0.00	37.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	-0.31	-18.11	0.00	0.00	0.00	0.00	0.00	-18.03
Nepal	-2.74	-1.75	0.00	0.00	0.00	-2.97	0.00	0.00	-7.46
Bangladesh	-11.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-11.74
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-14.09	-2.06	-18.11	0.00	0.00	-2.97	0.00	0.00	-37.23

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.00	161233	6291	4799	0	5731	1918	143050	3590	156434	165379	-1643
0:15	50.01	161878	6276	4621	0	6184	1812	143467	3487	157257	165847	-1649
0:30	50.03	160803	6263	4424	0	6722	1832	142187	3508	156379	164936	-1634
0:45	50.01	160041	6282	4286	0	6845	1833	141547	3472	155755	164265	-1677
1:00	50.00	159338	6266	4202	0	6883	1836	140607	3517	155136	163311	-1688
1:15	49.99	158206	6276	4189	0	6829	1832	139638	3541	154017	162305	-1700
1:30	49.99	157766	6287	4321	0	6590	1826	139283	3478	153445	161785	-1701
1:45	50.01	157332	6281	4226	0	6479	1860	139037	3534	153106	161417	-1679
2:00	50.04	156094	6280	4150	0	6428	1861	138059	3513	151944	160291	-1716
2:15	49.97	156312	6284	4052	0	6313	1950	138358	3500	152260	160457	-1748
2:30	50.02	156258	6283	4106	0	6339	1971	138128	3502	152152	160329	-1730
2:45	50.02	156569	6290	4171	0	6300	2002	138225	3505	152398	160493	-1775
3:00	50.00	156192	6287	4150	0	6185	2002	137940	3514	152042	160078	-1802
3:15	49.98	156300	6286	4162	0	5883	2027	138240	3571	152138	160169	-1786
3:30	50.04	156390	6278	4209	0	6171	2032	137935	3525	152181	160150	-1766
3:45	50.07	156591	6281	4332	0	6160	2016	138169	3509	152259	160467	-1738
4:00	50.09	157085	6296	4404	0	6299	2016	138478	3490	152681	160983	-1731
4:15	50.01	159354	6301	4464	0	6846	2040	140113	3460	154890	163224	-1775
4:30	50.03	161233	6306	4712	0	7013	2030	141550	3477	156521	165088	-1733
4:45	50.01	163049	6307	4713	0	6802	2034	143772	3556	158336	167184	-1777
5:00	50.04	165309	6309	5066	829	6966	2028	145672	3494	159414	170364	-1777
5:15	50.06	169568	6266	5019	825	7383	2013	150000	3521	163724	175027	-1807
5:30	50.06	173792	6311	5006	811	7990	2182	152923	3487	167975	178710	-1794
5:45	50.04	178987	6314	5082	808	8836	2381	157523	3572	173097	184516	-1792
6:00	50.09	183593	6314	5126	808	10173	2550	160589	3560	177659	189120	-1798
6:15	49.94	189672	6299	4921	821	11560	2893	165381	3495	183930	195370	-1841
6:30	50.06	196628	6291	4759	816	14340	2955	169890	3504	191053	202555	-1839
6:45	50.01	203841	6293	4732	821	17004	3556	173617	3556	198288	209579	-1821
7:00	50.03	209823	6304	4633	1002	20062	3697	176002	3593	204188	215293	-1373
7:15	49.97	215943	6302	4494	1579	23058	3827	177452	3628	209870	220350	-849
7:30	49.85	219319	6306	4415	2741	24525	3868	178220	3633	212163	223708	-848
7:45	50.03	221472	6298	4371	4790	25019	3677	177936	3596	212311	225687	-853
8:00	50.07	222511	6310	4364	7955	25030	3270	175947	3600	210192	226476	-767
8:15	50.06	226481	6318	4186	12068	24991	3204	175279	3676	210227	229722	-650
8:30	50.07	230040	6308	3987	17021	23177	3319	175065	3648	209032	232525	-654
8:45	50.20	232202	6302	3814	22314	21311	2416	173966	3669	206074	233792	-655
9:00	50.30	232633	6309	3625	27545	17152	2335	172735	3735	201463	233436	-673
9:15	50.04	238553	6305	3414	35823	15518	1921	172192	3692	199316	238865	-1037
9:30	50.05	239699	6307	3165	40861	14212	1945	169478	3716	195673	239684	-1351
9:45	50.06	240964	6311	2954	45635	12862	1944	167347	3652	192375	240705	-1898
10:00	50.01	239661	6267	2735	49796	10583	1943	164475	3623	187130	239422	-1916
10:15	50.04	239120	6267	2623	53752	8753	1945	161389	3686	182745	238415	-1964
10:30	50.02	237326	6286	2612	60677	7918	1860	157421	3594	174037	240368	-1974
10:45	49.97	237151	6281	2760	63757	7353	1931	154271	3577	170634	239930	-1989
11:00	49.95	235192	6272	2836	66025	6780	1857	150445	3669	166331	237884	-1994
11:15	49.94	232112	6258	2875	67882	6494	1870	146164	3574	161355	235117	-2079
11:30	49.94	230580	6261	2895	69625	6317	1865	142663	3562	158060	233188	-2096
11:45	50.00	229454	6250	2843	71572	6433	1944	139645	3585	155039	232272	-2047
12:00	50.08	225941	6259	2770	73389	6531	1924	134383	3553	149782	228809	-2105
12:15	49.99	223155	6289	2709	74347	6616	1852	130501	3636	146099	225950	-2082
12:30	50.06	221229	6271	2661	74633	6162	1854	128772	3584	143935	223937	-2051
12:45	50.01	220645	6267	2600	74702	6264	1821	127624	3601	143343	222879	-2043
13:00	50.10	217347	6250	2556	74328	6363	1820	125621	3547	140463	220485	-2056
13:15	50.01	213104	6254	2412	72400	6286	1835	123120	3590	138292	215897	-1998
13:30	50.00	211397	6257	2403	72557	6106	1802	121791	3633	136437	214549	-2051
13:45	49.96	211712	6275	2244	72641	6191	1816	121733	3570	136827	214470	-2040
14:00	50.03	211457	6267	2232	71580	6228	1825	122531	3559	137645	214222	-2085
14:15	49.98	211222	6249	2189	70158	6205	1817	123833	3629	138875	214080	-2054
14:30	49.95	212876	6251	2148	68381	6315	1821	127278	3589	142347	215783	-2059
14:45	49.97	214113	6252	2124	66414	6774	1848	129993	3559	145575	216964	-2076
15:00	49.98	214621	6255	2073	63946	7227	1847	132355	3563	148602	217266	-2069
15:15	49.99	213014	6253	2096	60812	7250	1841	134031	3553	150106	215836	-2104
15:30	50.00	213824	6258	2098	56797	7538	1835	138627	3541	154929	216694	-2138
15:45	49.97	213867	6268	2154	52443	8011	1839	142377	3548	159270	216640	-2188
16:00	50.08	213533	6260	2271	47582	7982	1820	146619	3528	163680	216062	-2183
16:15	50.01	210994	6264	2295	42139	7613	1799	149940	3542	166560	213592	-2172
16:30	50.10	211474	6270	2357	36092	9433	1912	154598	3497	173025	214159	-2168
16:45	49.99	210671	6259	2499	29265	10830	1927	159447	3589	178907	213816	-2123
17:00	50.08	210140	6260	2661	22419	12929	1973	163638	3574	185060	213454	-2080
17:15	50.06	208631	6275	2778	15657	15550	2026	165483	3569	190196	211338	-1580
17:30	50.06	211286	6272	2912	9875	19393	2133	169346	3563	198499	213494	-809
17:45	50.02	213270	6260	2955	5392	22570	2199	172997	3574	204923	215947	-840
18:00	50.09	213405	6266	3182	2352	23590	2246	174859	3587	207871	216082	-811
18:15	50.01	213513	6261	3628	805	23709	2164	176191	3574	209080	216332	-819
18:30	50.05	214269	6054	4100	464	23799	2146	176817	3574	209705	216954	-796
18:45	50.05	215038	6278	4699	442	23846	2151	176842	3597	209897	217855	-797
19:00	50.06	213155	6276	5325	126	22937	2154	175447	3598	207704	215863	-834
19:15	50.04	209980	6292	5985	150	20633	2153	173769	3635	203845	212617	-780
19:30	50.03	207850	6277	6443	0	17960	2155	174006	3603	201407	210444	-825
19:45	50.01	204475	6273	6933	0	16430	2092	171807	3540	197542	207075	-807
20:00	50.11	200432	6281	7336	0	15867	2032	168114	3599	193096	203229	-812
20:15	50.01	197497	6283	7616	0	13315	2012	167410	3676	189881	200312	-764
20:30	50.03	194990	6265	7994	0	12881	1998	165741	3638	186996	198517	-1247
20:45	49.99	191702	6266	8269	0	11241	2019	164220	3677	183433	195692	-1517
21:00	50.02	188765	6271	8626	0	11008	2021	161108	3689	180139	192723	-1730
21:15	49.96	186151	6292	8981	0	10356	2033	158922	3644	177170	190228	-1710
21:30	50.02	182819	6287	9343	0	9884	2006	156167	3594	173476	187281	-1714
21:45	50.03	179499	6271	9666	0	8631	2026	153577	3578	169833	183749	-1659
22:00	50.09	175265	6263	9959	0	7660	2030	150023	3589	165306	179524	-1711
22:15	50.04	174901	6265	10268	0	7648	2066	149054	3588	164633	178889	-1675
22:30	50.07	172912	6281	10568	0	7450	2026	147383	3659	162344	177367	-1663
22:45	50.01	1										