



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54313	64408	47113	22258	2771	190863
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1237	1534	1105	460	51	4387
Hydro Gen (MU)	120	35	99	27	15	296
Wind Gen (MU)	40	117	68	-	-	225
Solar Gen (MU)*	148.65	126.06	99.09	2.84	1.11	378
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65242	72476	55203	23102	2948	215543
Time Of Maximum Demand Met	10:24	09:56	10:17	17:58	17:14	10:24

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.05	3.07	3.11	78.78	18.11

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9582	0	164.3	74.8	0.0	351	0.00
	Haryana	8626	0	163.4	137.8	-1.1	380	0.00
	Rajasthan	17413	0	333.6	113.7	-0.9	844	0.00
	Delhi	4346	0	77.3	71.6	0.3	650	0.00
	UP	18401	0	345.9	95.7	-0.3	676	0.00
	Uttarakhand	2297	0	42.2	32.2	0.2	111	0.00
	HP	2158	0	37.6	27.6	-0.2	244	0.00
	J&K(UT) & Ladakh(UT)	3131	0	65.2	57.6	0.8	226	0.00
	Chandigarh	218	0	3.7	3.7	0.0	13	0.00
	Railways_NR ISTS	201	0	4.1	3.8	0.3	33	0.00
WR	Chhattisgarh	4655	0	90.6	27.8	-0.7	266	0.00
	Gujarat	23296	0	453.3	199.7	-4.7	1107	0.00
	MP	18165	0	332.8	202.1	0.0	727	0.00
	Maharashtra	26709	0	574.3	191.2	-1.8	570	0.00
	Goa	729	0	14.6	12.4	2.1	41	0.00
	DNHDDPDCL	1357	0	31.0	31.0	0.0	50	0.00
	AMNSIL	875	0	19.0	11.7	0.2	282	0.00
	BALCO	540	0	12.9	12.9	0.0	13	0.00
	RIL JAMNAGAR	251	0	5.9	5.9	0.0	0	0.00
	Andhra Pradesh	10010	0	204.1	59.2	-1.0	498	0.00
SR	Telangana	11188	0	206.4	85.3	0.3	443	0.00
	Karnataka	15588	0	281.0	97.4	-0.6	989	0.00
	Kerala	4214	0	83.1	67.7	-0.9	169	0.00
	Tamil Nadu	16200	0	321.8	219.4	-0.4	1090	0.00
	Puducherry	389	0	8.4	8.1	-0.2	54	0.00
	Bihar	4976	0	92.6	77.4	0.5	205	0.00
ER	DVC	3119	0	65.1	-38.7	0.3	480	0.00
	Jharkhand	2091	0	39.1	28.3	-3.5	136	0.00
	Odisha	5691	0	110.2	33.8	-1.5	491	0.00
	West Bengal	7672	0	151.1	43.9	-1.7	442	0.00
	Sikkim	101	0	1.6	1.5	0.1	36	0.00
	Railways_ER ISTS	19	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	178	0	3.0	2.8	0.0	24	0.00
	Assam	1685	0	29.0	22.5	0.4	137	0.00
	Manipur	232	0	3.5	3.4	0.0	37	0.00
	Meghalaya	363	0	6.2	5.3	-0.1	39	0.00
	Mizoram	160	0	2.2	1.2	-0.2	6	0.00
	Nagaland	154	0	2.6	2.5	-0.1	9	0.00
	Tripura	283	0	4.0	4.5	0.0	55	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.0	13.1	-20.4	-21.0
Day Peak (MW)	-419.6	737.7	-970.7	-1195.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	257.4	-207.8	142.3	-196.5	4.7	0.0
Actual(MU)	248.0	-201.2	140.3	-202.2	3.6	-11.4
O/D/U/D(MU)	-9.4	6.7	-2.0	-5.6	-1.1	-11.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6103	13335	6778	4690	55	30961	47
State Sector	13569	10710	7402	2927	205	34813	53
Total	19672	24045	14180	7617	260	65774	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	684	1481	665	701	13	3543	74
Lignite	23	18	50	0	0	91	2
Hydro	120	35	99	27	15	296	6
Nuclear	32	52	46	0	0	131	3
Gas, Naptha & Diesel	8	21	3	0	23	54	1
RES (Wind, Solar, Biomass & Others)	209	247	191	5	1	653	14
Total	1077	1853	1055	733	52	4770	100

Share of RES in total generation (%)	19.42	13.31	18.12	0.73	2.12	13.70
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.56	18.03	31.91	4.40	30.95	22.65

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215543	10:24	0
Non-Solar hr	201801	17:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 29-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1692	0.0	25.8	-25.8
4	765 kV	SASARAM-FATEHPUR	1	0	728	0.0	11.1	-11.1
5	765 kV	GAYA-BALIA	1	0	721	0.0	6.5	-6.5
6	400 kV	PUSAULI-VARANASI	1	36	61	0.1	0.0	0.1
7	400 kV	PUSAULI-ALLAHABAD	1	0	140	0.0	2.5	-2.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	810	0.0	10.8	-10.8
9	400 kV	PATNA-BALIA	2	0	1211	0.0	18.7	-18.7
10	400 kV	NAUBATPUR-BALIA	2	21	322	0.0	6.3	-6.3
11	400 kV	BIHARSHARIFF-BALIA	2	184	388	0.0	3.7	-3.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	585	0.0	9.3	-9.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	506	0.0	7.3	-7.3
14	220 kV	SAHUPURI-KARMANASA	1	37	8	0.0	1.8	-1.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.1	-0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	106.3	-105.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1336	0.0	19.3	-19.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	247	687	0.0	7.2	-7.2
3	765 kV	JHARSUGUDA-DURG	2	0	1273	0.0	25.9	-25.9
4	400 kV	JHARSUGUDA-RAIGARH	4	136	357	0.0	2.7	-2.7
5	400 kV	RANCHI-SIPAT	2	39	348	0.0	3.9	-3.9
6	400 kV	JEYPORE-JACDALPUR	2	244	333	1.8	0.0	1.8
7	220 kV	BUDHIPADAR-RAIGARH	1	0	135	0.0	1.9	-1.9
8	220 kV	BUDHIPADAR-KORBA	2	85	81	0.2	0.0	0.2
ER-WR						1.9	60.8	-58.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	332	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1371	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2778	0.0	52.2	-52.2
4	400 kV	TALCHER/UC	2	374	0	7.1	0.0	7.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	95.7	-95.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	370	60	3.0	0.0	3.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	653	0	6.4	0.0	6.4
3	220 kV	ALIPURDUAR-SALAKATI	2	130	0	1.5	0.0	1.5
ER-NER						10.9	0.0	10.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3043	0.0	48.1	-48.1
2	HVDC	VINDHYACHAL B/B	-	242	0	5.8	0.0	5.8
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1454	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	1956	0.0	33.5	-33.5
5	765 kV	GWALIOR-PHAGI	2	0	2419	0.0	36.2	-36.2
6	765 kV	JABALPUR-ORAI	2	0	1030	0.0	33.5	-33.5
7	765 kV	GWALIOR-ORAI	1	1045	0	17.7	0.0	17.7
8	765 kV	SATNA-ORAI	1	0	1194	0.0	23.8	-23.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1973	0	17.6	0.0	17.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	1955	0.0	29.8	-29.8
11	400 kV	ZERDA-KANKROLI	1	332	0	3.7	0.0	3.7
12	400 kV	ZERDA -BHINMAL	1	229	0	2.6	0.0	2.6
13	400 kV	VINDHYACHAL -RIHAND	1	971	0	21.2	0.0	21.2
14	400 kV	RAPP-SHUJALPUR	2	391	314	1.1	2.3	-1.2
15	400 kV	NEEMUCH-Chittorgarh	2	489	303	1.5	2.2	-0.7
16	220 kV	BHANPURA-RANPUR	1	0	125	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	124	12	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	106	21	0.5	0.1	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						72.4	237.3	-164.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	2003	0.0	47.1	-47.1
3	765 kV	SOLAPUR-RAICHUR	2	754	804	1.9	4.9	-3.0
4	765 kV	WARDHA-NIZAMABAD	2	0	1186	0.0	16.3	-16.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2071	0.0	33.3	-33.3
6	400 kV	KOLHAPUR-KUDGI	2	1610	0	26.4	0.0	26.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	115	2.1	0.0	2.1
WR-SR						30.4	125.5	-95.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-112	46	32	0.77	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	260	36	176	4.22	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-289	-224	-269	-6.46	
	NER	132kV GELEPHU-SALAKATI	-62	-47	-54	-1.30	
	NER	132kV MOTANGA-RANGIA	-15	-1	-8	-0.18	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-40	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	58	0	38	0.91	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	686	246	506	12.14	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-888	-650	-776	-18.64	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1195	-813	-876	-21.02	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-89	0	-73	-1.76	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.37	2.48	0.00	0.00	0.28	0.00	0.00	3.13
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	19.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	19.33	0.37	2.48	0.00	0.00	0.28	0.00	0.00	22.46

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	12.50	0.00	0.00	12.50
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	12.50	0.00	0.00	12.50

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.37	-2.48	0.00	0.00	-0.28	0.00	0.00	-3.13
Nepal	0.00	0.00	0.00	0.00	0.00	12.50	0.00	0.00	12.50
Bangladesh	-19.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.33	-0.37	-2.48	0.00	0.00	12.22	0.00	0.00	-9.96

