

National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 27-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.05.2024.

महोदय/Dear Sir,

आई०ई०जी०सी०-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 26-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	75182	62781	41331	24448	3259	207031
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1780	1557	974	601	67	4979
Hydro Gen (MU)	361	44	32	29	18	484
Wind Gen (MU)	18	230	267	-	-	516
Solar Gen (MU)*	168.03	91.78	105.47	3.08	1.25	370
Energy Shortage (MU)	0.97	0.00	0.00	0.19	0.00	1.16
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79621	68328	43494	31048	3259	222114
Time Of Maximum Demand Met	22:37	14:49	00:01	00:00	19:52	00:01

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.024	0.00	0.00	2.21	2.21	79.69	18.10

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13101	0	266.6	152.8	-0.4	478	0.00
	Haryana	10921	0	232.0	171.7	0.1	249	0.00
	Rajasthan	16383	0	350.0	150.4	-3.1	328	0.97
	Delhi	7597	0	145.8	120.0	-1.0	200	0.00
	UP	28753	0	621.8	327.0	-1.0	569	0.00
	Uttarakhand	2653	0	62.6	29.9	-0.3	148	0.00
	HP	1607	0	34.9	-2.3	0.1	188	0.00
	J&K(UT) & Ladakh(UT)	2592	0	54.5	31.2	-3.2	138	0.00
	Chandigarh	377	0	7.2	7.6	-0.3	18	0.00
WR	Railways_NR ISTS	203	0	4.3	3.9	0.4	42	0.00
	Chhattisgarh	5257	0	118.3	67.8	-1.4	300	0.00
	Gujarat	23380	0	485.0	148.2	-2.6	806	0.00
	MP	13419	0	297.4	168.0	-5.7	529	0.00
	Maharashtra	25920	0	581.0	182.8	-9.1	949	0.00
	Goa	729	0	15.1	13.7	1.2	45	0.00
	DNHDDPDCL	1301	0	29.9	29.8	0.1	55	0.00
	AMNSIL	860	0	17.4	6.0	1.3	334	0.00
	BALCO	522	0	12.5	12.5	0.0	7	0.00
SR	Andhra Pradesh	10252	0	212.4	32.0	-1.8	943	0.00
	Telangana	9044	0	188.2	72.6	0.3	705	0.00
	Karnataka	8158	0	182.7	14.9	-3.9	649	0.00
	Kerala	3569	0	72.2	53.1	1.1	442	0.00
	Tamil Nadu	14574	0	309.1	160.8	-20.5	418	0.00
	Puducherry	433	0	9.8	9.5	-0.3	41	0.00
ER	Bihar	7419	0	156.6	148.6	1.2	500	0.19
	DVC	3369	0	74.4	-31.0	0.6	380	0.00
	Jharkhand	2158	0	46.5	33.5	0.5	153	0.00
	Odisha	6567	0	133.4	50.9	0.4	375	0.00
	West Bengal	11595	0	189.2	64.1	-1.8	330	0.00
	Sikkim	76	0	1.1	1.3	-0.1	29	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	3	0.00
NER	Arunachal Pradesh	198	0	2.8	2.8	-0.2	48	0.00
	Assam	2258	0	45.6	39.0	0.0	129	0.00
	Manipur	201	0	2.9	3.2	-0.3	19	0.00
	Meghalaya	290	0	5.5	2.3	-0.3	42	0.00
	Mizoram	106	0	1.6	1.7	-0.3	12	0.00
	Nagaland	164	0	2.9	3.0	-0.1	16	0.00
	Tripura	278	0	5.6	4.9	0.1	87	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	8.0	-3.7	-22.3	-31.1
Day Peak (MW)	555.9	87.7	-1027.0	-1337.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	398.2	-352.2	-39.2	-22.9	16.1	0.0
Actual(MU)	394.7	-340.5	-74.2	-8.0	16.4	-11.6
O/D/U/D(MU)	-3.5	11.8	-35.1	14.9	0.3	-11.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3682	7659	6638	3766	351	22096	50
State Sector	6316	6192	7808	1764	120	22200	50
Total	9998	13850	14446	5530	471	44295	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	837	1565	579	655	12	3649	68
Lignite	22	16	56	0	0	94	2
Hydro	361	44	32	29	18	484	9
Nuclear	30	52	51	0	0	133	2
Gas, Naptha & Diesel	43	35	5	0	24	107	2
RES (Wind, Solar, Biomass & Others)	194	325	394	4	1	919	17
Total	1488	2038	1117	688	55	5386	100

Share of RES in total generation (%)	13.07	15.97	35.24	0.57	2.27	17.06
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.36	20.68	42.70	4.75	34.36	28.51

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.063

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	217981	14:50	0
Non-Solar hr	222114	0:01	968

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 27-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	840	964	1.1	0.0	1.1
4	765 kV	SASARAM-FATEHPUR	1	283	369	0.0	1.2	-1.2
5	765 kV	GAYA-BALIA	1	0	766	0.0	6.3	-6.3
6	400 kV	PUSAULI-VARANASI	1	55	74	0.0	0.4	-0.4
7	400 kV	PUSAULI -ALLAHABAD	1	70	57	0.4	0.0	0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	244	640	0.0	2.5	-2.5
9	400 kV	PATNA-BALIA	2	262	701	0.0	3.4	-3.4
10	400 kV	NAUBATPUR-BALIA	2	231	459	0.0	1.4	-1.4
11	400 kV	BIHARSHARIFF-BALIA	2	387	121	4.8	0.0	4.8
12	400 kV	MOTIHARI-GORAKHPUR	2	119	438	0.0	3.1	-3.1
13	400 kV	BIHARSHARIFF-VARANASI	2	233	317	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	41	54	0.0	0.1	-0.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						7.0	18.3	-11.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	424	991	0.0	9.5	-9.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2461	0	39.8	0.0	39.8
3	765 kV	JHARSUGUDA-DURG	2	0	759	0.0	10.2	-10.2
4	400 kV	JHARSUGUDA-RAIGARH	4	53	241	0.0	1.3	-1.3
5	400 kV	RANCHI-SIPAT	2	705	0	11.9	0.0	11.9
6	220 kV	BUDHIPADAR-RAIGARH	1	35	97	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	59	80	0.0	0.4	-0.4
ER-WR						51.8	22.4	29.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	666	212	4.8	0.0	4.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1690	0.0	40.9	-40.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2356	0.0	23.7	-23.7
4	400 kV	TALCHER-I/C	2	186	541	0.0	4.1	-4.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						4.8	64.6	-59.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	233	170	0.5	1.1	-0.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	350	313	0.0	2.0	-2.0
3	220 kV	ALIPURDUAR-SALAKATI	2	109	26	0.2	0.0	0.2
ER-NER						0.8	3.1	-2.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	560	0	13.3	0.0	13.3
NER-NR						13.3	0.0	13.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6064	0.0	128.8	-128.8
2	HVDC	VINDHYACHAL B/B	-	0	255	0.0	11.9	-11.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1660	0.0	43.4	-43.4
4	765 kV	GWALIOR-AGRA	2	0	3028	0.0	51.9	-51.9
5	765 kV	GWALIOR-PHAGI	2	584	1512	2.1	17.8	-15.7
6	765 kV	JABALPUR-ORAI	2	0	1356	0.0	42.1	-42.1
7	765 kV	GWALIOR-ORAI	1	617	74	10.1	0.1	10.0
8	765 kV	SATNA-ORAI	1	0	1136	0.0	19.8	-19.8
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1656	0.0	21.8	-21.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	4077	0.0	81.6	-81.6
11	400 kV	ZERDA-KANKROLI	1	75	241	0.2	2.4	-2.3
12	400 kV	ZERDA -BHINMAL	1	75	240	0.2	2.4	-2.2
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	212	609	0.5	6.0	-5.5
15	400 kV	NEEMUCH-Chittorgarh	2	325	525	1.0	4.9	-3.9
16	220 kV	BHANPURA-RANPUR	1	0	164	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.6	-2.6
18	220 kV	MEHGAON-AURAIYA	1	39	41	0.2	0.3	-0.1
19	220 kV	MALANPUR-AURAIYA	1	13	54	0.0	0.7	-0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						35.8	441.3	-405.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	998	0	23.9	0.0	23.9
2	HVDC	RAIGARH-PUGALUR	2	0	1002	0.0	16.7	-16.7
3	765 kV	SOLAPUR-RAICHUR	2	3205	0	42.9	0.0	42.9
4	765 kV	WARDHA-NIZAMABAD	2	938	1462	4.7	6.2	-1.6
5	765 kV	WARORA-WARANGAL(NEW)	2	980	1492	5.0	6.7	-1.8
6	400 kV	KOLHAPUR-KUDGI	2	2412	0	44.0	0.0	44.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	75	1.4	0.0	1.4
9	220 kV	XELDEM-AMBEWADI	1	0	119	2.4	0.0	2.4
WR-SR						124.3	29.6	94.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	374	142	296	7.10
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	227	-77	70	1.68
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-126	-28	-80	-1.91
	NER	132kV GELEPHU-SALAKATI	11	-9	3	0.06
	NER	132kV MOTANGA-RANGIA	60	32	45	1.09
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	-42	-1.02
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-42	-1.00
	ER	NEPAL IMPORT (FROM BIHAR)	-302	0	-132	-3.16
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	390	-118	63	1.51
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-937	-638	-851	-20.42
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1338	-1210	-1297	-31.12
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-90	0	-80	-1.92

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 27-May-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.35	0.00	3.67	0.00	0.00	0.00	0.00	0.00	4.02
Bangladesh	20.46	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.46
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.81	0.00	3.67	0.00	0.00	0.00	0.00	0.00	24.48

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	6.22	0.00	0.00	0.00	0.00	0.02	0.00	0.00	6.24
Nepal	0.00	0.00	0.00	0.00	0.00	4.18	0.00	0.00	4.18
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	6.22	0.00	0.00	0.00	0.00	4.20	0.00	0.00	10.42

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	6.22	0.00	0.00	0.00	0.00	0.02	0.00	0.00	6.24
Nepal	-0.35	0.00	-3.67	0.00	0.00	4.18	0.00	0.00	0.16
Bangladesh	-20.46	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.46
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-14.59	0.00	-3.67	0.00	0.00	4.20	0.00	0.00	-14.06