



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 04.09.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.09.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 3-सितंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03.09.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 04-Sep-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	60240	59439	49338	27281	3566	199864
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1240	1380	1158	608	76	4462
Hydro Gen (MU)	332	121	196	105	40	794
Wind Gen (MU)	13	123	269	-	-	406
Solar Gen (MU)*	169.37	117.73	124.29	4.36	1.24	417
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	61063	62563	53771	28566	3673	205350
Time Of Maximum Demand Met	19:40	18:50	09:56	18:54	19:09	19:23

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.00	0.38	3.84	4.22	79.70	16.07

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7500	0	152.5	67.3	-1.0	244	0.00
	Haryana	8063	0	164.8	127.6	-1.3	348	0.00
	Rajasthan	10897	0	248.2	106.9	-7.1	280	0.00
	Delhi	5527	0	109.5	105.4	-0.7	201	0.00
	UP	23706	0	445.8	191.8	1.0	357	0.00
	Uttarakhand	2206	0	40.9	28.1	0.5	179	0.00
	HP	1659	0	33.7	10.7	0.7	128	0.00
	J&K(UT) & Ladakh(UT)	2060	0	36.5	12.9	0.8	364	0.00
	Chandigarh	241	0	4.6	4.5	0.1	34	0.00
	Railways_NR ISTS	211	0	4.1	3.7	0.4	48	0.00
WR	Chhattisgarh	5216	0	114.5	68.2	-0.6	549	0.00
	Gujarat	19970	0	431.5	193.7	-0.9	814	0.00
	MP	10891	0	234.2	102.5	-3.7	495	0.00
	Maharashtra	24514	0	519.0	181.1	-2.3	1153	0.00
	Goa	659	0	13.8	11.5	1.9	48	0.00
	DNHDDPDCL	1333	0	30.9	30.7	0.2	55	0.00
	AMNSIL	841	0	17.8	9.2	-0.7	266	0.00
	BALCO	535	0	12.8	12.7	0.1	5	0.00
	RIL JAMNAGAR	249	0	5.5	5.5	0	0	0.00
	Andhra Pradesh	9592	0	211.4	27.2	-2.2	593	0.00
SR	Telangana	12610	0	246.6	108.3	0.2	578	0.00
	Karnataka	11367	0	220.3	23.4	-1.7	588	0.00
	Kerala	4060	0	83.3	43.9	0.2	394	0.00
	Tamil Nadu	17796	0	386.5	132.2	-2.8	1078	0.00
	Puducherry	453	0	10.1	9.6	-0.2	48	0.00
	Bihar	7971	0	161.8	152.9	-3.7	255	0.00
ER	DVC	3160	0	67.9	-17.4	0.3	359	0.00
	Jharkhand	2053	0	42.8	33.8	-0.2	171	0.00
	Odisha	6082	0	121.1	65.2	-3.3	394	0.00
	West Bengal	9833	0	213.2	97.3	-2.8	363	0.00
	Sikkim	75	0	1.1	1.4	-0.3	0	0.00
	Railways_ER ISTS	12	0	0.1	0.2	0.0	0	0.00
NER	Arunachal Pradesh	210	0	4.0	3.5	0.1	32	0.00
	Assam	2412	0	51.3	44.4	0.5	135	0.00
	Manipur	229	0	3.0	3.3	-0.2	34	0.00
	Meghalaya	342	0	5.5	2.6	-0.2	48	0.00
	Mizoram	116	0	2.5	0.8	0.1	5	0.00
	Nagaland	169	0	3.4	3.0	-0.1	24	0.00
	Tripura	355	0	6.3	5.9	-0.2	52	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	52.8	19.1	-24.4	-27.5
Day Peak (MW)	2303.9	927.9	-1030.1	-1258.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	139.5	-177.4	32.0	-1.8	7.7	0.0
Actual(MU)	165.6	-181.6	30.6	-25.7	6.9	-4.3
O/D/U/D(MU)	26.1	-4.2	-1.5	-24.0	-0.8	-4.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	8845	10852	12372	3680	115	35863	48
State Sector	13109	13126	8798	4399	199	39631	52
Total	21954	23978	21170	8079	314	75494	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	564	1201	484	589	11	2849	59
Lignite	22	14	47	0	0	82	2
Hydro	332	121	196	105	40	794	16
Nuclear	41	59	36	0	0	136	3
Gas, Naptha & Diesel	6	35	7	0	21	69	1
RES (Wind, Solar, Biomass & Others)	249	241	421	7	1	920	19
Total	1214	1670	1191	702	74	4851	100

Share of RES in total generation (%)	20.53	14.46	35.37	1.00	1.70	18.97
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	51.26	25.22	54.87	16.03	55.66	38.15

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.020
Based on State Max Demands	1.047

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	193185	10:15	0
Non-Solar hr	205350	19:23	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 04-Sep-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	401	0.0	9.1	-9.1
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	1235	431	0.0	0.0	0.0
4	765 kV	SASARAM-FATEHPUR	1	564	161	3.9	0.0	3.9
5	765 kV	GAYA-BALIA	1	48	839	0.0	8.9	-8.9
6	400 kV	PUSAULI-VARANASI	1	0	168	0.0	2.7	-2.7
7	400 kV	PUSAULI-ALLAHABAD	1	74	34	0.3	0.0	0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	270	656	0.0	5.5	-5.5
9	400 kV	PATNA-BALIA	2	169	929	0.0	9.3	-9.3
10	400 kV	NAUBATPUR-BALIA	2	71	333	0.0	1.1	-1.1
11	400 kV	BIHARSHARIFF-BALIA	2	320	246	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	186	413	0.0	2.3	-2.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	648	204	3.0	0.0	3.0
14	220 kV	SAHUPURI-KARMANASA	1	0	54	0.0	0.1	-0.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						16.0	41.4	-25.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1583	88	14.8	0.0	14.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1770	36	31.7	0.0	31.7
3	765 kV	JHARSUGUDA-DURG	2	384	517	0.0	1.9	-1.9
4	400 kV	JHARSUGUDA-RAIGARH	4	407	356	0.9	0.0	0.9
5	400 kV	RANCHI-SIPAT	2	507	126	6.7	0.0	6.7
6	400 kV	JEYPORE-JACDALPUR	2	435	134	5.2	0.0	5.2
7	220 kV	BUDHIPADAR-RAIGARH	1	90	101	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	223	78	0.7	0.0	0.7
ER-WR						60.0	2.6	57.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	531	0.0	12.0	-12.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1416	0.0	31.7	-31.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2612	0.0	30.0	-30.0
4	400 kV	TALCHER/JC	2	399	691	0.0	3.4	-3.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	73.7	-73.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	87	344	0.2	2.9	-2.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	686	0.0	9.3	-9.3
3	220 kV	ALIPURDUAR-SALAKATI	2	0	133	0.0	2.2	-2.2
ER-NER						0.2	14.4	-14.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	304	0.0	7.3	-7.3
NER-NR						0.0	7.3	-7.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2025	0.0	47.9	-47.9
2	HVDC	VINDHYACHAL B/B	-	0	257	0.0	6.0	-6.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	23.9	-23.9
4	765 kV	GWALIOR-AGRA	2	738	2092	2.3	16.9	-14.6
5	765 kV	GWALIOR-PHAGI	2	1561	1625	9.2	15.8	-6.6
6	765 kV	JABALPUR-ORAI	2	427	1086	0.0	15.6	-15.6
7	765 kV	GWALIOR-ORAI	2	1042	252	11.9	0.8	11.3
8	765 kV	SATNA-ORAI	1	0	844	0.0	10.5	-10.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1974	205	17.9	0.1	17.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	3043	0.0	50.3	-50.3
11	400 kV	ZERDA-KANKROLI	1	409	0	5.0	0.0	5.0
12	400 kV	ZERDA -BHINMAL	1	282	0	3.4	0.0	3.4
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	874	342	6.4	1.8	4.6
15	400 kV	NEEMUCH-Chittorgarh	2	614	453	3.3	3.7	-0.4
16	220 kV	BHANPURA-RANPUR	1	0	119	0.0	2.3	-2.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	89	32	0.6	0.1	0.6
19	220 kV	MALANPUR-AURAIYA	1	65	44	0.3	0.1	0.2
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						60.3	197.3	-137.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	513	0	7.8	0.0	7.8
2	HVDC	RAIGARH-PUGALUR	2	0	2001	0.0	18.3	-18.3
3	765 kV	SOLAPUR-RAICHUR	2	1864	699	23.7	0.5	23.1
4	765 kV	WARDHA-NIZAMABAD	2	90	2486	0.0	17.9	-17.9
5	765 kV	WARORA-WARANGAL(NEW)	2	81	2544	0.0	17.7	-17.7
6	400 kV	KOLHAPUR-KUDGI	2	1794	0	32.3	0.0	32.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	94	0.0	2.0	-2.0
WR-SR						65.9	54.4	11.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1261	1017	1222	29.32	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	884	842	862	20.69	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	120	59	92	2.20	
	NER	132kV GELEPHU-SALAKATI	-8	0	-6	-0.15	
	NER	132kV MOTANGA-RANGIA	67	0	30	0.73	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	47	1.12	
	ER	NEPAL IMPORT (FROM BIHAR)	176	69	135	3.24	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	700	408	616	14.79	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-974	-900	-970	-23.28	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1258	-1051	-1146	-27.50	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-54	0	-48	-1.14	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 04-Sep-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.01	0.14	0.00	0.00	0.00	0.00	0.00	0.00	24.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.01	0.14	0.00	0.00	0.00	0.00	0.00	0.00	24.15

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	50.28	0.00	1.33	0.00	0.00	0.08	0.00	0.00	51.69
Nepal	8.56	4.75	0.00	0.00	0.00	5.39	0.00	0.00	18.70
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	58.84	4.75	1.33	0.00	0.00	5.47	0.00	0.00	70.39

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	50.28	0.00	1.33	0.00	0.00	0.08	0.00	0.00	51.69
Nepal	8.56	4.75	0.00	0.00	0.00	5.39	0.00	0.00	18.70
Bangladesh	-24.01	-0.14	0.00	0.00	0.00	0.00	0.00	0.00	-24.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	34.83	4.61	1.33	0.00	0.00	5.47	0.00	0.00	46.24

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	180320	5255	19229	0	31659	2592	119688	1789	161091	180212	1980
0:15	50.08	178849	5265	19349	0	31164	2549	119866	1709	159500	179902	1991
0:30	50.08	177748	5257	19605	0	31061	2495	118481	1701	158143	178600	1993
0:45	50.03	176993	5253	19564	0	31267	2494	117556	1760	157429	177894	2022
1:00	50.03	175420	5270	19568	0	30970	2494	116343	1728	155852	176373	2024
1:15	50.03	173869	5261	19431	0	30612	2491	115336	1721	154438	174852	2024
1:30	50.03	172604	5260	19187	0	30444	2497	114625	1731	153417	173744	2026
1:45	49.98	171563	5262	18856	0	30588	2495	113672	1676	152707	172549	2017
2:00	50.03	170496	5271	18633	0	30458	2488	113050	1686	151863	171586	1970
2:15	49.98	169953	5260	18271	0	30351	2491	112809	1764	151682	170946	1990
2:30	49.98	169006	5263	17964	0	30294	2502	112329	1724	151042	170076	1986
2:45	49.98	169014	5261	17900	0	30416	2496	112035	1741	151114	169849	1986
3:00	50.03	168092	5260	17715	0	30470	2502	111120	1685	150377	168752	1986
3:15	49.93	168020	5257	17569	0	30561	2533	110909	1704	150451	168533	1999
3:30	49.98	167240	5266	17654	0	30372	2495	110375	1735	149586	167897	1990
3:45	50.03	166311	5271	17712	0	30058	2491	109614	1689	148599	166835	2010
4:00	50.03	166088	5254	17651	0	29784	2543	109763	1694	148437	166689	2003
4:15	49.98	166667	5273	17461	0	29994	2539	110250	1730	149206	167247	2017
4:30	49.98	166863	5271	17302	0	30201	2493	110521	1788	149561	167576	2011
4:45	49.97	167282	5277	17162	0	30081	2532	111179	1720	150120	167951	1979
5:00	49.98	167713	5268	16780	66	30143	2553	112125	1721	150867	168656	1922
5:15	49.98	168334	5270	16451	76	29931	2500	113127	1735	151807	169090	1953
5:30	49.98	169162	5269	16272	75	30341	2493	113824	1710	152815	169984	2029
5:45	49.97	170438	5266	16134	64	30494	2488	115178	1721	154240	171345	1990
6:00	50.08	171397	5261	15915	61	30160	2506	116655	1811	155421	172369	1937
6:15	50.02	174456	5172	15690	337	30429	2491	119678	1812	158429	175609	1883
6:30	50.02	177467	4803	15288	953	30567	2499	122562	1790	161226	178462	1871
6:45	49.98	179560	4796	14865	2148	30870	2502	123579	1774	162547	180534	1933
7:00	50.08	180365	4811	14522	4416	30669	2505	122641	1789	161427	181353	1886
7:15	50.03	181530	4812	14089	7395	30226	2512	121545	1777	160046	182356	1940
7:30	50.03	182627	4814	13838	11016	30087	2514	119070	1794	157773	183133	1947
7:45	50.03	182967	4818	13882	15142	30019	2527	115121	1818	153943	183327	1950
8:00	50.03	183057	4826	14126	19689	29898	2529	110641	1815	149242	183524	1950
8:15	49.98	184456	4830	14077	24118	29881	2536	107651	1879	146261	184972	1909
8:30	50.03	185729	4829	14064	29587	29620	2555	103335	1869	142078	186201	1882
8:45	50.03	186576	4848	14345	33981	29940	2557	99754	1851	138250	187276	1868
9:00	50.02	186910	4837	14683	37003	30012	2555	97515	1850	135224	188455	1906
9:15	50.08	188861	4855	14947	40126	29983	2558	95854	1872	133788	190195	1887
9:30	50.03	190238	4847	14922	43314	29754	2566	94520	1955	132002	191878	1906
9:45	50.13	191828	4843	15123	46584	29589	2603	92486	1939	130121	193167	1905
10:00	50.08	192844	4817	14926	48884	29597	2571	91646	1907	129034	194348	1887
10:15	50.07	193185	4828	14846	49408	29551	2614	91262	1859	128931	194368	1905
10:30	50.02	192445	4828	14973	48733	29488	2545	91323	1958	128739	193848	1881
10:45	49.97	192360	4846	15176	47406	29403	2602	92239	1858	129778	193530	1917
11:00	49.97	192435	4848	15318	48080	29291	2642	91721	1894	129037	193794	1841
11:15	50.07	192146	4837	15344	49369	28710	2663	90721	1996	127433	193640	1836
11:30	50.02	192305	4842	15051	49747	28746	2712	91051	1879	127507	194028	1820
11:45	49.92	191539	4859	14782	47415	28478	2667	93060	1917	129342	193178	1805
12:00	49.97	191247	4852	14854	46320	28107	2713	93748	1970	130073	192564	1814
12:15	49.97	190388	4851	14729	46705	27750	2675	93276	1899	128954	191885	1828
12:30	49.97	190467	4831	14659	46737	27493	2688	93148	1971	129071	191527	1815
12:45	50.07	189965	4840	14752	47326	27584	2685	92305	1854	127887	191346	1784
13:00	50.12	187459	4868	14908	47214	26628	2644	90869	1896	125337	189027	1772
13:15	50.07	184358	4876	15228	43358	27291	2702	90468	1892	125772	185815	1629
13:30	49.97	184125	4860	15435	43119	27113	2680	90606	1955	125571	185768	1665
13:45	50.02	184793	4880	15675	43737	27299	2638	90374	1881	125381	186484	1630
14:00	50.02	185629	4884	15973	44581	27365	2681	90013	1916	125075	187413	1611
14:15	50.02	186757	4892	16446	45003	27315	2709	90052	1874	125308	188291	1750
14:30	50.07	188568	4891	16725	46879	27121	2692	90111	1879	124964	190298	1738
14:45	50.02	188861	4914	16536	46500	27335	2701	90645	1870	125825	190501	1811
15:00	50.02	190562	4896	16775	45503	28153	2769	92016	1891	128284	192003	1753
15:15	50.07	190368	4942	16865	45926	28062	2647	91760	1884	127577	192086	1777
15:30	50.07	189907	4935	16654	43953	28717	2646	93182	1801	129300	191888	1644
15:45	49.97	190250	4943	16983	42029	28870	2606	94601	1838	131238	191870	1623
16:00	49.97	189327	4958	16939	39415	29254	2627	96047	1802	132973	191042	1601
16:15	49.87	188292	4961	17151	35872	29333	2665	97325	1820	135269	189127	1638
16:30	49.92	188761	4969	17297	31752	29968	2653	101091	1769	139712	189499	1701
16:45	49.97	189181	5016	17628	28600	30398	2661	103656	1780	142953	189739	1734
17:00	49.97	188449	5018	18090	24345	30501	2636	107049	1754	146014	189393	1747
17:15	49.97	187183	5022	18294	20227	30547	2568	109747	1744	148662	188149	1705
17:30	49.97	186875	5031	17817	15640	31253	2599	113766	1682	153418	187788	1732
17:45	49.97	186843	5018	17677	11908	31766	2623	117188	1678	157258	187858	1741
18:00	49.92	188420	5048	17790	8566	32055	2605	120978	1702	162064	188744	1711
18:15	49.92	190857	5050	18145	5535	32880	2664	124765	1675	167177	190714	1683
18:30	50.07	195123	5033	18293	3159	33681	2925	129905	1761	173671	194757	1648
18:45	50.07	198712	5048	18425	1330	33452	3220	134718	1769	178957	197962	1640
19:00	50.07	201380	5055	18465	381	34181	3078	137632	1809	182534	200601	1720
19:15	50.07	204844	5042	18538	87	34993	2915	140411	1862	186219	203848	1686
19:30	50.02	204542	5045	18511	65	35060	2819	140688	1868	185966	204056	1691
19:45	50.02	203712	5057	18819	79	34399	2831	140406	1836	184814	203427	1769
20:00	50.07	201352	5062	18834	63	33389	2827	139355	1809	182455	201339	1761
20:15	50.07	199814	5089	18699	0	33013	2815	138524	1840	181115	199980	1733
20:30	50.02	199187	5087	18528	0	32712	2783	137219	1837	180659	198166	1769
20:45	49.92	198104	5095	18586	0	32811	2777	136437	1854	179518	197560	1703
21:00	49.97	197260	5115	18247	0	33100	2796	136313	1850	179013	197421	1690
21:15	49.97	196029	5117	17881	0	33260	2781	135500	1820	178148	196359	1720
21:30	49.97	195127	5125	17574	0	33227	2728	134970	1871	177553	195495	1707
21:45	50.02	194315	5139	17361	0	33174	2632	134526	1876	176954	194708	1621
22:00	50.07	194006	5142	17368	0	32973	2572	134530	1833	176638	194418	1635
22:15	50.02	194258	5141	17340	0	32959	2684	134598	1853	176918	194575	1681
22:30	50.											