



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 13-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 12.05.2024.

महोदय/Dear Sir,

आई०ई०जी०सी०-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 12-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 12-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 13-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	64778	60169	44447	25025	3059	197478
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1454	1499	1118	530	57	4659
Hydro Gen (MU)	292	40	23	17	18	391
Wind Gen (MU)	13	58	34	-	-	105
Solar Gen (MU)*	173.99	90.42	118.44	3.50	1.40	388
Energy Shortage (MU)	0.03	0.00	0.00	0.00	0.00	0.03
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66947	67754	50750	26453	3111	206852
Time Of Maximum Demand Met	22:36	14:48	11:58	22:55	19:01	22:57

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.00	6.39	6.39	80.75	12.86

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8607	0	193.2	91.7	-1.7	160	0.00
	Haryana	8618	0	189.8	143.3	-1.9	192	0.00
	Rajasthan	14047	0	294.0	91.2	-0.2	441	0.00
	Delhi	6078	0	119.5	98.7	3.5	455	0.00
	UP	25215	0	521.3	225.9	0.3	396	0.00
	Uttarakhand	2210	0	47.7	25.9	0.0	184	0.00
	HP	1455	0	29.5	1.7	-1.0	42	0.03
	J&K(UT) & Ladakh(UT)	2626	0	49.2	27.6	-1.2	252	0.00
	Chandigarh	277	0	5.6	5.5	0.2	42	0.00
WR	Railways_NR ISTS	206	0	4.2	4.0	0.2	37	0.00
	Chhattisgarh	5011	0	110.8	50.8	-1.3	353	0.00
	Gujarat	22429	0	466.9	196.3	-0.5	546	0.00
	MP	12737	0	279.0	157.2	-6.3	330	0.00
	Maharashtra	24815	0	567.0	188.5	-3.8	613	0.00
	Goa	678	0	14.9	13.0	1.5	48	0.00
	DNHDDPDCL	1278	0	29.2	29.2	0.0	42	0.00
	AMNSIL	877	0	19.0	9.4	-0.1	287	0.00
	BALCO	525	0	12.5	12.5	0.0	10	0.00
SR	Andhra Pradesh	10983	0	224.5	77.6	-0.7	505	0.00
	Telangana	8750	0	188.4	74.8	-1.2	399	0.00
	Karnataka	12232	0	240.0	112.3	-5.1	880	0.00
	Kerala	4559	0	87.7	79.0	-0.5	258	0.00
	Tamil Nadu	16928	0	367.0	241.8	-5.8	393	0.00
	Puducherry	476	0	10.7	10.4	-0.3	33	0.00
ER	Bihar	5988	0	122.2	109.3	2.0	469	0.00
	DVC	3266	0	71.2	-37.3	0.4	286	0.00
	Jharkhand	1943	0	39.3	28.2	-1.2	225	0.00
	Odisha	6068	0	120.9	44.2	0.4	485	0.00
	West Bengal	8930	0	175.6	43.4	-1.3	233	0.00
	Sikkim	65	0	1.0	1.3	-0.4	21	0.00
	Railways_ER ISTS	12	0	0.2	0.1	0.0	0	0.00
NER	Arunachal Pradesh	151	0	3.0	3.1	-0.2	9	0.00
	Assam	1967	0	36.3	29.1	0.4	168	0.00
	Manipur	193	0	2.9	3.0	-0.1	20	0.00
	Meghalaya	292	0	5.7	4.2	-0.4	46	0.00
	Mizoram	108	0	1.8	1.6	-0.3	13	0.00
	Nagaland	146	0	2.6	2.7	-0.1	7	0.00
	Tripura	308	0	5.1	4.9	0.0	40	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.5	-8.0	-22.8	-13.0
Day Peak (MW)	-377.0	-600.4	-1062.0	-722.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	193.9	-272.5	179.4	-107.1	6.3	0.0
Actual(MU)	187.2	-252.4	156.2	-101.8	5.2	-5.7
O/D/U/D(MU)	-6.8	20.1	-23.2	5.3	-1.1	-5.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2830	7741	2752	3456	351	17130	54
State Sector	4293	4932	2955	2071	110	14360	46
Total	7123	12672	5707	5527	461	31490	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	797	1613	700	696	14	3820	75
Lignite	19	16	57	0	0	92	2
Hydro	292	40	23	17	18	391	8
Nuclear	31	38	75	0	0	144	3
Gas, Naptha & Diesel	23	37	11	0	24	96	2
RES (Wind, Solar, Biomass & Others)	195	150	175	5	1	526	10
Total	1357	1893	1043	718	58	5069	100

Share of RES in total generation (%)	14.37	7.90	16.81	0.66	2.46	10.38
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	38.16	12.03	26.28	3.02	33.79	20.93

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.039
Based on State Max Demands	1.068

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	204587	15:01	6
Non-Solar hr	206852	22:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 13-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	0.0	0.1	-0.1
3	765 kV	GAYA-VARANASI	2	486	1127	0.0	10.8	-10.8
4	765 kV	SASARAM-FATEHPUR	1	153	591	0.0	7.6	-7.6
5	765 kV	GAYA-BALIA	1	0	802	0.0	12.6	-12.6
6	400 kV	PUSAULI-VARANASI	1	40	60	0.0	0.1	-0.1
7	400 kV	PUSAULI -ALLAHABAD	1	65	38	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	159	685	0.0	7.9	-7.9
9	400 kV	PATNA-BALIA	2	0	1014	0.0	14.3	-14.3
10	400 kV	NAUBATPUR-BALIA	2	29	646	0.0	4.3	-4.3
11	400 kV	BIHARSHARIFF-BALIA	2	264	260	0.0	0.0	0.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	571	0.0	7.5	-7.5
13	400 kV	BIHARSHARIFF-VARANASI	2	2	9	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	11	137	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	67.2	-66.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1734	0	25.4	0.0	25.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	720	473	6.5	0.0	6.5
3	765 kV	JHARSUGUDA-DURG	2	0	1164	0.0	20.9	-20.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	559	0.0	5.9	-5.9
5	400 kV	RANCHI-SIPAT	2	287	72	3.4	0.0	3.4
6	220 kV	BUDHIPADAR-RAIGARH	1	10	102	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	111	50	0.8	0.0	0.8
ER-WR						36.1	27.8	8.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	485	0.0	11.5	-11.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1445	0.0	34.9	-34.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2403	0.0	49.8	-49.8
4	400 kV	TALCHER-I/C	2	453	434	6.5	0.0	6.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	96.2	-96.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	363	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	631	0	7.2	0.0	7.2
3	220 kV	ALIPURDUAR-SALAKATI	2	66	21	0.7	0.0	0.7
ER-NER						11.4	0.0	11.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	649	0	16.0	0.0	16.0
NER-NR						16.0	0.0	16.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1610	0.0	32.2	-32.2
2	HVDC	VINDHYACHAL B/B	-	198	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	977	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	2324	0.0	32.0	-32.0
5	765 kV	GWALIOR-PHAGI	2	711	1557	2.9	18.9	-16.0
6	765 kV	JABALPUR-ORAI	2	0	1083	0.0	27.6	-27.6
7	765 kV	GWALIOR-ORAI	1	658	0	10.8	0.0	10.8
8	765 kV	SATNA-ORAI	1	0	1124	0.0	21.1	-21.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2069	246	21.2	0.3	21.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2932	0.0	53.1	-53.1
11	400 kV	ZERDA-KANKROLI	1	415	25	4.8	0.0	4.8
12	400 kV	ZERDA -BHINMAL	1	414	24	4.8	0.0	4.8
13	400 kV	VINDHYACHAL -RIHAND	1	964	0	22.1	0.0	22.1
14	400 kV	RAPP-SHUJALPUR	2	556	444	3.9	3.4	0.4
15	400 kV	NEEMUCH-Chittorgarh	2	633	400	4.5	3.5	1.0
16	220 kV	BHANPURA-RANPUR	1	0	115	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	46	5	0.4	0.0	0.4
19	220 kV	MALANPUR-AURAIYA	1	24	24	0.1	0.1	0.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						80.5	220.7	-140.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	307	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	3504	0.0	47.8	-47.8
3	765 kV	SOLAPUR-RAICHUR	2	160	716	0.1	5.6	-5.4
4	765 kV	WARDHA-NIZAMABAD	2	0	1727	0.0	27.3	-27.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2095	0.0	35.2	-35.2
6	400 kV	KOLHAPUR-KUDGI	2	1107	0	16.2	0.0	16.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	86	1.9	0.0	1.9
9	220 kV	XELDEM-AMBEWADI	1	1	124	1.4	0.0	1.4
WR-SR						19.6	123.1	-103.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	111	-17	39	0.93
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-207	112	-33	-0.80
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-212	-115	-158	-3.80
	NER	132kV GELEPHU-SALAKATI	-17	-10	-13	-0.32
	NER	132kV MOTANGA-RANGIA	33	0	21	0.50
NEPAL	NR	NEPAL IMPORT (FROM UP)	-76	0	-15	-0.35
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-76	0	-49	-1.18
	ER	NEPAL IMPORT (FROM BIHAR)	-300	-24	-121	-2.90
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-300	-12	-150	-3.60
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-940	-647	-850	-20.41
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-722	-405	-541	-12.98
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-122	0	-98	-2.36

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	4.56	0.00	0.00	0.00	0.00	0.00	4.56
Nepal	0.35	0.00	6.17	0.00	0.00	0.00	0.00	0.00	6.52
Bangladesh	20.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.47
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.82	0.00	10.73	0.00	0.00	0.00	0.00	0.00	31.55

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	2.46	0.00	0.00	2.46
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	2.46	0.00	0.00	2.80

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.34	0.00	-4.56	0.00	0.00	0.00	0.00	0.00	-4.22	
Nepal	-0.35	0.00	-6.17	0.00	0.00	0.00	2.46	0.00	0.00	-4.06
Bangladesh	-20.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.47
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.48	0.00	-10.73	0.00	0.00	0.00	2.46	0.00	0.00	-28.75