



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 14.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 13.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 13-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 13.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 14-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	51167	67768	52618	26110	2700	200363
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1250	1659	1365	555	47	4876
Hydro Gen (MU)	138	53	78	22	8	300
Wind Gen (MU)	7	131	36	-	-	174
Solar Gen (MU)*	192.61	144.70	149.82	4.09	0.58	492
Energy Shortage (MU)	0.07	0.95	0.00	0.00	0.15	1.17
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64014	76535	65290	26317	2782	230513
Time Of Maximum Demand Met	10:30	10:38	10:53	19:01	18:08	10:36

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.044	0.00	0.90	3.99	4.90	74.47	20.63

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9004	0	169.1	59.9	-2.0	469	0.00
	Haryana	8384	0	155.3	112.0	-1.9	359	0.00
	Rajasthan	16344	0	313.5	97.1	-2.8	1152	0.00
	Delhi	3950	0	74.6	67.0	-0.1	243	0.00
	UP	19372	0	398.1	108.7	-1.5	271	0.00
	Uttarakhand	1948	0	38.0	28.7	-0.4	77	0.00
	HP	1796	0	32.9	23.2	-0.7	433	0.00
	J&K(UT) & Ladakh(UT)	2826	0	60.5	54.9	-1.9	613	0.07
	Chandigarh	197	0	3.6	3.7	0.0	15	0.00
WR	Railways_NR ISTS	221	0	4.6	3.9	0.7	54	0.00
	Chhattisgarh	6263	0	141.4	75.1	0.4	319	0.00
	Gujarat	22358	313	450.6	185.1	-10.9	707	0.81
	MP	14799	39	299.3	165.0	-4.4	602	0.14
	Maharashtra	30675	0	685.0	255.6	0.2	1140	0.00
	Goa	810	0	17.1	15.6	1.0	66	0.00
	DNHDDPDCL	1330	0	30.8	30.6	0.2	83	0.00
	AMNSIL	757	0	16.1	10.2	0.1	214	0.00
	BALCO	537	0	12.8	12.7	0.1	14	0.00
SR	RIL JAMNAGAR	245	0	5.8	5.9	-0.1	0	0.00
	Andhra Pradesh	12802	0	247.5	81.9	0.9	576	0.00
	Telangana	16918	0	332.5	186.1	0.1	764	0.00
	Karnataka	17892	0	343.7	133.7	-0.2	1128	0.00
	Kerala	4907	0	92.1	77.9	-0.3	248	0.00
	Tamil Nadu	16691	0	339.1	207.5	-1.3	531	0.00
	Puducherry	429	0	9.6	9.2	-0.2	28	0.00
ER	Bihar	5485	0	110.0	101.9	1.8	161	0.00
	DVC	3355	0	71.2	-53.3	-0.1	319	0.00
	Jharkhand	2093	0	41.2	30.4	-0.9	152	0.00
	Odisha	5965	0	125.8	37.0	0.4	582	0.00
	West Bengal	9502	0	205.1	55.2	-0.9	571	0.00
	Sikkim	93	0	1.6	1.9	-0.3	7	0.00
	Railways_ER ISTS	20	0	0.2	0.1	0.0	3	0.00
NER	Arunachal Pradesh	173	0	3.5	3.0	0.4	47	0.00
	Assam	1592	0	26.0	21.9	0.4	117	0.00
	Manipur	203	0	2.4	2.6	-0.2	32	0.15
	Meghalaya	327	0	5.5	4.7	-0.2	223	0.00
	Mizoram	114	0	2.5	1.8	0.0	26	0.00
	Nagaland	145	0	2.2	2.2	0.0	21	0.00
	Tripura	283	0	5.1	4.3	0.4	50	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.4	-9.6	-23.8	-28.6
Day Peak (MW)	-588.0	-538.3	-1016.0	-1367.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	133.0	-260.8	254.5	-171.9	10.6	-34.6
Actual(MU)	124.2	-263.8	262.0	-145.7	10.6	-12.6
O/D/U/D(MU)	-8.8	-3.0	7.5	26.3	0.0	22.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4899	9578	3438	3332	701	21948	49
State Sector	7458	9389	4346	1651	187	23031	51
Total	12357	18967	7784	4983	888	44979	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	803	1665	733	763	10	3974	75
Lignite	26	15	58	0	0	100	2
Hydro	138	53	78	22	8	300	6
Nuclear	21	26	73	0	0	119	2
Gas, Naptha & Diesel	8	24	8	0	22	62	1
RES (Wind, Solar, Biomass & Others)	222	279	228	6	1	737	14
Total	1218	2062	1179	792	41	5292	100

Share of RES in total generation (%)	18.27	13.53	19.36	0.80	1.41	13.92
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.28	17.39	32.16	3.63	20.97	21.85

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	230513	10:36	391
Non-Solar hr	202933	18:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 14-Mar-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	809	746	0.0	5.7	-5.7
4	765 kV	SASARAM-FATEHPUR	1	242	465	0.0	5.8	-5.8
5	765 kV	GAYA-BALIA	1	13	436	0.0	4.8	-4.8
6	400 kV	PUSAULI-VARANASI	1	0	135	0.0	2.3	-2.3
7	400 kV	PUSAULI -ALLAHABAD	1	41	47	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	516	262	0.0	1.0	-1.0
9	400 kV	PATNA-BALIA	2	137	780	0.0	12.6	-12.6
10	400 kV	NAUBATPUR-BALIA	2	67	258	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	472	86	3.0	0.0	3.0
12	400 kV	MOTIHARI-GORAKHPUR	2	131	368	0.0	4.7	-4.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	2.6	-2.6
14	220 kV	SAHUPURI-KARAMNASA	1	1	49	0.0	0.2	-0.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.6	45.8	-42.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	453	760	0.0	3.2	-3.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	768	1113	0.0	7.7	-7.7
3	765 kV	JHARSUGUDA-DURG	2	0	777	0.0	14.8	-14.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	707	0.0	10.7	-10.7
5	400 kV	RANCHI-SIPAT	2	200	374	0.0	3.6	-3.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	149	0.0	2.3	-2.3
7	220 kV	BUDHIPADAR-KORBA	2	117	72	0.1	0.0	0.1
ER-WR						0.1	42.2	-42.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	316	0.0	7.5	-7.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1882	0.0	40.3	-40.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2835	0.0	55.3	-55.3
4	400 kV	TALCHER-I/C	2	575	661	0.0	7.1	-7.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	103.0	-103.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	373	192	2.6	1.1	1.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	643	240	3.5	0.0	3.5
3	220 kV	ALIPURDUAR-SALAKATI	2	131	40	0.9	0.0	0.9
ER-NER						6.9	1.1	5.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	1096	0	16.7	0.0	16.7
NER-NR						16.7	0.0	16.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3016	0.0	78.0	-78.0
2	HVDC	VINDHYACHAL B/B	-	49	0	1.2	0.0	1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2367	0.0	53.9	-53.9
4	765 kV	GWALIOR-AGRA	2	1097	828	5.0	3.8	1.2
5	765 kV	GWALIOR-PHAGI	2	1311	973	5.6	10.6	-5.0
6	765 kV	JABALPUR-ORAI	2	461	429	0.2	0.0	0.2
7	765 kV	GWALIOR-ORAI	1	667	0	11.1	0.0	11.1
8	765 kV	SATNA-ORAI	1	0	826	0.0	14.9	-14.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1723	0	20.9	0.0	20.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	2063	0.0	24.9	-24.9
11	400 kV	ZERDA-KANKROLI	1	351	0	5.4	0.0	5.4
12	400 kV	ZERDA -BHINMAL	1	243	0	3.8	0.0	3.8
13	400 kV	VINDHYACHAL -RIHAND	1	486	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	630	13	7.3	0.0	7.3
15	400 kV	NEEMUCH-Chittorgarh	2	608	57	7.3	0.0	7.3
16	220 kV	BHANPURA-RANPUR	1	0	145	0.0	2.3	-2.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	136	0	2.1	0.0	2.1
19	220 kV	MALANPUR-AURAIYA	1	100	0	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						81.8	190.2	-108.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	19.5	-19.5
2	HVDC	RAIGARH-PUGALUR	2	0	5515	0.0	114.9	-114.9
3	765 kV	SOLAPUR-RAICHUR	2	997	1221	4.2	8.2	-4.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2745	0.0	42.1	-42.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2802	0.0	45.1	-45.1
6	400 kV	KOLHAPUR-KUDGI	2	1651	0	25.6	0.0	25.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	126	2.6	0.0	2.6
WR-SR						32.4	229.8	-197.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	242	-145	61	1.47	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-270	75	-80	-1.92	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-223	-107	-158	-3.78	
	NER	132kV GELEPHU-SALAKATI	-28	0	-4	-0.10	
	NER	132kV MOTANGA-RANGIA	-27	-1	-4	-0.09	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-52	0	-42	-1.02	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-52	0	-34	-0.82	
	ER	NEPAL IMPORT (FROM BIHAR)	-163	-95	-134	-3.22	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-375	-17	-188	-4.52	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-948	-887	-930	-22.31	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1368	-909	-1194	-28.65	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-68	0	-63	-1.51	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	6.74	0.00	0.00	0.33	0.00	0.00	7.46
Nepal	3.93	0.00	4.85	0.00	0.00	0.81	0.00	0.00	9.59
Bangladesh	23.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.16
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.09	0.39	11.59	0.00	0.00	1.14	0.00	0.00	40.21

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.40
Nepal	0.00	0.00	0.00	0.00	0.00	0.66	0.00	0.00	0.66
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.40	0.00	0.00	0.00	0.00	0.66	0.00	0.00	3.06

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.40	-0.39	-6.74	0.00	0.00	-0.33	0.00	0.00	-5.06
Nepal	-3.93	0.00	-4.85	0.00	0.00	-0.15	0.00	0.00	-8.93
Bangladesh	-23.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.16
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.69	-0.39	-11.59	0.00	0.00	-0.48	0.00	0.00	-37.15

Date of Reporting: 14-Mar-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	50.02	188112	4325	8272	245	9758	2318	165782	2366	179595	193066	-1664
0:15	49.77	187774	4309	8099	240	8403	2400	166924	2333	179435	192708	-1745
0:30	50.02	188273	4288	7948	235	8599	2388	167411	2261	180090	193130	-1755
0:45	50.02	187321	4316	7796	234	8311	2405	166957	2270	179291	192289	-1770
1:00	50.02	186850	4307	7685	235	8108	2405	166540	2275	178930	191555	-1778
1:15	50.02	185899	4317	7650	240	7975	2289	165986	2250	178009	190707	-1791
1:30	50.02	185254	4338	7749	242	7557	2339	165308	2278	177263	189811	-1726
1:45	50.07	183914	4337	7786	245	7439	2343	164433	2317	175883	188900	-1736
2:00	50.07	182899	4343	7985	245	7008	2406	163431	2263	174669	187681	-1774
2:15	50.02	182130	4317	8026	240	6178	2434	163438	2358	173864	186991	-1727
2:30	50.02	181413	4312	8053	240	6430	2429	162382	2329	173120	186175	-1746
2:45	50.02	180927	4311	8037	247	6340	2409	161972	2315	172643	185631	-1728
3:00	50.02	180565	4308	8278	247	6193	2403	161634	2321	172040	185384	-1733
3:15	50.02	181121	4308	8453	253	5875	2439	162488	2323	172415	186139	-1729
3:30	50.06	180985	4313	8474	246	6297	2430	161701	2317	172265	185778	-1678
3:45	50.01	181399	4433	8497	238	6455	2447	161823	2314	172664	186207	-1697
4:00	50.01	181757	4334	8283	241	6492	2422	162397	2283	173233	186452	-1704
4:15	49.96	183630	4506	8173	247	7082	2441	163999	2293	175210	188741	-1720
4:30	50.06	185199	4513	7985	244	8151	2401	164541	2294	176970	190129	-1720
4:45	50.01	185690	4522	7871	241	8554	2376	164764	2351	177578	190679	-1680
5:00	50.06	186994	4548	7678	248	8746	2477	165439	2363	179068	191499	-1337
5:15	49.91	189010	4520	7651	262	9290	2523	167296	2354	181097	193896	-1332
5:30	50.01	191779	4532	7728	254	10481	2532	168822	2367	183797	196716	-1370
5:45	50.01	194061	4572	7788	251	12285	2544	169390	2382	186022	199212	-1373
6:00	50.01	195333	4583	7694	244	14147	2567	168611	2348	187395	200194	-1342
6:15	50.06	198573	4583	7606	333	17666	2538	168487	2366	190634	203579	-1308
6:30	50.11	203068	4558	7574	377	21402	2554	169314	2371	195117	208150	-1307
6:45	50.01	206351	4595	7477	739	23574	2648	169828	2379	198135	211240	-1152
7:00	50.06	208611	4576	7327	1771	24706	2750	169525	2388	199513	213043	-1119
7:15	50.01	210291	4585	7054	3645	24482	2781	169713	2492	199592	214752	-1107
7:30	50.06	212063	4580	6777	6540	24177	2773	168818	2491	198746	216156	-1159
7:45	50.06	212262	4563	6500	10198	22859	2757	167076	2496	195564	216449	-1374
8:00	50.11	212577	4523	6196	14973	20029	2729	165468	2471	191408	216389	-1405
8:15	50.01	215213	4488	6103	20074	17324	2690	165978	2495	189036	219152	-1406
8:30	50.06	216076	4481	5760	25123	15134	2647	164049	2508	185193	219702	-1424
8:45	50.06	218509	4514	5095	30851	13701	2620	162773	2533	182563	222087	-1325
9:00	50.06	218842	4504	4486	35573	11612	2579	161135	2613	178783	222502	-1294
9:15	49.96	222910	4496	3897	39857	10217	2615	162671	2521	179156	226274	-1333
9:30	49.90	225639	4490	3261	43764	9652	2627	162612	2625	178614	229031	-1610
9:45	50.01	226969	4532	2767	47479	9769	2595	160853	2607	176723	230602	-1795
10:00	50.01	227120	4529	2381	50783	9230	2555	158527	2606	173956	230611	-1797
10:15	50.01	229557	4470	2273	54454	8614	2786	158282	2621	172830	233500	-1777
10:30	50.01	229965	4481	2402	56582	8223	2797	156659	2572	170981	233716	-1762
10:45	50.06	230327	4481	2671	58377	8157	2868	155192	2576	169279	234322	-1953
11:00	50.06	229640	4475	2891	60159	8821	2903	151700	2611	166590	233560	-1958
11:15	50.01	228890	4480	3198	61473	8182	3013	149763	2589	164219	232698	-1952
11:30	50.06	228303	4475	3457	62510	8042	2991	147660	2608	162336	231743	-1950
11:45	49.96	227061	4524	3725	62928	8222	3029	145910	2610	160408	230948	-1925
12:00	50.06	225356	4450	4181	63306	8397	3019	143154	2609	157869	229116	-1837
12:15	50.01	224257	4448	4638	63547	7828	3008	141917	2596	156072	227982	-1691
12:30	50.06	224238	4449	5084	63843	7471	2991	141057	2638	155311	227533	-1696
12:45	50.06	222828	4453	5614	63637	7559	2990	139844	2573	153577	226670	-1684
13:00	50.16	220548	4453	6187	63528	7071	3000	137331	2558	150833	224128	-1711
13:15	50.21	217776	4457	6708	63380	6269	3026	135253	2518	147688	221611	-1691
13:30	50.16	216243	4462	7105	62692	6281	3075	133927	2555	146446	220097	-1702
13:45	50.01	215861	4454	7285	62202	6265	3091	133497	2607	146374	219401	-1512
14:00	50.01	216404	4469	7363	61163	6914	3021	134214	2522	147878	219666	-1494
14:15	49.96	216909	4430	7461	60306	6877	2996	135708	2515	149142	220293	-1532
14:30	50.01	217727	4447	7653	58917	7421	3036	135192	2511	151157	219177	-1552
14:45	49.96	218156	4453	7719	56494	7774	3036	139751	2485	153943	221712	-1541
15:00	49.96	219049	4545	7752	53664	31437	3042	139205	2700	157633	242345	-703
15:15	49.96	218399	4455	7749	51964	7695	3045	144385	2487	158686	221780	-1418
15:30	49.91	217670	4428	7857	48238	8138	3053	146784	2456	161575	220954	-1452
15:45	49.91	218069	4412	7820	45178	8337	3039	150147	2586	165071	221519	-1453
16:00	49.96	218848	4379	7972	42306	9666	3048	152610	2587	168570	222568	-1465
16:15	49.96	215628	4371	7925	38679	9431	3074	153496	2508	169024	219484	-1474
16:30	49.91	215594	4367	8035	34722	10495	3175	156389	2336	172837	219519	-1440
16:45	49.96	214956	4344	8089	30612	11034	3213	159112	2331	176255	218735	-1265
17:00	50.06	213079	4261	8162	26051	13192	3194	159614	2319	178866	216793	-1158
17:15	50.01	208942	4244	8130	20983	14417	3080	159169	2305	179829	212328	-1016
17:30	50.06	206483	4243	8042	16419	16447	3182	159472	2309	182022	210114	-1051
17:45	49.96	203676	4275	7887	11409	18073	3185	160385	2351	184380	207565	-1006
18:00	50.06	201520	4280	7691	7377	19073	3211	161431	2318	186452	205381	-1026
18:15	50.06	198113	4279	7461	4274	19557	3204	161043	2327	186378	202145	-1032
18:30	49.96	199701	4273	7451	2211	21333	3213	162831	2329	190039	203641	-960
18:45	50.01	201919	4273	7282	989	22547	3262	164858	2348	193648	205559	-921
19:00	50.01	202810	4281	7256	429	23069	3266	165879	2324	195125	206504	-917
19:15	50.06	202774	4285	7424	161	22063	3356	166795	2331	195189	206415	-943
19:30	50.06	201297	4274	7528	126	20836	3306	166473	2360	193643	204903	-927
19:45	50.01	199207	4259	7644	145	19602	3138	165416	2388	191418	202592	-936
20:00	50.06	196318	4266	7713	137	17646	3102	164542	2401	188468	199807	-953
20:15	50.06	194481	4291	7856	131	16312	3064	163730	2339	186494	197723	-1025
20:30	50.06	193079	4314	8056	135	15910	3020	162357	2346	184888	196138	-1037
20:45	50.01	191220	4310	8256	133	14721	2632	161964	2352	182831	194368	-1044
21:00	50.01	189235	4294	8433	133	13856	2600	160976	2352	180669	192644	-1007
21:15	49.96	188573	4230	8679	134	12948	2444	161162	2425	179760	192022	-1084
21:30	50.01	188365	4257	8705	99	12808	2378	160992	2418	179561	191657	-1094
21:45	49.91	188119	4301	8789	99	12771	2378	161176	2378	179231	191892	-1368
22:00	50.06	187296	4316	8889	99	12970	2356	160310	2340	178308	191280	-1410
22:15	50.01	189345	4296	8985	99	12821	2226	162654	2367	180261	193448	-1383
22:30	49.96	189959	4305									