



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52309	62923	47607	21665	2761	187265
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1167	1471	1090	445	51	4224
Hydro Gen (MU)	125	46	103	31	16	321
Wind Gen (MU)	12	61	67	-	-	140
Solar Gen (MU)*	172.33	149.93	98.49	2.98	0.84	425
Energy Shortage (MU)	0.14	0.34	0.00	0.00	0.00	0.48
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59268	69301	53697	22274	2988	204324
Time Of Maximum Demand Met	09:57	09:53	09:57	17:50	17:03	09:57

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.067	0.91	2.79	9.14	12.85	79.03	8.12

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8059	0	152.0	62.6	-0.1	239	0.00
	Haryana	7885	0	156.6	130.0	-1.0	193	0.00
	Rajasthan	16784	0	318.9	91.1	2.3	1501	0.00
	Delhi	4005	0	73.0	66.8	0.6	328	0.00
	UP	17063	0	320.5	64.1	-3.0	356	0.00
	Uttarakhand	2159	0	40.7	30.2	0.3	123	0.14
	HP	2107	0	36.6	25.8	-0.7	83	0.00
	J&K(UT) & Ladakh(UT)	2970	0	60.7	54.4	-1.6	86	0.00
	Chandigarh	195	0	3.5	3.5	0.0	17	0.00
	Railways_NR ISTS	201	0	4.0	3.8	0.2	36	0.00
WR	Chhattisgarh	4541	0	89.4	39.0	0.1	358	0.34
	Gujarat	21969	0	432.6	200.3	-0.6	963	0.00
	MP	17906	0	316.6	194.2	0.5	651	0.00
	Maharashtra	26137	0	548.4	179.2	2.6	818	0.00
	Goa	732	0	15.2	12.2	2.5	60	0.00
	DNHDDPDCL	1346	0	30.1	29.9	0.2	70	0.00
	AMNSIL	874	0	19.2	11.6	0.6	308	0.00
	BALCO	539	0	12.9	12.8	0.1	31	0.00
	RIL JAMNAGAR	261	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	9469	0	204.6	55.7	-0.3	457	0.00
SR	Telangana	10372	0	194.1	110.3	-0.1	878	0.00
	Karnataka	14647	0	267.8	100.7	-0.6	652	0.00
	Kerala	4344	0	88.5	69.7	0.3	306	0.00
	Tamil Nadu	16127	0	326.9	214.1	-1.0	1111	0.00
	Puducherry	383	0	8.5	7.9	0.0	38	0.00
	Bihar	4627	0	91.4	76.5	1.1	144	0.00
ER	DVC	3066	0	64.1	-36.9	-0.3	379	0.00
	Jharkhand	2076	0	38.8	26.6	-1.5	196	0.00
	Odisha	5344	0	97.4	22.1	-2.9	383	0.00
	West Bengal	7527	0	151.2	42.9	-2.0	150	0.00
	Sikkim	102	0	1.6	1.5	0.0	40	0.00
	Railways_ER ISTS	17	0	0.1	0.2	0.0	0	0.00
NER	Arunachal Pradesh	171	0	3.0	2.8	0.1	22	0.00
	Assam	1679	0	30.1	23.0	0.6	104	0.00
	Manipur	231	0	3.4	3.4	0.0	85	0.00
	Meghalaya	354	0	6.0	4.9	-0.1	43	0.00
	Mizoram	149	0	2.2	1.2	-0.3	5	0.00
	Nagaland	168	0	2.6	2.4	0.0	12	0.00
	Tripura	235	0	4.0	5.6	-0.1	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	1.3	14.6	-22.2	-23.9
Day Peak (MW)	-131.1	880.2	-1005.9	-1475.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	154.1	-171.2	200.3	-188.6	5.4	0.0
Actual(MU)	147.6	-161.2	192.0	-196.0	3.3	-14.3
O/D/U/D(MU)	-6.5	10.0	-8.3	-7.4	-2.2	-14.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6968	14141	8078	5140	224	34550	46
State Sector	12019	13101	11168	3417	306	40011	54
Total	18987	27242	19246	8557	530	74561	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	714	1398	596	674	14	3396	74
Lignite	23	15	36	0	0	73	2
Hydro	125	46	103	31	16	321	7
Nuclear	27	52	41	0	0	120	3
Gas, Naptha & Diesel	13	23	4	0	23	63	1
RES (Wind, Solar, Biomass & Others)	204	212	200	5	1	622	14
Total	1106	1747	981	710	53	4597	100

Share of RES in total generation (%)	18.47	12.16	20.38	0.69	1.57	13.54
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.21	17.81	35.12	5.05	31.59	23.16

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.061

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	204324	9:57	0
Non-Solar hr	194994	18:20	173

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 23-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	0	1462	0.0	22.8	-22.8
4	765 kV	SASARAM-FATEHPUR	1	0	699	0.0	11.4	-11.4
5	765 kV	GAYA-BALIA	1	0	599	0.0	9.7	-9.7
6	400 kV	PUSAULI-VARANASI	1	24	70	0.0	0.7	-0.7
7	400 kV	PUSAULI-ALLAHABAD	1	0	119	0.0	1.7	-1.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	764	0.0	9.7	-9.7
9	400 kV	PATNA-BALIA	2	0	928	0.0	15.3	-15.3
10	400 kV	NAUBATPUR-BALIA	2	38	265	0.0	4.9	-4.9
11	400 kV	BIHARSHARIFF-BALIA	2	187	282	0.0	1.0	-1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	546	0.0	7.0	-7.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	30	518	0.0	6.2	-6.2
14	220 kV	SAHUPURI-KARMANASA	1	39	0	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	94.1	-93.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	145	1069	0.0	13.0	-13.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	137	946	0.0	13.2	-13.2
3	765 kV	JHARSUGUDA-DURG	2	0	1314	0.0	26.3	-26.3
4	400 kV	JHARSUGUDA-RAIGARH	4	167	426	0.0	3.8	-3.8
5	400 kV	RANCHI-SIPAT	2	51	375	0.0	4.9	-4.9
6	400 kV	JEYPORE-JACDALPUR	2	269	304	0.0	0.0	0.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	143	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	48	136	0.0	0.7	-0.7
ER-WR						0.8	63.9	-63.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	311	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1621	0.0	37.0	-37.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2711	0.0	47.8	-47.8
4	400 kV	TALCHER-UC	2	300	546	0.8	0.0	0.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	7	0	0.0	0.0	0.0
ER-SR						0.0	92.1	-92.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	318	32	3.4	0.0	3.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	624	18	5.9	0.0	5.9
3	220 kV	ALIPURDUAR-SALAKATI	2	107	6	1.1	0.0	1.1
ER-NER						10.4	0.0	10.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	655	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2013	0.0	48.2	-48.2
2	HVDC	VINDHYACHAL B/B	-	192	0	0.0	1.7	-1.7
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	295	1063	1.3	9.6	-8.3
5	765 kV	GWALIOR-PHAGI	2	461	1812	0.6	27.5	-26.9
6	765 kV	JABALPUR-ORAI	2	104	683	0.0	17.0	-17.0
7	765 kV	GWALIOR-ORAI	1	934	0	15.5	0.0	15.5
8	765 kV	SATNA-ORAI	1	0	1046	0.0	18.1	-18.1
9	765 kV	BANASKANTHA-CHITTORGARH	2	2666	0	34.0	0.0	34.0
10	765 kV	VINDHYACHAL-VARANASI	2	522	1434	0.0	12.1	-12.1
11	400 kV	ZERDA-KANKROLI	1	433	0	6.3	0.0	6.3
12	400 kV	ZERDA -BHINMAL	1	299	0	4.3	0.0	4.3
13	400 kV	VINDHYACHAL -RIHAND	1	989	1	12.1	0.0	12.1
14	400 kV	RAPP-SHUJALPUR	2	611	122	4.4	0.3	4.2
15	400 kV	NEEMUCH-Chittorgarh	2	659	211	4.3	0.6	3.7
16	220 kV	BHANPURA-RANPUR	1	0	127	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	161	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	129	0	0.9	0.0	0.9
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						85.0	162.8	-77.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	997	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4013	0.0	89.8	-89.8
3	765 kV	SOLAPUR-RAICHUR	2	697	1236	1.6	4.5	-3.0
4	765 kV	WARDHA-NIZAMABAD	2	0	1616	0.0	22.9	-22.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2523	0.0	35.7	-35.7
6	400 kV	KOLHAPUR-KUDGI	2	1576	0	26.7	0.0	26.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	0.0	2.2	0.0
WR-SR						30.5	176.9	-146.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	96	26	96	3.32	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	231	115	160	3.85	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-193	-148	-172	-4.14	
	NER	132kV GELEPHU-SALAKATI	-77	-63	-65	-1.56	
	NER	132kV MOTANGA-RANGIA	-41	0	-29	-0.70	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.91	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	795	604	645	15.48	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-908	-690	-844	-20.25	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1475	-816	-997	-23.92	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-98	0	-81	-1.94	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 23-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.37	0.00	0.00	0.00	0.00	0.00	0.00	0.37
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	21.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.14
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.14	0.37	0.00	0.00	0.00	0.00	0.00	0.00	21.51

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	11.65	0.00	0.00	0.00	4.25	0.00	0.00	15.90
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	11.65	0.00	0.00	0.00	4.25	0.00	0.00	15.90

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	-0.37	0.00	0.00	0.00	0.00	0.00	0.00	-0.37	
Nepal	0.00	0.00	11.65	0.00	0.00	0.00	4.25	0.00	0.00	15.90
Bangladesh	-21.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.14
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.14	-0.37	11.65	0.00	0.00	0.00	4.25	0.00	0.00	-5.61

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.05	147937	4682	8986	0	8421	2169	123769	2956	138951	150983	-111
0:15	49.95	147519	4690	8800	0	8135	2183	123875	2921	138719	150604	-104
0:30	50.00	146008	4680	8439	0	8205	2169	122731	2885	137569	149109	6
0:45	49.95	145314	4681	8191	0	8184	2187	122256	2896	137123	148395	22
1:00	49.95	144467	4689	8048	0	8153	2182	121293	2967	136419	147332	53
1:15	49.95	143246	4650	8024	0	8009	2155	120232	2883	135222	145953	113
1:30	49.95	142443	4472	8025	0	8139	2164	119599	2907	134418	145306	132
1:45	49.95	142119	4479	7826	0	8082	2169	119198	2905	134293	144659	108
2:00	50.00	140981	4473	7733	0	8004	2156	118273	2931	133248	143570	85
2:15	49.95	140551	4482	7673	0	8064	2176	117800	2900	132878	143095	96
2:30	50.00	140465	4479	7618	0	8019	2167	117571	2933	132847	142787	88
2:45	50.00	140577	4481	7709	0	7752	2170	117855	2946	132868	142913	39
3:00	50.00	139936	4483	7668	0	7716	2162	117444	2906	132268	142379	68
3:15	49.95	140139	4488	7613	0	7700	2194	117723	2984	132526	142702	41
3:30	49.95	140252	4480	7521	0	7941	2213	117853	2954	132731	142962	41
3:45	49.95	140132	4473	7513	0	7708	2206	118064	2930	132619	142894	9
4:00	50.00	140313	4476	7482	0	7666	2219	118451	2916	132831	143210	0
4:15	49.84	142509	4479	7435	0	7999	2269	120370	2935	135074	145487	8
4:30	49.94	143439	4466	7349	0	8437	2251	121354	2933	136090	146790	-20
4:45	49.89	145993	4478	7198	0	8755	2282	123707	2954	138795	149374	-43
5:00	49.99	148229	4474	7100	-18	9164	2267	126046	2931	141147	151964	-51
5:15	49.94	153249	4480	7070	30	10182	2437	130158	2897	146149	157254	-61
5:30	49.99	157033	4477	7081	40	10757	2862	133394	3009	149912	161620	-77
5:45	50.04	161427	4474	7156	46	12271	3181	136478	2964	154225	166570	-61
6:00	50.14	165049	4476	7249	25	14553	3522	138215	3017	157775	171057	-88
6:15	50.10	169853	4470	7269	38	17247	3482	140773	2928	162546	176207	-267
6:30	50.04	175261	4487	7387	97	19158	3421	144073	2942	167777	181565	-247
6:45	49.99	179739	4490	7582	476	20307	3556	146430	2950	171681	185791	-227
7:00	50.05	182998	4490	7723	1321	21103	3806	147527	2946	173954	188916	-240
7:15	50.05	186480	4473	7645	2918	21722	4309	148265	2925	175917	192257	-242
7:30	50.05	188787	4487	7569	5401	22174	4425	147215	2981	175817	194252	-235
7:45	50.05	189953	4487	7241	9499	20295	2629	147679	3004	173213	194834	-209
8:00	50.05	188995	4493	6786	15727	17135	2189	145437	3054	166482	194821	-187
8:15	49.95	190970	4483	6527	21037	14952	2150	144412	3075	163406	196636	-234
8:30	50.05	193933	4486	6433	27101	13592	2149	142343	3186	160399	199290	-238
8:45	49.94	194766	4484	6196	32768	12393	2151	138713	3117	155802	199822	-189
9:00	50.09	195753	4481	6271	37520	11765	2147	135441	3084	151962	200709	-188
9:15	49.94	200443	4480	6238	41566	10950	2135	136526	3107	152639	205002	-194
9:30	50.04	203346	4487	5995	45896	10764	2135	135346	3149	151455	207772	-194
9:45	49.99	203771	4486	5643	48870	9511	2126	134027	3130	149528	207793	-159
10:00	49.99	204013	4479	5241	52243	9193	2149	131704	3179	146529	208188	-160
10:15	49.94	202728	4471	5035	53863	8636	2141	129661	3133	143830	206940	-187
10:30	49.99	202598	4483	4832	55687	8788	2134	127661	3200	142079	206785	-233
10:45	49.94	202038	4466	4711	56764	8633	2124	126347	3233	140563	206278	-246
11:00	49.99	200884	4471	4667	57996	8495	2116	124144	3192	138221	205081	-293
11:15	49.94	199068	4451	4510	58586	8121	2125	121781	3228	135972	202802	-387
11:30	49.94	198189	4459	4498	59352	7894	2070	120383	3165	134339	201821	-518
11:45	50.04	198108	4470	4229	60537	7629	2036	118892	3283	133342	201076	-464
12:00	50.04	196518	4444	3896	60739	7833	2024	117402	3148	131883	199486	-458
12:15	49.99	194580	4450	3845	61392	7459	2043	115285	3168	129343	197642	-469
12:30	49.99	193706	4466	3758	60891	7341	2047	114715	3137	129057	196355	-482
12:45	49.94	192753	4451	3753	59513	7164	2059	114591	3185	129487	194716	-493
13:00	50.04	190693	4458	3736	59667	7345	2040	112458	3158	127290	192862	-473
13:15	49.99	187300	4468	3781	58844	6970	2038	110090	3178	124675	189369	-530
13:30	49.99	187219	4447	3740	57810	6959	2022	111492	3238	125669	189708	-553
13:45	49.94	187815	4443	3519	56195	6744	2027	113875	3193	128101	189996	-545
14:00	49.94	187928	4445	3447	54425	6474	2024	116070	3199	130056	190084	-533
14:15	49.93	188829	4433	3349	52123	6762	2112	119199	3148	133357	191126	-553
14:30	49.99	190343	4444	3255	49987	7298	2106	122428	3140	137101	192658	-536
14:45	49.94	190999	4442	2980	48246	7571	2098	124692	3186	139773	193215	-535
15:00	49.89	192051	4437	2560	45361	8355	2109	128716	3165	144130	194703	-561
15:15	49.94	190904	4448	2527	41782	9264	2143	130483	3136	146595	193783	-564
15:30	49.94	191575	4439	2628	38268	9935	2291	134061	3139	150679	194761	-560
15:45	49.83	191436	4441	2651	32819	10448	2718	139312	3046	155966	195435	-563
16:00	49.78	190985	4423	2651	28643	11287	2943	142680	3079	159691	195706	-570
16:15	49.89	189773	4433	2645	24255	11495	3422	144898	2990	162873	194138	-571
16:30	49.78	189456	4426	2783	18497	13325	3984	148785	3072	168176	194872	-566
16:45	49.84	190457	4450	2892	13589	16473	4296	151324	2976	173976	196000	-556
17:00	49.89	191009	4430	3019	8894	19554	4348	153180	2986	179096	196411	-564
17:15	49.84	190372	4450	3170	5489	22167	4425	153136	2946	181713	195783	-575
17:30	49.74	190083	4429	3570	2896	23812	4420	153643	2924	183617	195694	-595
17:45	49.68	191780	4439	3891	1377	26603	4417	153963	2915	186512	197605	-604
18:00	49.94	193779	4422	3946	835	28618	4401	154447	2924	188998	199593	-625
18:15	49.89	194895	4444	4158	706	29867	4463	154221	2937	190031	200796	-617
18:30	50.04	194345	4456	4361	695	29768	4419	153604	2934	189289	200237	-501
18:45	50.04	193515	4457	4645	629	28932	4332	153138	2980	188241	199113	-455
19:00	50.04	190576	4449	5050	597	28071	2847	152670	2917	184929	196601	-350
19:15	50.04	188013	4460	5267	593	25984	2437	152349	2956	182153	194046	-383
19:30	50.04	185688	4461	5441	0	25054	2378	150455	2960	180247	190749	-309
19:45	50.04	182265	4462	5536	0	23632	2345	148035	2944	176729	186954	-303
20:00	50.04	178237	4462	5744	0	20263	2327	146887	3041	172493	182724	-231
20:15	49.99	175766	4456	5952	0	17078	2261	146571	2963	169814	179281	-215
20:30	49.99	173609	4447	6089	0	16108	2267	145001	2992	167520	176904	-191
20:45	49.84	171379	4460	6130	0	15708	2285	143028	2964	165249	174575	-159
21:00	50.04	169180	4461	6031	0	15123	2278	141646	2970	163149	172509	-196
21:15	49.99	166514	4467	5914	0	13967	2260	140289	2948	160600	169845	-291
21:30	49.99	164688	4462	5746	0	13236	2247	139162	2916	158942	167769	-283
21:45	50.04	162920	4476	5646	0	12926	2250	137157	2935	157274	165390	-126
22:00	50.04	160081	4473	5543	0	11963	2218	135138	3006	154538	162341	-107
22:15	49.99	160222	4476	5600	0	12045	2200	135254	3001	154622	162576	-138
22:30	49.99	158909	4482	5582	0	11391	2170	134785	2981	153327	161391	-165
22:45	49.99	157168	4459	5578	0	10785	2173	133734	3018	151590	1597	