



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 11-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61849	65258	44457	22376	2715	196655
Peak Shortage (MW)	382	0	0	966	0	1348
Energy Met (MU)	1298	1541	1199	477	50	4565
Hydro Gen (MU)	91	42	104	19	11	268
Wind Gen (MU)	19	64	91	-	-	174
Solar Gen (MU)*	151.75	90.07	109.80	3.08	1.07	356
Energy Shortage (MU)	0.86	0.00	0.00	2.25	0.00	3.11
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68515	77085	61537	23624	2842	230846
Time Of Maximum Demand Met	10:48	10:21	09:57	17:38	17:34	10:26

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.06	0.50	6.58	7.14	77.88	14.98

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8496	0	158.7	63.0	0.9	487	0.00
	Haryana	8366	0	161.0	106.2	-0.1	362	0.34
	Rajasthan	18544	0	343.3	109.9	-0.4	635	0.00
	Delhi	5477	0	90.4	89.5	-1.4	462	0.00
	UP	21171	0	381.0	131.1	-2.5	270	0.00
	Uttarakhand	2568	0	47.5	38.5	0.7	162	0.12
	HP	2170	0	38.3	31.9	-0.6	205	0.00
	J&K(UT) & Ladakh(UT)	3180	84	69.3	64.0	1.2	1071	0.40
	Chandigarh	300	0	5.1	5.0	0.0	64	0.00
WR	Railways_NR ISTS	216	0	4.0	3.7	0.3	77	0.00
	Chhattisgarh	5489	0	109.8	59.5	-1.8	388	0.00
	Gujarat	22948	0	426.2	202.6	3.2	1609	0.00
	MP	17823	0	334.8	199.0	-2.3	713	0.00
	Maharashtra	28669	0	593.0	183.1	-0.8	469	0.00
	Goa	712	0	14.4	13.4	0.4	99	0.00
	DNHDDPDCL	1333	0	30.7	30.8	-0.1	32	0.00
	AMNSIL	753	0	16.7	6.7	0.6	325	0.00
	BALCO	533	0	12.7	12.7	0.0	9	0.00
SR	RIL JAMNAGAR	111	0	2.6	2.6	0.0	0	0.00
	Andhra Pradesh	11551	0	209.2	48.8	0.6	729	0.00
	Telangana	14367	0	268.3	147.4	-0.3	1090	0.00
	Karnataka	16528	0	288.8	88.2	1.4	814	0.00
	Kerala	4286	0	83.7	61.9	1.4	359	0.00
	Tamil Nadu	16654	0	340.7	197.3	-0.6	970	0.00
	Puducherry	394	0	8.7	8.4	-0.3	124	0.00
	Bihar	5494	0	104.4	96.8	-4.5	337	2.25
	DVC	3517	0	73.2	-43.3	0.2	271	0.00
ER	Jharkhand	2101	0	40.0	28.1	0.4	153	0.00
	Odisha	5260	0	105.2	35.1	-1.1	436	0.00
	West Bengal	7732	0	152.3	24.7	-1.7	174	0.00
	Sikkim	125	0	2.0	1.9	0.2	39	0.00
	Railways_ER ISTS	17	0	0.2	0.2	0.0	8	0.00
	Arunachal Pradesh	175	0	3.1	2.9	0.0	24	0.00
	Assam	1598	0	27.3	20.9	0.1	114	0.00
NER	Manipur	234	0	4.2	4.1	0.1	34	0.00
	Meghalaya	372	0	6.3	5.1	-0.3	75	0.00
	Mizoram	159	0	2.3	2.0	-0.2	21	0.00
	Nagaland	149	0	2.4	2.3	0.0	46	0.00
	Tripura	236	0	4.1	3.4	0.1	45	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.6	-6.6	-20.5	-12.6
Day Peak (MW)	-341.0	-467.3	-993.0	-761.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	252.7	-256.5	130.2	-130.9	4.5	0.0
Actual(MU)	250.6	-253.2	125.0	-133.1	2.8	-8.0
O/D/U/D(MU)	-2.1	3.3	-5.2	-2.3	-1.7	-8.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4643	8221	5048	5693	769	24373	45
State Sector	7878	11628	6943	3249	241	29938	55
Total	12521	19848	11991	8942	1010	54312	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	792	1625	656	669	15	3757	75
Lignite	22	15	63	0	0	100	2
Hydro	91	42	104	19	11	268	5
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	6	27	14	0	24	71	1
RES (Wind, Solar, Biomass & Others)	197	158	233	36	1	625	13
Total	1140	1921	1141	724	52	4978	100

Share of RES in total generation (%)	17.30	8.20	20.43	4.95	2.11	12.55
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.11	13.22	35.76	7.62	23.45	21.09

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.038

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	230846	10:26	55
Non-Solar hr	202952	18:38	799

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 11-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	0	0.0	3.8	-3.8
3	765 kV	GAYA-VARANASI	2	0	937	0.0	12.5	-12.5
4	765 kV	SASARAM-FATEHPUR	1	0	531	0.0	8.4	-8.4
5	765 kV	GAYA-BALIA	1	0	862	0.0	13.8	-13.8
6	400 kV	PUSAULI-VARANASI	1	0	168	0.0	2.2	-2.2
7	400 kV	PUSAULI -ALLAHABAD	1	84	130	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	623	0.0	6.6	-6.6
9	400 kV	PATNA-BALIA	2	0	766	0.0	11.7	-11.7
10	400 kV	NAUBATPUR-BALIA	2	0	518	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	0	278	0.0	5.5	-5.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	461	0.0	6.3	-6.3
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNESA	1	0	101	0.0	3.3	-3.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	78.7	-78.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	620	821	0.0	0.1	-0.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	954	599	5.0	0.0	5.0
3	765 kV	JHARSUGUDA-DURG	2	0	762	0.0	13.7	-13.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	576	0.0	8.0	-8.0
5	400 kV	RANCHI-SIPAT	2	232	237	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	128	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	136	24	1.6	0.0	1.6
ER-WR						6.6	23.6	-16.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	214	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1250	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2763	0.0	50.2	-50.2
4	400 kV	TALCHER-I/C	2	72	73	0.1	0.0	0.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	85.4	-85.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	283	0	4.0	0.0	4.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	454	0	7.1	0.0	7.1
3	220 kV	ALIPURDUAR-SALAKATI	2	82	0	1.5	0.0	1.5
ER-NER						12.6	0.0	12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	668	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3031	0.0	71.4	-71.4
2	HVDC	VINDHYACHAL B/B	-	261	100	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	31.5	-31.5
4	765 kV	GWALIOR-AGRA	2	0	2674	0.0	31.6	-31.6
5	765 kV	GWALIOR-PHAGI	2	94	1806	0.1	23.5	-23.4
6	765 kV	JABALPUR-ORAI	2	0	1337	0.0	32.5	-32.5
7	765 kV	GWALIOR-ORAI	1	814	0	14.6	0.0	14.6
8	765 kV	SATNA-ORAI	1	0	1113	0.0	19.6	-19.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1792	549	15.0	1.0	14.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2909	0.0	40.5	-40.5
11	400 kV	ZERDA-KANKROLI	1	335	78	3.0	0.1	2.9
12	400 kV	ZERDA -BHINMAL	1	232	54	2.1	0.1	2.0
13	400 kV	VINDHYACHAL -RIHAND	1	971	0	21.5	0.0	21.5
14	400 kV	RAPP-SHUJALPUR	2	588	450	2.9	1.9	1.1
15	400 kV	NEEMUCH-Chittorgarh	2	541	534	2.5	2.3	0.2
16	220 kV	BHANPURA-RANPUR	1	0	174	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	112	5	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	81	27	0.7	0.1	0.7
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						63.7	261.7	-198.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	510	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	2004	0.0	36.2	-36.2
3	765 kV	SOLAPUR-RAICHUR	2	1471	1007	8.0	5.5	2.5
4	765 kV	WARDHA-NIZAMABAD	2	257	2189	0.1	30.2	-30.1
5	765 kV	WARORA-WARANGAL(NEW)	2	303	2159	0.1	28.6	-28.5
6	400 kV	KOLHAPUR-KUDGI	2	1840	0	30.1	0.0	30.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	121	2.3	0.0	2.3
WR-SR						40.6	112.5	-71.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	182	-4	96	2.30	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-161	100	-52	-1.24	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-237	-95	-169	-4.06	
	NER	132kV GELEPHU-SALAKATI	-24	-3	-16	-0.39	
	NER	132kV MOTANGA-RANGIA	-34	0	-10	-0.25	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-1.10	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00	
	ER	NEPAL IMPORT (FROM BIHAR)	-162	-21	-81	-1.94	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-305	-24	-149	-3.57	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-926	-546	-802	-19.26	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-761	-406	-526	-12.62	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-67	0	-53	-1.26	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.30	5.17	0.00	0.00	0.00	0.00	0.00	5.47	
Nepal	2.06	0.00	2.74	0.00	0.00	0.00	0.83	0.00	0.00	5.63
Bangladesh	20.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.16	0.30	7.91	0.00	0.00	0.00	0.83	0.00	0.00	31.20

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	-0.30	-5.17	0.00	0.00	0.00	0.00	0.00	-4.11
Nepal	-2.06	0.00	-2.74	0.00	0.00	-0.83	0.00	0.00	-5.63
Bangladesh	-20.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.80	-0.30	-7.91	0.00	0.00	-0.83	0.00	0.00	-29.84

Date of Reporting: 11-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	155974	6234	10909	114	6034	2074	130913	3325	144951	159603	-1560
0:15	50.03	155317	6208	10957	109	6002	2073	130243	3367	144251	158959	-1446
0:30	50.03	154203	6224	10955	104	5868	2077	129249	3351	143144	157828	-1383
0:45	49.98	153119	6235	10971	102	5889	2076	127934	3357	142046	156564	-1350
1:00	49.98	152058	6224	10893	101	5843	2078	127030	3382	141064	155551	-1371
1:15	50.03	150593	6222	10907	98	5723	2074	125934	3350	139588	154308	-1301
1:30	49.98	149746	6224	10636	96	5369	2076	125570	3362	139014	153333	-1317
1:45	49.97	149560	6212	10484	89	5335	2082	125802	3349	138987	153353	-1326
2:00	50.02	147982	6222	10467	89	5010	2072	124452	3409	137426	151721	-1336
2:15	49.97	147455	6217	10253	93	4953	2075	124179	3491	137109	151261	-1329
2:30	49.97	147654	6231	10439	103	5197	2074	123954	3446	137112	151444	-1356
2:45	49.97	146889	6239	10157	113	5158	2082	123401	3383	136619	150533	-1163
3:00	50.02	147210	6233	10624	107	5157	2075	123368	3404	136479	150968	-1155
3:15	49.97	147233	6234	10800	98	5216	2072	123207	3383	136335	151010	-1128
3:30	49.97	147448	6209	10878	96	5368	2077	122973	3390	136474	150991	-1170
3:45	50.03	147871	6237	10959	86	5521	2072	123332	3413	136826	151620	-1175
4:00	50.03	148225	6231	11043	86	5590	2082	123524	3391	137096	151947	-1188
4:15	49.97	150744	6239	11154	117	5553	2082	125914	3373	139473	154432	-1187
4:30	50.07	152278	6242	11124	116	5590	2081	127521	3449	141038	156123	-1200
4:45	50.02	154331	6236	11092	120	5809	2088	129614	3371	143119	158330	-1167
5:00	50.07	156774	6237	11015	123	5959	2094	132329	3391	145636	161148	-1214
5:15	50.02	160951	6230	10857	122	6442	2104	136005	3381	149972	165141	-1204
5:30	50.07	165260	6239	10881	117	7065	2118	139657	3378	154262	169455	-1254
5:45	50.02	170209	6238	10811	117	7805	2150	143714	3422	159281	174257	-1226
6:00	50.07	173121	6240	10632	145	8124	2209	146289	3436	162344	177075	-1208
6:15	50.02	178966	6230	10341	350	9165	2375	150969	3302	168275	182732	-1219
6:30	50.07	186743	6219	9971	338	11733	2656	156099	3367	176434	190383	-1161
6:45	50.02	193553	6240	9451	344	15335	2977	159518	3348	183758	197213	-1292
7:00	49.97	199280	6238	9216	531	18430	3419	161884	3346	189533	203064	-1270
7:15	49.87	203803	6238	8822	1156	21273	3350	162732	3384	193825	206955	-1108
7:30	49.92	206744	6244	8542	2166	22675	3376	163432	3433	196036	209868	-1030
7:45	49.87	209754	6240	8330	3964	23051	3509	164079	3486	197460	212659	-1023
8:00	50.07	211351	6238	8256	6691	23035	3683	162885	3482	196404	214270	-1007
8:15	49.97	214850	6244	7833	10414	22969	3779	162772	3401	196603	217412	-1023
8:30	50.07	218143	6237	7412	14652	19720	3706	162921	3452	196079	218100	-992
8:45	50.02	221536	6230	7064	19438	19981	3861	163738	3540	195034	223852	-1022
9:00	50.07	222352	6240	6883	24112	17920	3841	162160	3563	191357	224719	-1092
9:15	49.92	226878	6228	6777	28312	16981	3889	163596	3633	191789	229416	-1095
9:30	50.02	228821	6204	6688	32305	15613	4072	162929	3608	189828	231419	-1166
9:45	50.02	229782	6215	6296	36106	14487	4260	161734	3601	187380	232699	-1273
10:00	50.02	229839	6209	6006	39576	12563	3509	161032	3638	184257	232533	-1247
10:15	49.97	230537	6190	5535	42208	10348	2808	162422	3611	182794	233122	-1358
10:30	49.97	230504	6194	5155	44882	9440	2806	161264	3604	180467	233345	-1394
10:45	49.92	229993	6179	4824	47154	8811	2801	159516	3589	178015	232874	-1412
11:00	50.02	229781	6198	4506	49046	8715	2801	157370	3648	176229	232284	-1405
11:15	50.07	228900	6229	4137	51080	8360	2793	155093	3624	173683	231316	-1453
11:30	50.07	227392	6203	3976	52115	8097	2792	152583	3630	171301	229396	-1419
11:45	50.02	226567	6213	3816	53105	7637	2773	151581	3617	169646	228742	-1620
12:00	50.02	225428	6203	3566	53737	7414	2494	151027	3659	168125	228100	-1706
12:15	49.97	223440	6211	3439	53146	7203	2363	150146	3624	166855	226132	-1673
12:30	49.97	221905	6219	3357	52945	7318	2291	149199	3592	165603	224921	-1723
12:45	49.92	220711	6218	3210	52966	7548	2273	148088	3544	164535	223847	-1704
13:00	50.02	217574	6197	3095	52215	7471	2274	145975	3551	162264	220778	-1788
13:15	49.97	213826	6212	3038	51647	7426	2279	142817	3590	159141	217009	-1754
13:30	50.02	211803	6198	2990	50604	7253	2280	142240	3546	158209	215111	-1722
13:45	50.07	211125	6205	2898	49289	7211	2284	142505	3612	158938	214004	-1606
14:00	50.07	209436	6194	2875	47258	6932	2290	143306	3595	159303	212450	-1590
14:15	50.07	209047	6194	2753	45732	7333	2285	144298	3542	160562	212137	-1496
14:30	50.02	209544	6178	2750	43345	7349	2277	147141	3554	163449	212594	-1433
14:45	49.92	209660	6200	2685	40997	7318	2277	149597	3540	165978	212614	-1431
15:00	49.97	209724	6194	2729	38194	7683	2293	152340	3550	168801	212983	-1450
15:15	49.97	208844	6209	2760	35642	7676	2278	153975	3559	170442	212099	-1308
15:30	50.02	208333	6202	2818	32993	8167	2332	155615	3579	172522	211706	-1235
15:45	49.97	207000	6192	2830	30182	8651	2374	156515	3574	173988	210318	-1314
16:00	49.97	205095	6198	2759	26745	8769	2401	157944	3571	175591	208387	-1278
16:15	50.02	203112	6192	2859	22912	9911	2499	158575	3546	177341	206494	-1236
16:30	49.92	202809	6202	2845	18787	11328	2420	161201	3449	181177	206232	-1206
16:45	49.87	202745	6186	2992	14547	13479	2729	162603	3438	185206	205974	-1161
17:00	49.87	201039	6194	3305	10377	15576	2939	162752	3386	187357	204529	-1194
17:15	49.97	199743	6187	3566	6545	18033	3075	162263	3470	189632	203139	-984
17:30	49.92	200350	6174	3826	3994	20726	2922	163070	3342	192530	204054	-1081
17:45	49.87	200431	6191	4005	1970	21951	2961	163533	3391	194456	204002	-1076
18:00	49.92	200455	6185	4147	858	22057	2978	164416	3353	195450	203994	-1047
18:15	49.72	202124	6193	4186	451	23229	3028	164950	3397	197487	205434	-1031
18:30	49.92	202852	6175	4260	400	23419	3222	165667	3380	198192	206523	-1022
18:45	49.92	202841	6180	4541	382	23284	3091	165486	3422	197918	206386	-996
19:00	50.02	200994	6195	4957	240	21560	3309	165239	3392	195797	204892	-1001
19:15	49.92	200073	6167	5362	224	20259	3128	165305	3364	194487	203809	-966
19:30	50.02	197449	6190	5701	203	18301	2730	164762	3347	191545	201234	-988
19:45	50.02	195298	6185	5879	291	16051	2714	164618	3354	189128	199092	-991
20:00	50.07	193200	6185	6115	294	14737	2714	163588	3370	186791	197003	-1012
20:15	50.02	191091	6193	6389	193	13187	2723	162577	3363	184509	194625	-1035
20:30	50.07	189273	6190	7000	196	12076	2636	161876	3290	182077	193264	-1054
20:45	50.02	187010	6203	7052	189	10609	2566	160980	3345	179769	190944	-1062
21:00	50.07	184347	6210	7330	155	10030	2706	158658	3332	176862	188421	-1049
21:15	50.02	182183	6217	7553	156	9159	2394	157571	3256	174474	186306	-1397
21:30	50.07	179340	6216	7885	154	8612	2354	155081	3307	171301	183609	-1362
21:45	50.04	176026	6217	8110	157	8167	2355	152117	3321	167759	180444	-1517
22:00	50.04	172497	6218	8270	48	7930	2353	149044	3274	164179	177137	-1577
22:15	49.93	171403	6203	8151	50	8094	2463	147798	3315	163202	176074	-1599
22:30	49.98	169617	6194	81								