



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 16.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 15.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 15-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 15.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 16-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71522	55356	41542	27663	3486	199569
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1587	1352	971	607	68	4586
Hydro Gen (MU)	334	101	166	100	47	747
Wind Gen (MU)	4	58	271	-	-	333
Solar Gen (MU)*	170.07	105.48	115.25	2.70	1.02	395
Energy Shortage (MU)	0.14	0.00	0.00	0.00	0.00	0.14
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	73076	60588	45417	28965	3508	201376
Time Of Maximum Demand Met	22:24	06:25	07:13	00:02	19:52	00:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.046	0.29	0.30	7.68	8.27	77.17	14.56

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12196	0	258.1	160.9	-0.6	383	0.00
	Harvana	9877	0	204.7	164.8	-1.2	180	0.00
	Rajasthan	15207	0	347.9	168.6	-1.2	412	0.00
	Delhi	5337	0	106.0	95.2	-1.3	273	0.00
	UP	26529	0	542.6	239.4	-0.6	567	0.00
	Uttarakhand	1932	0	39.0	24.7	0.7	158	0.14
	HP	1498	0	30.6	-4.2	1.5	785	0.00
	J&K(UT) & Ladakh(UT)	2377	0	48.1	24.3	-0.8	107	0.00
	Chandigarh	279	0	5.5	5.5	0.0	49	0.00
	Railways NR ISTS	208	0	4.4	3.8	0.5	39	0.00
WR	Chhattisgarh	5834	0	128.8	76.4	-0.9	301	0.00
	Gujarat	19010	0	420.6	224.3	-11.1	622	0.00
	MP	11950	0	260.4	131.6	-0.8	730	0.00
	Maharashtra	22455	0	468.5	161.8	-8.7	741	0.00
	Goa	491	0	12.6	10.5	1.8	59	0.00
	DNHDDPDCL	1296	0	24.4	24.2	0.2	77	0.00
	AMNSIL	814	0	18.4	11.6	0.5	254	0.00
	BALCO	530	0	12.7	12.7	0.0	7	0.00
	RIL JAMNAGAR	250	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	8784	0	192.5	12.3	-4.0	648	0.00
SR	Telangana	10545	0	209.4	60.1	-0.1	420	0.00
	Karnataka	9410	0	173.3	6.5	-3.7	763	0.00
	Kerala	3723	0	74.5	37.4	-0.9	389	0.00
	Tamil Nadu	14032	0	313.0	88.0	-2.4	765	0.00
	Puducherry	400	0	8.7	8.3	-0.2	26	0.00
	Bihar	7442	0	156.5	147.6	-1.2	339	0.00
ER	DVC	3131	0	67.7	-30.9	0.2	396	0.00
	Jharkhand	2060	0	44.0	34.3	1.5	236	0.00
	Odisha	6631	0	129.9	50.1	-0.7	490	0.00
	West Bengal	10227	0	207.8	90.2	-2.6	391	0.00
	Sikkim	56	0	0.8	1.0	-0.2	3	0.00
	Railways ER ISTS	20	0	0.2	0.1	0.0	8	0.00
NER	Arunachal Pradesh	198	0	3.8	3.7	-0.4	10	0.00
	Assam	2322	0	44.5	37.6	0.2	96	0.00
	Manipur	213	0	3.1	3.3	-0.1	12	0.00
	Meghalaya	332	0	5.9	0.7	-0.2	23	0.00
	Mizoram	132	0	1.8	0.9	-0.4	4	0.00
	Nagaland	163	0	3.1	2.7	-0.1	15	0.00
	Tripura	311	0	5.9	4.4	-0.1	13	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	50.2	17.7	-23.8	-25.0
Day Peak (MW)	2465.2	894.2	-1013.7	-1383.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	378.2	-174.1	-124.5	-73.6	-6.0	0.0
Actual(MU)	380.6	-161.4	-141.9	-78.0	-7.1	-7.8
O/D/UD(MU)	2.4	12.7	-17.3	-4.4	-1.2	-7.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	9103	16243	11368	3670	452	40836	55
State Sector	8149	12525	10000	3162	199	34035	45
Total	17252	28768	21368	6832	651	74870	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	701	1290	505	642	13	3152	64
Lignite	25	13	50	0	0	89	2
Hydro	334	101	166	100	47	747	15
Nuclear	35	49	47	0	0	131	3
Gas, Naptha & Diesel	13	14	2	0	20	49	1
RES (Wind, Solar, Biomass & Others)	182	164	410	5	1	762	15
Total	1289	1632	1181	747	81	4930	100

Share of RES in total generation (%)	14.11	10.05	34.76	0.66	1.29	15.46
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.70	19.25	52.76	14.05	59.04	33.27

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.050
Based on State Max Demands	1.083

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	193913	7:00	0
Non-Solar hr	201376	0:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 16-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	401	0.0	9.7	-9.7
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	360	1199	0.0	11.1	-11.1
4	765 kV	SASARAM-FATEHPUR	1	172	603	0.0	5.7	-5.7
5	765 kV	GAYA-BALIA	1	0	962	0.0	12.8	-12.8
6	400 kV	PUSAULI-VARANASI	1	0	103	0.0	1.2	-1.2
7	400 kV	PUSAULI-ALLAHABAD	1	4	83	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	1066	0.0	16.5	-16.5
9	400 kV	PATNA-BALIA	2	0	927	0.0	12.5	-12.5
10	400 kV	NAUBATPUR-BALIA	2	0	413	0.0	3.5	-3.5
11	400 kV	BIHARSHARIFF-BALIA	2	197	417	0.0	2.9	-2.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	592	0.0	9.0	-9.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	93	476	0.0	5.7	-5.7
14	220 kV	SAHUPURI-KARAMNESA	1	0	69	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.7	-94.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	881	914	0.0	1.6	-1.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2003	0	31.7	0.0	31.7
3	765 kV	JHARSUGUDA-DURG	2	187	532	0.0	6.3	-6.3
4	400 kV	JHARSUGUDA-RAIGARH	4	305	289	1.3	0.0	1.3
5	400 kV	RANCHI-SIPAT	2	438	121	4.9	0.0	4.9
6	400 kV	JEYPORE-JAGDALPUR	2	0	650	0.0	9.1	-9.1
7	220 kV	BUDHIPADAR-RAIGARH	1	43	119	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	83	138	0.0	0.9	-0.9
						ER-WR	37.9	18.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	677	0	16.2	0.0	16.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1197	0.0	25.5	-25.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2134	0.0	24.1	-24.1
4	400 kV	TALCHER-I/C	2	559	415	2.9	0.0	2.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	16.2	-33.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	339	193	2.7	0.4	2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	261	134	0.0	1.2	-1.2
3	220 kV	ALIPURDUAR-SALAKATI	2	38	74	0.0	0.6	-0.6
						ER-NER	2.7	0.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	303	0.0	6.3	-6.3
						NER-NR	0.0	-6.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4048	0.0	70.5	-70.5
2	HVDC	VINDHYACHAL-B/B	-	0	403	0.0	5.2	-5.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	26.7	-26.7
4	765 kV	GWALIOR-AGRA	2	0	3177	0.0	42.1	-42.1
5	765 kV	GWALIOR-PHAGI	2	342	2361	0.2	34.1	-33.8
6	765 kV	JABALPUR-ORAI	2	0	1520	0.0	48.0	-48.0
7	765 kV	GWALIOR-ORAI	1	1206	0	17.6	0.0	17.6
8	765 kV	SATNA-ORAI	1	0	1216	0.0	19.6	-19.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1800	295	17.5	0.6	17.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	3427	0.0	55.7	-55.7
11	400 kV	ZERDA-KANKROLI	1	371	45	3.1	0.1	3.0
12	400 kV	ZERDA-BHINMAL	1	256	32	2.1	0.1	2.1
13	400 kV	VINDHYACHAL-RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	405	771	0.8	8.3	-7.5
15	400 kV	NEEMUCH-Chittorgarh	2	234	922	0.2	11.9	-11.7
16	220 kV	BHANPURA-RANPUR	1	0	162	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.7	-2.7
18	220 kV	MEHGAON-AURAIYA	1	55	29	0.3	0.1	0.2
19	220 kV	MALANPUR-AURAIYA	1	30	46	0.1	0.4	-0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	42.1	-286.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1000	0	18.3	0.0	18.3
2	HVDC	RAIGARH-PUGAULUR	2	2408	0	35.2	0.0	35.2
3	765 kV	SOLAPUR-RAICHUR	2	2847	0	43.8	0.0	43.8
4	765 kV	WARDHAN-NIZAMABAD	2	1337	1263	8.2	4.1	4.1
5	765 kV	WARORA-WARANGAL(NEW)	2	1297	1291	8.2	4.2	3.9
6	400 kV	KOLHAPUR-KUDGI	2	1887	0	37.5	0.0	37.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.1	0.0	2.1
						WR-SR	153.3	144.9

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU JEP 4*180MW)	1468	686	1177	28.24	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	908	759	860	20.64	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-134	109	49	1.18	
	NER	132kV GELEPHU-SALAKATI	24	-15	7	0.17	
	NER	132kV MOTANGA-RANGIA	15	-10	-3	-0.06	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-58	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	44	0	2	0.06	
	ER	NEPAL IMPORT (FROM BIHAR)	150	111	128	3.07	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	702	440	606	14.54	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-954	-948	-949	-22.78	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1383	-811	-1043	-25.03	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-46	0	-41	-0.98	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 16-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.12
Bangladesh	23.48	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.61
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.60	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.73

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	50.52	0.00	1.49	0.00	0.00	0.11	0.00	0.00	52.12
Nepal	8.40	3.81	5.36	0.00	0.00	0.47	0.00	0.00	18.04
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	58.92	3.81	6.85	0.00	0.00	0.58	0.00	0.00	70.16

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	50.52	0.00	1.49	0.00	0.00	0.11	0.00	0.00	52.12
Nepal	8.28	3.81	5.36	0.00	0.00	0.47	0.00	0.00	17.92
Bangladesh	-23.48	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-23.61
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	35.32	3.68	6.85	0.00	0.00	0.58	0.00	0.00	46.43

