



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	48450	57467	42738	19998	2538	171191
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1076	1347	1023	419	49	3913
Hydro Gen (MU)	128	31	99	32	16	305
Wind Gen (MU)	3	104	74	-	-	181
Solar Gen (MU)*	184.50	150.89	125.30	3.56	1.16	465
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	54838	63588	50052	20711	2778	187958
Time Of Maximum Demand Met	10:16	09:16	09:23	17:59	17:23	09:56

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.039	0.00	0.00	6.16	6.16	79.44	14.41

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6818	0	131.6	40.6	-1.8	126	0.00
	Haryana	6488	0	133.1	109.9	-1.6	283	0.00
	Rajasthan	15604	0	295.7	104.8	0.4	1445	0.00
	Delhi	3886	0	68.9	63.4	-0.6	249	0.00
	UP	16409	0	310.4	89.7	-1.7	710	0.00
	Uttarakhand	1978	0	36.1	26.6	-0.1	110	0.00
	HP	1911	0	34.3	22.4	-1.1	288	0.00
	J&K(UT) & Ladakh(UT)	2941	0	58.8	52.7	0.2	210	0.00
	Chandigarh	183	0	3.3	3.3	0.0	12	0.00
	Railways_NR ISTS	187	0	4.0	4.0	0.0	19	0.00
WR	Chhattisgarh	4450	0	84.2	31.4	-2.3	313	0.00
	Gujarat	19519	0	395.3	150.4	0.0	1105	0.00
	MP	16328	0	288.6	188.5	0.0	570	0.00
	Maharashtra	23762	0	499.8	162.7	4.0	753	0.00
	Goa	616	0	12.4	10.6	1.4	52	0.00
	DNHDDPDCL	1237	0	28.2	28.1	0.1	44	0.00
	AMNSIL	881	0	19.2	11.6	0.5	337	0.00
	BALCO	538	0	12.8	12.9	-0.1	10	0.00
	RIL JAMNAGAR	257	0	6.1	6.2	-0.1	0	0.00
	Andhra Pradesh	9565	0	193.9	57.7	-0.1	494	0.00
SR	Telangana	8975	0	168.4	84.6	0.6	597	0.00
	Karnataka	13956	0	255.5	89.7	-0.4	598	0.00
	Kerala	4046	0	77.3	59.9	-0.4	302	0.00
	Tamil Nadu	14451	0	320.2	169.6	0.1	749	0.00
	Puducherry	353	0	8.1	7.7	-0.3	32	0.00
	Bihar	4793	0	88.5	71.8	-0.4	225	0.00
ER	DVC	2975	0	62.3	-15.3	0.9	399	0.00
	Jharkhand	1949	0	36.0	27.8	-0.2	377	0.00
	Odisha	4914	0	92.7	22.4	-2.9	286	0.00
	West Bengal	6729	0	138.0	30.1	-2.9	155	0.00
	Sikkim	72	0	1.1	1.3	-0.2	1	0.00
	Railways_ER ISTS	24	0	0.2	0.2	0.1	4	0.00
NER	Arunachal Pradesh	173	0	2.8	2.6	0.0	25	0.00
	Assam	1608	0	28.8	21.7	0.2	143	0.00
	Manipur	231	0	3.2	3.1	0.1	76	0.00
	Meghalaya	325	0	5.8	5.1	-0.1	71	0.00
	Mizoram	117	0	1.6	0.8	-0.3	11	0.00
	Nagaland	141	0	2.5	2.3	-0.1	14	0.00
	Tripura	233	0	4.0	5.4	0.2	34	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.2	17.0	-23.0	-14.2
Day Peak (MW)	183.8	923.8	-985.1	-761.1

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	162.8	-160.1	131.6	-141.4	7.1	0.0
Actual(MU)	159.1	-149.9	132.6	-156.9	6.1	-8.9
O/D/U/D(MU)	-3.8	10.3	1.0	-15.4	-1.0	-8.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7863	14611	7248	4850	583	35155	46
State Sector	12739	13837	10468	3557	306	40907	54
Total	20602	28448	17716	8407	889	76062	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	590	1214	553	605	11	2973	70
Lignite	28	17	39	0	0	84	2
Hydro	128	31	99	32	16	305	7
Nuclear	32	53	41	0	0	126	3
Gas, Naptha & Diesel	7	15	4	0	19	45	1
RES (Wind, Solar, Biomass & Others)	209	257	226	6	1	699	17
Total	993	1586	962	643	48	4232	100

Share of RES in total generation (%)	21.05	16.21	23.52	0.88	2.44	16.52
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.08	21.51	38.06	5.84	36.54	26.71

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.062

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	187958	9:56	0
Non-Solar hr	180291	17:59	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 17-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	176	1249	0.0	15.4	-15.4
4	765 kV	SASARAM-FATEHPUR	1	0	561	0.0	7.5	-7.5
5	765 kV	GAYA-BALIA	1	18	605	0.0	7.0	-7.0
6	400 kV	PUSAULI-VARANASI	1	7	76	0.0	1.1	-1.1
7	400 kV	PUSAULI-ALLAHABAD	1	0	102	0.0	1.3	-1.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	801	0.0	10.9	-10.9
9	400 kV	PATNA-BALIA	2	0	814	0.0	9.8	-9.8
10	400 kV	NAUBATPUR-BALIA	2	128	143	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	160	258	0.0	1.3	-1.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	526	0.0	6.6	-6.6
13	400 kV	BIHARSARIFF-SAHUPURI	2	136	436	0.0	4.3	-4.3
14	220 kV	SAHUPURI-KARMANASA	1	21	7	0.0	1.3	-1.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.3	72.0	-71.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	78	965	0.0	12.0	-12.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	430	658	0.0	4.2	-4.2
3	765 kV	JHARSUGUDA-DURG	2	0	1262	0.0	21.3	-21.3
4	400 kV	JHARSUGUDA-RAIGARH	4	148	394	0.0	3.7	-3.7
5	400 kV	RANCHI-SIPAT	2	175	279	0.0	1.8	-1.8
6	400 kV	JEYPORE-JACDALPUR	2	435	322	0.0	0.0	2.1
7	220 kV	BUDHIPADAR-RAIGARH	1	21	115	0.0	1.4	-1.4
8	220 kV	BUDHIPADAR-KORBA	2	128	86	0.2	0.0	0.2
ER-WR						2.3	44.3	-42.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	652	0.0	7.1	-7.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1617	0.0	41.8	-41.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2674	0.0	46.3	-46.3
4	400 kV	TALCHER/UC	2	572	298	0.0	2.6	-2.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	22	0	0.4	0.0	0.4
ER-SR						0.4	95.2	-94.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	283	24	2.8	0.0	2.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	476	2	4.5	0.0	4.5
3	220 kV	ALIPURDUAR-SALAKATI	2	76	8	0.7	0.0	0.7
ER-NER						7.9	0.0	7.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	661	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2007	0.0	46.9	-46.9
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	791	0.0	18.6	-18.6
4	765 kV	GWALIOR-AGRA	2	332	1591	0.2	17.1	-16.9
5	765 kV	GWALIOR-PHAGI	2	651	2112	2.0	24.0	-22.1
6	765 kV	JABALPUR-ORAI	2	218	686	0.0	17.2	-17.2
7	765 kV	GWALIOR-ORAI	1	1076	0	16.0	0.0	16.0
8	765 kV	SATNA-ORAI	1	0	819	0.0	14.6	-14.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1451	697	16.3	1.2	15.1
10	765 kV	VINDHYACHAL-VARANASI	2	59	1261	0.0	16.5	-16.5
11	400 kV	ZERDA-KANKROLI	1	250	39	3.5	0.0	3.5
12	400 kV	ZERDA -BHINMAL	1	173	27	2.4	0.0	2.4
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	706	303	4.0	1.1	2.9
15	400 kV	NEEMUCH-Chittorgarh	2	738	315	4.1	2.0	2.1
16	220 kV	BHANPURA-RANPUR	1	0	117	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	95	0	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	69	6	0.3	0.0	0.3
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						54.3	162.6	-108.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	991	0.0	23.0	-23.0
2	HVDC	RAIGARH-PUGALUR	2	0	2003	0.0	42.6	-42.6
3	765 kV	SOLAPUR-RAICHUR	2	942	857	3.2	3.9	-0.6
4	765 kV	WARDHA-NIZAMABAD	2	54	1535	0.0	18.8	-18.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1842	0.0	25.4	-25.4
6	400 kV	KOLHAPUR-KUDGI	2	1545	0	25.7	0.0	25.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	91	1.8	0.0	1.8
WR-SR						30.7	113.6	-82.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	119	59	119	4.38
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	270	186	222	5.32
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-179	-122	-145	-3.49
	NER	132kV GELEPHU-SALAKATI	-74	-60	-65	-1.56
	NER	132kV MOTANGA-RANGIA	-28	-5	-21	-0.51
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	64	0	57	1.37
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	820	602	651	15.63
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-903	-856	-874	-20.99
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-761	-410	-592	-14.22
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-106	0	-85	-2.04

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 17-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.37	0.00	0.00	0.00	0.00	0.00	0.00	0.37
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	21.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.89
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.89	0.37	0.00	0.00	0.00	0.00	0.00	0.00	22.26

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	11.98	0.00	0.00	0.00	4.46	0.00	0.00	16.44
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	11.98	0.00	0.00	0.00	4.46	0.00	0.00	16.44

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	-0.37	0.00	0.00	0.00	0.00	0.00	0.00	-0.37	
Nepal	0.00	0.00	11.98	0.00	0.00	0.00	4.46	0.00	0.00	16.44
Bangladesh	-21.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.89
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.89	-0.37	11.98	0.00	0.00	0.00	4.46	0.00	0.00	-5.82

