



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58975	64963	50702	24167	2866	201673
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1210	1539	1228	488	51	4516
Hydro Gen (MU)	104	37	82	23	14	261
Wind Gen (MU)	28	120	90	-	-	238
Solar Gen (MU)*	177.96	158.40	150.60	3.32	1.06	491
Energy Shortage (MU)	0.00	0.00	0.00	0.04	0.00	0.04
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64146	81819	62675	24946	3037	232705
Time Of Maximum Demand Met	10:55	09:44	09:23	18:26	17:47	09:40

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.02	3.45	3.47	72.05	24.48

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8462	0	157.8	75.6	-2.6	556	0.00
	Haryana	8118	0	153.3	110.3	-1.0	278	0.00
	Rajasthan	17838	0	315.8	105.2	-4.9	1186	0.00
	Delhi	5088	0	89.0	81.1	-0.6	417	0.00
	UP	19654	0	343.1	74.6	-1.1	686	0.00
	Uttarakhand	2524	0	46.0	38.4	0.2	351	0.00
	HP	2091	0	38.0	31.6	-0.8	140	0.00
	J&K(UT) & Ladakh(UT)	3092	0	57.9	54.8	-2.0	160	0.00
	Chandigarh	282	0	4.9	4.9	0.0	47	0.00
	Railways NR ISTS	204	0	4.0	3.8	0.2	37	0.00
WR	Chhattisgarh	5677	0	114.6	62.6	-1.4	421	0.00
	Gujarat	24611	0	434.8	194.6	0.2	1721	0.00
	MP	18452	0	315.9	203.6	0.0	782	0.00
	Maharashtra	29911	0	594.3	168.9	-12.5	1213	0.00
	Goa	751	0	14.7	12.1	2.5	72	0.00
	DNHDDPDCL	1343	0	28.4	28.3	0.1	54	0.00
	AMNSIL	882	0	19.5	10.6	0.8	329	0.00
	BALCO	601	0	14.2	14.5	-0.3	0	0.00
	RIL JAMNAGAR	231	0	2.3	2.3	0.0	0	0.00
	Andhra Pradesh	12158	0	227.4	67.8	-0.2	494	0.00
SR	Telangana	15528	0	273.6	128.6	-0.3	552	0.00
	Karnataka	17134	0	309.4	106.5	-0.2	790	0.00
	Kerala	4721	0	89.1	70.5	2.1	326	0.00
	Tamil Nadu	17091	0	320.3	178.2	-4.6	965	0.00
	Puducherry	413	0	8.4	7.9	-0.1	59	0.00
	Bihar	5885	0	103.6	83.6	-0.6	310	0.04
	DVC	3147	0	68.5	-12.0	0.6	477	0.00
ER	Jharkhand	2079	0	38.4	28.0	-1.3	185	0.00
	Odisha	5550	0	108.9	27.7	-2.4	645	0.00
	West Bengal	8224	0	166.3	58.4	-2.5	171	0.00
	Sikkim	117	0	1.9	1.9	0.0	11	0.00
	Railways ER ISTS	21	0	0.2	0.2	0.0	2	0.00
	Arunachal Pradesh	190	0	3.3	3.1	0.1	25	0.00
	Assam	1687	0	28.8	24.1	0.6	120	0.00
NER	Manipur	264	0	3.9	4.0	-0.2	39	0.00
	Meghalaya	381	0	6.3	5.7	-0.1	76	0.00
	Mizoram	158	0	2.3	2.2	-0.2	15	0.00
	Nagaland	172	0	2.6	2.6	-0.1	15	0.00
	Tripura	237	0	4.1	6.1	0.4	67	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-18.1	-9.6	-24.7	-16.7
Day Peak (MW)	-1044.2	-649.3	-1061.6	-1158.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	184.1	-211.5	136.8	-119.9	10.5	0.0
Actual(MU)	191.4	-205.8	118.6	-131.9	9.3	-18.6
O/D/U/D(MU)	7.2	5.7	-18.2	-12.0	-1.2	-18.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5566	12255	3358	2994	469	24641	43
State Sector	9844	11388	7085	4183	205	32704	57
Total	15410	23643	10443	7176	674	57345	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	696	1455	704	678	13	3545	72
Lignite	28	23	51	0	0	102	2
Hydro	104	37	82	23	14	261	5
Nuclear	52	53	71	0	0	176	4
Gas, Naptha & Diesel	10	18	9	0	20	57	1
RES (Wind, Solar, Biomass & Others)	230	282	279	7	1	800	16
Total	1120	1868	1196	708	48	4941	100

Share of RES in total generation (%)	20.57	15.09	23.32	1.03	2.21	16.18
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.54	19.90	36.09	4.34	32.07	25.03

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.052

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	232705	9:40	0
Non-Solar hr	208535	18:45	0

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 28-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	358	1097	0.0	11.2	-11.2
4	765 kV	SASARAM-FATEHPUR	1	131	522	0.0	8.0	-8.0
5	765 kV	GAYA-BALIA	1	0	960	0.0	12.3	-12.3
6	400 kV	PUSAULI-VARANASI	1	0	103	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	7	77	0.0	1.2	-1.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	485	538	0.0	8.0	-8.0
9	400 kV	PATNA-BALIA	2	32	1172	0.0	18.8	-18.8
10	400 kV	NAUBATPUR-BALIA	2	160	249	0.0	4.8	-4.8
11	400 kV	BIHARSHARIEFF-BALIA	2	435	343	0.6	0.0	0.6
12	400 kV	MOTIHARI-GORAKHPUR	2	180	513	0.0	4.9	-4.9
13	400 kV	BIHARSARIEFF-SAHUPURI	2	175	386	0.0	4.4	-4.4
14	220 kV	SAHUPURI-KARAMNASA	1	15	32	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	79.1	-78.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	227	1295	0.0	13.7	-13.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1621	648	15.7	0.0	15.7
3	765 kV	JHARSUGUDA-BURG	2	0	1372	0.0	21.1	-21.1
4	400 kV	JHARSUGUDA-RAIGARH	4	202	287	0.0	0.7	-0.7
5	400 kV	RANCHI-SIPAT	2	274	305	0.6	0.0	0.6
6	400 kV	JEYPORE-JAGDALPUR	2	386	134	3.2	0.0	3.2
7	220 kV	BUDHIPADAR-RAIGARH	1	2	115	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	34	156	0.0	1.3	-1.3
ER-WR						19.5	38.0	-18.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	570	0.0	12.5	-12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1613	0.0	39.2	-39.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1657	0.0	24.7	-24.7
4	400 kV	TALCHER-I/C	2	336	701	0.0	4.0	-4.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	76.4	-76.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	184	226	0.7	1.6	-1.0
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	356	159	2.3	0.0	2.3
3	220 kV	ALIPURDUAR-SALAKATI	2	57	49	0.1	0.0	0.1
ER-NER						3.1	1.6	1.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	570	0	13.0	0.0	13.0
NER-NR						13.0	0.0	13.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	3	2952	0.0	42.8	-42.8
2	HVDC	VINDHYACHAL B/B	-	0	517	0.0	7.0	-7.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1923	0.0	25.3	-25.3
4	765 kV	GWALIOR-AGRA	2	257	2311	0.1	21.8	-21.7
5	765 kV	GWALIOR-PHAGI	2	756	2148	2.2	21.8	-19.7
6	765 kV	JABALPUR-ORAI	2	96	1183	0.0	22.2	-22.2
7	765 kV	GWALIOR-ORAI	1	887	0	12.5	0.0	12.5
8	765 kV	SATNA-ORAI	1	0	1048	0.0	16.0	-16.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1729	556	14.3	0.7	13.6
10	765 kV	VINDHYACHAL-VARANASI	2	73	2286	0.0	33.5	-33.5
11	400 kV	ZERDA-KANKROLI	1	277	0	3.9	0.0	3.9
12	400 kV	ZERDA -BHINMAL	1	191	0	2.7	0.0	2.7
13	400 kV	VINDHYACHAL -RIHAND	1	495	0	9.2	0.0	9.2
14	400 kV	RAPP-SHUJALPUR	2	862	326	7.8	1.0	6.8
15	400 kV	NEEMUCH-Chittorgarh	2	787	537	5.4	2.3	3.2
16	220 kV	BHANPURA-RANPUR	1	0	111	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	116	48	1.0	0.1	0.9
19	220 kV	MALANPUR-AURAIYA	1	84	53	0.3	0.1	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						59.3	197.8	-138.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	983	0.0	15.2	-15.2
2	HVDC	RAIGARH-PUGALUR	2	0	4013	0.0	59.4	-59.4
3	765 kV	SOLAPUR-RAICHUR	2	2333	870	14.9	3.1	11.8
4	765 kV	WARDHA-NIZAMABAD	2	1009	2409	1.5	25.5	-24.0
5	765 kV	WARORA-WARANGAL(NEW)	2	760	2587	0.8	30.2	-29.4
6	400 kV	KOLHAPUR-KUDGI	2	2013	0	28.3	0.0	28.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	123	2.3	0.0	2.3
WR-SR						47.9	133.4	-85.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-283	109	-206	-4.95		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-362	154	-192	-4.61		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-313	-204	-266	-6.39		
	NER	132kV GELEPHU-SALAKATI	-73	-45	-59	-1.42		
	NER	132kV MOTANGA-RANGIA	-32	-7	-29	-0.70		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	-22	-0.52		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-41	-0.98		
	ER	NEPAL IMPORT (FROM BIHAR)	-143	-92	-121	-2.89		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-396	-116	-218	-5.22		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-916	-909	-913	-21.91		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1158	-209	-698	-16.74		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-151	0	-118	-2.82		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	18.51	0.00	0.00	0.74	0.00	0.00	19.25
Nepal	3.07	1.75	1.38	0.00	0.00	2.38	0.00	0.00	8.58
Bangladesh	22.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.01	1.75	19.89	0.00	0.00	3.12	0.00	0.00	50.77

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.44
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.44

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.44	0.00	-18.51	0.00	0.00	-0.74	0.00	0.00	-18.81
Nepal	-3.07	-1.75	-1.38	0.00	0.00	-2.38	0.00	0.00	-8.58
Bangladesh	-22.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.57	-1.75	-19.89	0.00	0.00	-3.12	0.00	0.00	-50.33

Date of Reporting: 28-Jan-2026												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-C+D)	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.10	147599	6236	12665	0	5288	1986	121026	3751	134934	150952	-2134
0:15	50.10	147393	6249	12846	0	5443	1981	120767	3758	134547	151044	-2221
0:30	49.97	147446	6257	13310	0	5449	1991	120342	3751	134136	151100	-2211
0:45	49.98	146118	6257	13374	0	5342	2012	119332	3802	132744	150119	-2191
1:00	50.02	145467	6252	13370	0	5330	1991	118764	3835	132097	149542	-2187
1:15	49.96	144661	6282	13273	0	5187	1995	117995	3841	131388	148573	-2176
1:30	49.98	143782	6260	13264	0	4987	1991	117538	3809	130518	147849	-2167
1:45	49.98	143783	6275	13029	0	5199	1993	117500	3861	130754	147857	-2147
2:00	50.02	142586	6285	13019	0	5056	2001	116625	3837	129567	146823	-2150
2:15	49.96	142637	6291	12979	0	5112	1987	116495	3792	129658	146656	-2157
2:30	50.01	142739	6279	13104	0	5091	1983	116553	3799	129635	146809	-2147
2:45	50.02	143091	6264	13257	0	5340	1985	116820	3780	129834	147446	-2146
3:00	50.05	143156	6287	13227	0	5440	1991	116700	3737	129929	147382	-2137
3:15	50.00	143534	6300	13053	0	5206	1990	117532	3727	130481	147808	-2157
3:30	49.98	143846	6302	13103	0	5204	1993	117915	3659	130743	148176	-2156
3:45	50.04	144212	6286	13080	0	5170	1987	118371	3659	131132	148553	-2166
4:00	50.06	144891	6321	13035	0	5114	1984	118688	3645	131856	148787	-2135
4:15	50.03	147016	6300	12891	0	5673	1998	120001	3727	134125	150590	-2127
4:30	50.03	148557	6296	12632	0	6287	1986	121520	3640	135925	152361	-2134
4:45	50.06	150477	6295	12435	0	6449	2050	123659	3624	138042	154476	-2191
5:00	50.12	151576	6281	12206	43	6443	2059	124951	3689	139327	155672	-2157
5:15	50.01	155886	6272	12156	83	6430	2118	129503	3684	143647	160246	-2203
5:30	50.05	160212	6253	12164	84	6690	2140	133617	3661	147964	164609	-2270
5:45	50.00	165421	6254	12154	87	7100	2243	138062	3715	153180	169615	-2271
6:00	50.10	169656	6255	11884	78	8609	2277	141360	3754	157694	174217	-2298
6:15	49.89	175986	6249	11616	90	9884	2277	146731	3729	164280	180576	-2282
6:30	50.05	184734	6206	11216	72	12268	2276	153562	3711	173446	189311	-2253
6:45	50.07	192072	6278	11018	108	14855	2273	158067	3775	180946	196374	-1780
7:00	50.06	198684	6356	10703	267	16893	2303	161909	3828	187714	202259	-1239
7:15	50.02	204665	6329	10378	778	19424	2312	164983	3850	193509	208054	-1265
7:30	49.99	209116	6330	10169	1803	20525	2337	167238	3879	197144	212281	-1240
7:45	50.04	211999	6320	9689	3969	21002	2356	167752	3897	198341	214985	-1220
8:00	50.05	214276	6324	9288	7360	20994	2355	167071	3864	197628	217256	-1219
8:15	50.03	218728	6324	8780	12317	21099	2336	166730	3875	197631	221461	-1202
8:30	50.05	221775	6333	8198	17654	20507	2333	165504	3803	195923	224332	-1215
8:45	50.08	224006	6351	7753	24176	19405	2331	162764	3798	192077	226578	-1222
9:00	50.19	225332	6339	7334	30767	15971	2356	161154	3839	187231	227760	-1278
9:15	50.09	229756	6390	7060	38041	14196	2353	160974	3850	184655	232864	-1677
9:30	50.07	231553	6408	6575	43585	12373	2346	159823	3767	181393	234877	-2257
9:45	50.03	232563	6449	6231	48845	11379	2360	156940	3776	177487	235980	-2432
10:00	50.02	231666	6484	6063	54065	10143	2353	152374	3756	171538	235238	-2445
10:15	50.04	232573	6476	5946	57188	9065	2344	150674	3745	169439	235438	-2517
10:30	50.04	230984	6528	5920	60593	8383	2352	147157	3690	164471	234623	-2475
10:45	50.04	231233	6560	5797	64117	7363	2319	144509	3771	161319	234436	-2467
11:00	49.95	230379	6631	5708	66182	6282	2312	142737	3714	158489	233566	-2458
11:15	49.89	228071	6654	5678	66990	6471	2354	139542	3683	155403	231372	-2526
11:30	49.96	226714	6666	5608	68000	6673	2297	137163	3697	153106	230104	-2516
11:45	50.02	225724	6667	5446	68680	6560	2274	135694	3731	151598	229052	-2507
12:00	50.14	223251	6702	5307	69308	6623	2281	132644	3655	148636	226520	-2502
12:15	49.99	220001	6686	5283	68703	6383	2339	130330	3628	146015	223352	-2464
12:30	50.06	218931	6720	5289	69871	6237	2279	125032	3648	143771	219076	-2449
12:45	50.07	216876	6708	5403	70431	6277	2279	125450	3674	141042	220222	-2411
13:00	50.11	213490	6716	5587	69194	6262	2272	123357	3697	138709	217085	-2442
13:15	50.04	209622	6741	5666	68793	6037	2274	120102	3665	135163	213278	-2437
13:30	49.98	208395	6745	5695	69164	5729	2280	118453	3702	133536	211768	-2450
13:45	50.02	208875	6760	5848	67912	6035	2265	118641	3681	135115	211142	-2509
14:00	50.06	209039	6742	5985	66763	6336	2272	119250	3729	136291	211077	-2520
14:15	50.00	208548	6746	6014	64785	6276	2272	121302	3636	137749	211031	-2482
14:30	49.98	210469	6748	6033	63497	6636	2276	123726	3628	140939	212544	-2444
14:45	49.96	210487	6738	6112	61231	7008	2273	125582	3634	143144	212578	-2513
15:00	49.97	211061	6719	6140	59684	7117	2268	127976	3609	145237	213513	-2540
15:15	49.92	208942	6737	6232	56251	7177	2283	128808	3710	146459	211198	-2523
15:30	49.91	209432	6738	6312	52924	7604	2288	132465	3663	150196	211994	-2574
15:45	49.90	208714	6720	6352	48581	7502	2302	136375	3641	153781	211473	-2544
16:00	50.01	209383	6717	6243	44718	8442	2283	140247	3653	158422	212303	-2525
16:15	49.98	206264	6709	6259	40320	8262	2305	142448	3624	159685	209927	-2483
16:30	50.06	206846	6685	6072	34627	9688	2364	146638	3626	166147	209700	-2428
16:45	50.03	206843	6653	6199	29058	10781	2384	150865	3661	171586	209601	-2430
17:00	50.05	206556	6622	6172	22954	12266	2550	156316	3635	177430	210515	-2431
17:15	50.05	203662	6591	6269	17126	13762	2673	157788	3718	180267	207927	-2420
17:30	50.10	204519	6557	6393	11677	16569	2786	160748	3769	186449	208499	-2397
17:45	50.00	206517	6549	6627	6889	18267	2896	164767	3726	193001	209721	-1629
18:00	50.09	207434	6529	6775	3501	19293	3024	168144	3733	197158	210999	-1511
18:15	50.06	206299	6528	6863	1359	19499	2913	169007	3783	198077	209952	-1534
18:30	50.05	208412	6539	7188	788	20288	3016	170286	3761	200436	211866	-1382
18:45	50.03	208535	6532	7616	347	20627	2972	170253	3780	200572	212127	-1446
19:00	50.06	207117	6545	8075	185	20192	2958	168814	3801	198857	210570	-1446
19:15	50.03	204216	6532	8586	317	17623	2772	168147	3792	195313	207769	-1370
19:30	50.05	202075	6530	9098	0	16360	2604	166927	3838	192977	205357	-1482
19:45	50.01	198541	6509	9732	0	14226	2418	165505	3812	188809	202202	-1591
20:00	49.99	194814	6548	10164	0	13735	2359	161737	3855	184650	198398	-1601
20:15	50.03	191353	6555	10680	0	12771	2356	159118	3905	180673	195385	-1560
20:30	50.00	188832	6569	11024	0	11896	2318	157360	3773	177808	192940	-1600
20:45	50.04	186621	6568	11342	0	11889	2360	154935	3805	175279	190899	-1579
21:00	49.97	183553	6586	11551	0	11515	2303	152255	3897	172002	188107	-1707
21:15	49.98	180663	6626	11714	0	10984	2306	149807	3790	168949	185227	-1921
21:30	50.02	177831	6636	11965	0	10727	2376	147219	3839	165866	182762	-1968
21:45	50.04	174899	6634	12283	0	9491	2368	145483	3793	162616	180052	-1976
22:00	50.15	171111	6642	12654	0	8844	2318	142093	3771	158457	176322	-1918
22:15	50.01	169771	6655	12965	0	8336	2382	141005	3834	156806		