



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52071	58354	41970	21812	2599	176806
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1195	1425	1045	461	49	4175
Hydro Gen (MU)	133	34	89	45	19	320
Wind Gen (MU)	5	39	41	-	-	86
Solar Gen (MU)*	147.36	90.58	127.04	2.82	1.11	369
Energy Shortage (MU)	0.00	0.00	0.00	0.11	0.00	0.11
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	55851	65332	48950	22789	2822	191376
Time Of Maximum Demand Met	10:42	10:25	09:26	18:02	17:25	10:21

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.03	6.90	6.93	78.45	14.62

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6597	0	136.2	68.3	-0.7	455	0.00
	Haryana	6715	0	140.0	99.4	-1.9	334	0.00
	Rajasthan	16623	0	327.6	122.1	-1.2	423	0.00
	Delhi	3859	0	78.4	69.6	-0.2	199	0.00
	UP	18470	0	382.8	146.0	-0.3	241	0.00
	Uttarakhand	1938	0	38.6	28.6	-0.1	58	0.00
	HP	1758	0	32.4	21.4	-1.2	10	0.00
	J&K(UT) & Ladakh(UT)	2642	0	51.3	44.8	-1.0	353	0.00
	Chandigarh	189	0	3.5	3.4	0.1	50	0.00
WR	Railways_NR ISTS	186	0	4.2	3.8	0.3	31	0.00
	Chhattisgarh	4329	0	93.7	39.7	-1.4	381	0.00
	Gujarat	19075	0	393.6	211.1	0.3	540	0.00
	MP	15539	0	309.8	193.3	-2.6	896	0.00
	Maharashtra	25377	0	553.5	221.0	2.2	933	0.00
	Goa	646	0	13.5	12.5	0.4	40	0.00
	DNHDDPDCL	1252	0	29.0	29.1	-0.1	40	0.00
	AMNSIL	867	0	19.3	9.1	0.3	293	0.00
	BALCO	532	0	12.7	12.6	0.1	55	0.00
SR	Andhra Pradesh	10903	0	216.6	65.0	-0.7	609	0.00
	Telangana	9431	0	195.9	91.1	-0.6	516	0.00
	Karnataka	12395	0	231.9	103.8	0.7	623	0.00
	Kerala	3981	0	77.8	58.1	0.2	221	0.00
	Tamil Nadu	14193	0	313.9	171.3	-1.2	726	0.00
	Puducherry	395	0	9.1	8.7	-0.2	35	0.00
	Bihar	5197	0	100.4	89.0	0.2	432	0.11
ER	DVC	3151	0	64.1	-37.8	-0.4	358	0.00
	Jharkhand	1893	0	37.2	25.7	-0.6	158	0.00
	Odisha	4955	0	102.7	41.5	-1.8	319	0.00
	West Bengal	7657	0	155.3	30.8	-3.3	119	0.00
	Sikkim	68	0	1.1	1.3	-0.2	8	0.00
	Railways_ER ISTS	13	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	151	0	2.6	2.6	-0.2	36	0.00
	Assam	1624	0	29.1	21.5	0.2	117	0.00
	Manipur	280	0	2.5	2.6	-0.1	43	0.00
	Meghalaya	350	0	6.2	5.1	-0.1	80	0.00
	Mizoram	115	0	1.8	1.3	-0.2	7	0.00
	Nagaland	153	0	2.4	2.2	0.0	13	0.00
	Tripura	262	0	4.6	5.2	0.3	43	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	7.7	10.9	-23.1	-12.2
Day Peak (MW)	443.5	574.8	-986.0	-511.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	247.7	-164.9	108.5	-191.1	-0.3	0.0
Actual(MU)	242.9	-154.7	102.2	-198.3	-1.5	-9.4
O/D/U/D(MU)	-4.8	10.2	-6.3	-7.2	-1.2	-9.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5012	8994	4648	3336	597	22586	42
State Sector	9328	10246	7911	3269	230	30984	58
Total	14340	19240	12559	6605	827	53570	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	675	1474	597	681	15	3443	76
Lignite	26	17	49	0	0	92	2
Hydro	133	34	89	45	19	320	7
Nuclear	35	49	76	0	0	160	4
Gas, Naptha & Diesel	9	6	6	0	20	41	1
RES (Wind, Solar, Biomass & Others)	170	132	194	4	1	502	11
Total	1049	1712	1011	730	56	4558	100

Share of RES in total generation (%)	16.25	7.69	19.20	0.59	2.02	11.01
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.32	12.52	35.50	6.75	36.80	21.55

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.022
Based on State Max Demands	1.064

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	191376	10:21	0
Non-Solar hr	185795	18:19	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 11-Nov-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.2	-7.2
2	HVDC	PUSAULI B/B	-	0	297	0.0	7.0	-7.0
3	765 kV	GAYA-VARANASI	2	151	1033	0.0	16.1	-16.1
4	765 kV	SASARAM-FATEHPUR	1	86	497	0.0	7.6	-7.6
5	765 kV	GAYA-BALIA	1	0	662	0.0	11.9	-11.9
6	400 kV	PUSAULI-VARANASI	1	0	254	0.0	4.6	-4.6
7	400 kV	PUSAULI -ALLAHABAD	1	0	135	0.0	2.4	-2.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	120	522	0.0	7.4	-7.4
9	400 kV	PATNA-BALIA	2	0	841	0.0	15.0	-15.0
10	400 kV	NAUBATPUR-BALIA	2	0	273	0.0	4.7	-4.7
11	400 kV	BIHARSHARIFF-BALIA	2	146	141	0.0	1.6	-1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	411	0.0	7.1	-7.1
13	400 kV	BIHARSHARIFF-VARANASI	2	49	335	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	97	0.0	0.5	-0.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	92.8	-92.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	503	743	0.0	2.5	-2.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	800	527	0.7	0.0	0.7
3	765 kV	JHARSUGUDA-DURG	2	0	892	0.0	17.0	-17.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	611	0.0	9.2	-9.2
5	400 kV	RANCHI-SIPAT	2	130	216	0.0	1.9	-1.9
6	220 kV	BUDHIPADAR-RAIGARH	1	20	85	0.0	1.1	-1.1
7	220 kV	BUDHIPADAR-KORBA	2	105	64	0.0	0.4	-0.4
ER-WR						0.7	32.1	-31.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	528	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1995	0.0	41.4	-41.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2486	0.0	43.1	-43.1
4	400 kV	TALCHER-I/C	2	376	235	2.1	0.0	2.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	97.1	-97.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	546	0.1	8.6	-8.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	757	0.0	11.2	-11.2
3	220 kV	ALIPURDUAR-SALAKATI	2	0	141	0.0	2.0	-2.0
ER-NER						0.1	21.9	-21.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	1005	0.0	24.1	-24.1
NER-NR						0.0	24.1	-24.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1013	0.0	24.8	-24.8
2	HVDC	VINDHYACHAL B/B	-	173	116	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1448	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1310	0.0	18.8	-18.8
5	765 kV	GWALIOR-PHAGI	2	410	1982	0.6	29.5	-28.9
6	765 kV	JABALPUR-ORAI	2	0	960	0.0	30.7	-30.7
7	765 kV	GWALIOR-ORAI	1	884	0	15.1	0.0	15.1
8	765 kV	SATNA-ORAI	1	0	974	0.0	19.8	-19.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1290	0	17.2	0.0	17.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	2039	0.0	35.8	-35.8
11	400 kV	ZERDA-KANKROLI	1	377	0	4.7	0.0	4.7
12	400 kV	ZERDA -BHINMAL	1	261	0	3.3	0.0	3.3
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	22.1	0.0	22.1
14	400 kV	RAPP-SHUJALPUR	2	467	243	2.4	1.5	1.0
15	400 kV	NEEMUCH-Chittorgarh	2	0	0	2.2	0.0	2.2
16	220 kV	BHANPURA-RANPUR	1	0	196	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	102	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	67	0	0.9	0.0	0.9
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						70.0	203.9	-134.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	17.3	-17.3
2	HVDC	RAIGARH-PUGALUR	2	0	4008	0.0	45.2	-45.2
3	765 kV	SOLAPUR-RAICHUR	2	1630	98	15.6	0.0	15.6
4	765 kV	WARDHA-NIZAMABAD	2	159	1405	0.0	14.8	-14.8
5	765 kV	WARORA-WARANGAL(NEW)	2	679	309	21.0	0.0	21.0
6	400 kV	KOLHAPUR-KUDGI	2	1526	0	28.8	0.0	28.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	71	0.6	0.0	0.6
9	220 kV	XELDEM-AMBEWADI	1	0	107	2.1	0.0	2.1
WR-SR						68.2	77.3	-9.1

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	201	146	171	4.11	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	328	170	238	5.70	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-154	-80	-121	-2.91	
	NER	132kV GELEPHU-SALAKATI	17	2	11	0.26	
	NER	132kV MOTANGA-RANGIA	31	17	24	0.57	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	61	1.47	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	506	184	392	9.41	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-914	-904	-908	-21.78	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-511	-497	-507	-12.17	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-72	0	-57	-1.36	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.69

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.49
Nepal	0.00	0.00	0.00	0.00	0.00	9.92	0.00	0.00	9.92
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	7.49	0.00	0.00	0.00	0.00	9.92	0.00	0.00	17.41

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.49
Nepal	0.00	0.00	0.00	0.00	0.00	9.92	0.00	0.00	9.92
Bangladesh	-22.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-15.20	0.00	0.00	0.00	0.00	9.92	0.00	0.00	-5.28

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A- (C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	50.04	164757	5828	3214	46	11289	1903	144324	1351	161497	167955	-19
0:15	49.89	164280	5823	3302	45	11221	1728	143953	1344	160933	167416	-6
0:30	49.94	163109	5816	3358	46	11170	1672	142940	1347	159705	166349	6
0:45	49.99	162964	5809	3489	45	11228	1672	142395	1362	159430	166000	20
1:00	50.04	161762	5828	3446	46	11224	1663	141331	1328	158270	164866	17
1:15	49.94	160489	5836	3487	45	10846	1670	140370	1325	156957	163579	7
1:30	49.94	159830	5833	3520	44	10219	1668	140289	1329	156266	162902	14
1:45	49.99	159224	5827	3600	45	9928	1673	139982	1333	155579	162388	17
2:00	50.04	158207	5977	3665	43	9739	1677	138961	1329	154499	161391	-7
2:15	50.04	157772	6197	3666	45	9245	1672	138863	1337	154061	161025	-15
2:30	50.04	157170	6269	3711	45	9153	1659	138317	1331	153414	160485	-5
2:45	50.04	156913	6297	3785	45	9182	1669	137911	1335	153083	160224	-21
3:00	50.04	156286	6316	3802	45	9161	1638	137161	1380	152439	159503	16
3:15	49.98	156054	6320	3676	44	9262	1574	137201	1351	152334	159428	-8
3:30	50.03	155866	6318	3740	42	9516	1575	136568	1350	152084	159109	-3
3:45	50.03	155744	6330	3657	44	9794	1554	136326	1332	152043	159037	-1
4:00	50.03	155705	6320	3668	44	9806	1555	136341	1347	151993	159081	8
4:15	50.04	156186	6331	3731	44	9367	1573	137163	1361	152411	159570	-11
4:30	50.04	157219	6322	3883	44	9672	1556	137889	1383	153292	160749	-24
4:45	50.04	158198	6315	3873	45	10304	1522	138309	1381	154280	161749	-43
5:00	50.04	159621	6298	3885	45	10765	1564	139186	1423	155691	163166	-84
5:15	50.04	162157	6318	3859	45	11466	1559	141178	1430	158253	165855	-92
5:30	50.04	164051	6325	3852	42	12777	1568	141668	1432	160157	167664	-61
5:45	50.04	166309	6319	3866	42	14049	1570	142573	1476	162401	169895	-127
6:00	50.09	167693	6314	3802	46	16039	1573	142002	1426	163845	171202	-189
6:15	50.09	169160	6324	3771	60	17705	1556	141983	1401	165329	172800	-193
6:30	50.03	172288	6315	3721	75	19117	1559	142889	1495	168492	175171	-180
6:45	50.04	174842	6326	3686	168	19684	1550	143962	1432	170988	176808	-182
7:00	49.98	176387	6306	3756	455	19910	1550	143522	1421	172176	176920	-198
7:15	49.99	177206	6314	3767	1185	19977	1564	142787	1420	172254	177014	-225
7:30	50.04	178459	6313	3847	2696	19364	1560	141624	1469	171916	176873	-245
7:45	49.99	179113	6314	3810	4930	16308	1568	141930	1595	170373	176455	-240
8:00	50.04	179553	6320	3207	14109	15338	1561	140304	1570	162237	182409	-213
8:15	50.03	182330	6346	3107	18671	14275	1582	139765	1552	160552	185298	-216
8:30	50.09	183468	6326	3080	23126	13086	1567	137579	1580	157262	186344	-208
8:45	49.98	184944	6338	3106	27156	12304	1563	135464	1633	154682	187564	-170
9:00	50.08	186177	6333	3121	30891	11762	1577	133577	1612	152165	188873	-144
9:15	50.04	188984	6340	3030	34256	11093	1588	133610	1613	151698	191530	-159
9:30	50.04	190169	6339	2925	37424	10011	1582	132838	1651	149820	192770	-222
9:45	50.04	190687	6324	2914	25397	8366	1565	132171	1648	162376	178385	-237
10:00	50.04	190786	6343	2936	42862	8201	1600	129660	1665	144988	193267	-232
10:15	50.03	190900	6331	2970	45145	7852	1601	127927	1686	142785	193512	-224
10:30	50.03	190930	6332	2992	46915	8070	1595	125839	1706	141023	193449	-186
10:45	50.03	191107	6350	2960	48549	7772	1645	124520	1690	139598	193486	-116
11:00	50.03	191105	6321	3038	49786	7469	1665	123305	1727	138281	193311	-122
11:15	49.98	190802	6327	3030	33297	7339	1685	122274	1705	154475	175657	-152
11:30	49.98	189994	6341	2934	51136	7531	1706	120947	1722	135924	192317	-64
11:45	49.93	189490	6320	2965	51215	7176	1710	120543	1769	135310	191698	-34
12:00	49.99	189050	6321	2928	51618	7135	1709	119979	1735	134504	191425	-28
12:15	49.94	187642	6329	2833	51287	7048	1716	119322	1734	133522	190269	-62
12:30	49.94	187480	6311	2817	51175	7112	1705	119121	1700	133488	189941	-75
12:45	49.94	187264	6309	2798	51211	7158	1709	118765	1682	133255	189632	-77
13:00	50.04	185754	6329	2815	50933	6994	1713	117860	1695	132006	188339	-91
13:15	49.99	184054	6340	2904	50027	6861	1700	117454	1686	131123	186972	-74
13:30	50.04	183216	6365	2832	49522	6854	1697	117331	1704	130862	186305	-64
13:45	49.98	183290	6363	2699	48213	6762	1697	118650	1682	132378	186066	-53
14:00	50.03	182764	6367	2626	46641	6802	1703	119471	1670	133497	185280	-79
14:15	49.98	182719	6379	2583	45248	7053	1717	120671	1656	134888	185307	-71
14:30	49.99	183327	6377	2528	42880	7269	1711	123430	1686	137919	185881	-78
14:45	49.98	184144	6371	2532	40305	8124	1734	126092	1653	141307	186811	-80
15:00	49.98	184421	6370	2460	37934	8653	1742	128192	1621	144027	186972	-91
15:15	50.03	183530	6384	2433	34774	9406	1754	129345	1619	146323	185715	-93
15:30	49.93	183070	6374	2408	31981	9788	1766	131391	1632	148681	185340	-94
15:45	49.88	182440	6383	2429	28305	11007	1747	133237	1597	151706	184705	-70
16:00	49.98	182156	6356	2497	24432	12279	1738	135386	1583	155227	184271	-83
16:15	49.98	180391	6373	2549	20593	12410	1740	137531	1536	157249	182732	-82
16:30	49.93	180416	6375	2562	16502	13656	1741	140479	1561	161352	182876	-84
16:45	49.88	180260	6373	2638	11906	15112	1736	143589	1548	165716	182902	-119
17:00	50.08	180260	6370	2693	7870	16912	1738	146275	1420	169697	183278	-200
17:15	49.98	179618	6387	2727	4573	17055	1737	148527	1469	172318	182475	-288

17:30	50.08	180876	6396	2831	2174	19837	1729	149535	1392	175871	183894	-363
17:45	50.03	183876	6386	2975	762	21944	1737	151566	1397	180139	186767	-406
18:00	50.08	184907	6393	3305	302	23742	1748	150998	1433	181300	187921	-378
18:15	50.03	185322	6402	3547	247	24289	1738	150805	1421	181528	188449	-365
18:30	49.98	185311	6428	3738	187	25480	1736	149502	1423	181386	188494	-360
18:45	50.03	184272	6424	3949	358	25072	1729	148371	1415	179965	187318	-339
19:00	49.98	182251	6407	4159	360	24737	1737	146628	1418	177732	185446	-340
19:15	50.03	180004	6426	4267	326	23335	1744	145714	1436	175411	183248	-289
19:30	49.93	177900	6424	4192	328	22238	1732	144538	1410	173380	180862	-264
19:45	49.98	175584	6427	4246	90	20612	1746	144040	1385	171248	178546	-250
20:00	50.03	173427	6438	4316	90	19590	1749	142805	1396	169021	176384	-237
20:15	49.93	171081	6440	4331	80	18210	1734	141801	1449	166670	174045	-184
20:30	49.93	169921	6429	4332	78	17438	1731	141549	1400	165511	172957	-162
20:45	49.88	168758	6429	4301	79	17048	1751	140875	1393	164378	171876	-139
21:00	50.03	167386	6453	4449	44	16236	1760	140145	1405	162893	170492	-139
21:15	49.98	166752	6470	4516	44	15897	1756	139696	1424	162192	169803	-127
21:30	49.98	165570	6452	4487	44	15459	1763	138957	1424	161039	168586	-138
21:45	50.03	164827	6455	4515	42	15088	1765	138594	1440	160270	167899	-293
22:00	50.03	163515	6450	4441	44	13981	1797	138302	1403	159030	166418	-202
22:15	49.98	164005	6459	4516	45	13869	1817	138987	1405	159444	167098	-162
22:30	49.98	163717	6453	4556	44	13318	1804	139043	1434	159117	166652	-140
22:45	49.98	163056	6446	4660	45	12381	1830	139113	1391	158351	165866	-139
23:00	50.03	161877	6461	4714	42	11778	1883	138553	1408	157121	164839	-126
23:15	49.98	161472	6460	4743	44	10875	1894	138912	1389	156685	164317	-113
23:30	50.03	160404	6455	4628	44	10617	1910	138464	1381	155732	163499	-124
23:45	50.03	159352	6466	4552	44	10278	1887	137896	1414	154756	162537	-122

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.