



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57486	65016	47946	22967	2840	196255
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1281	1523	1139	466	52	4461
Hydro Gen (MU)	117	41	112	24	13	307
Wind Gen (MU)	4	74	97	-	-	176
Solar Gen (MU)*	189.04	170.62	134.94	3.42	1.10	499
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69449	74337	56518	23970	3008	222472
Time Of Maximum Demand Met	10:40	09:56	09:44	17:39	17:13	10:26

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.036	0.00	0.76	4.70	5.46	80.95	13.59

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9805	0	170.0	82.2	-0.8	421	0.00
	Haryana	9460	0	172.6	124.6	-1.0	480	0.00
	Rajasthan	18294	0	338.2	112.3	-1.7	909	0.00
	Delhi	4497	0	81.3	74.1	1.6	496	0.00
	UP	19979	0	363.6	96.0	-0.3	722	0.00
	Uttarakhand	2440	0	44.2	32.5	0.6	123	0.00
	HP	2204	0	38.5	30.0	-0.7	78	0.00
	J&K(UT) & Ladakh(UT)	3088	0	64.8	64.3	-0.8	114	0.00
	Chandigarh	244	0	4.0	4.0	0.1	18	0.00
	Railways_NR ISTS	202	0	4.1	3.8	0.3	34	0.00
WR	Chhattisgarh	4772	0	95.4	41.1	1.1	374	0.00
	Gujarat	21994	0	429.0	167.9	-1.9	582	0.00
	MP	18684	0	344.5	222.6	0.0	414	0.00
	Maharashtra	27240	0	569.7	171.4	-3.6	762	0.00
	Goa	701	0	13.8	11.7	1.9	45	0.00
	DNHDDPDCL	1358	0	30.8	30.7	0.1	63	0.00
	AMNSIL	915	0	20.6	13.0	0.5	271	0.00
	BALCO	567	0	13.5	13.7	-0.2	18	0.00
	RIL JAMNAGAR	263	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	10172	0	202.0	48.2	-2.4	457	0.00
SR	Telangana	12891	0	229.7	97.5	1.2	774	0.00
	Karnataka	15854	0	281.3	93.4	-1.2	533	0.00
	Kerala	4479	0	85.0	61.2	-1.2	191	0.00
	Tamil Nadu	16734	0	332.1	201.4	-2.3	655	0.00
	Puducherry	414	0	8.8	8.4	-0.2	28	0.00
	Bihar	5301	0	97.0	84.0	-2.3	750	0.00
ER	DVC	3216	0	62.3	-42.0	-0.8	328	0.00
	Jharkhand	2170	0	40.5	28.4	-1.3	196	0.00
	Odisha	5621	0	109.1	29.5	-4.0	494	0.00
	West Bengal	7741	0	154.7	28.5	-2.1	230	0.00
	Sikkim	112	0	1.8	1.8	0.0	28	0.00
	Railways_ER ISTS	12	0	0.2	0.2	0.1	4	0.00
NER	Arunachal Pradesh	183	0	3.2	3.0	0.1	22	0.00
	Assam	1722	0	29.1	22.4	0.7	157	0.00
	Manipur	259	0	3.8	3.8	0.0	33	0.00
	Meghalaya	345	0	6.1	5.3	-0.1	63	0.00
	Mizoram	154	0	2.4	1.8	-0.1	14	0.00
	Nagaland	174	0	2.6	2.7	-0.3	11	0.00
	Tripura	244	0	4.7	4.9	0.3	26	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-8.9	7.0	-22.0	-25.1
Day Peak (MW)	-672.2	636.1	-1011.4	-1370.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	247.2	-232.7	122.7	-145.9	8.7	0.0
Actual(MU)	238.9	-219.7	113.5	-152.4	6.7	-13.0
O/D/U/D(MU)	-8.4	13.0	-9.2	-6.6	-2.0	-13.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5942	12585	6868	6220	190	31805	50
State Sector	9849	10774	8514	2077	226	31439	50
Total	15791	23358	15382	8297	416	63244	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	725	1481	639	665	13	3523	73
Lignite	23	15	53	0	0	91	2
Hydro	117	41	112	24	13	307	6
Nuclear	37	52	47	0	0	136	3
Gas, Naptha & Diesel	9	27	4	0	23	63	1
RES (Wind, Solar, Biomass & Others)	219	248	261	7	1	735	15
Total	1130	1865	1115	696	50	4856	100

Share of RES in total generation (%)	19.37	13.29	23.39	0.95	2.20	15.14
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.04	18.32	37.60	4.40	27.70	24.27

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	222472	10:26	0
Non-Solar hr	208013	17:59	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 11-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	161	1258	0.0	17.6	-17.6
4	765 kV	SASARAM-FATEHPUR	1	50	535	0.0	8.9	-8.9
5	765 kV	GAYA-BALIA	1	0	755	0.0	12.0	-12.0
6	400 kV	PUSAULI-VARANASI	1	20	74	0.0	0.4	-0.4
7	400 kV	PUSAULI-ALLAHABAD	1	0	118	0.0	1.9	-1.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	267	788	0.0	9.0	-9.0
9	400 kV	PATNA-BALIA	2	0	965	0.0	12.6	-12.6
10	400 kV	NAUBATPUR-BALIA	2	137	252	0.0	4.7	-4.7
11	400 kV	BIHARSHARIFF-BALIA	2	271	366	0.0	2.2	-2.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	579	0.0	8.0	-8.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	55	531	0.0	6.7	-6.7
14	220 kV	SAHUPURI-KARMANASA	1	2	0	0.0	1.6	-1.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	10	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.6	-0.6
ER-NR						0.6	88.5	-87.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	466	708	0.0	4.6	-4.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	665	785	0.0	8.7	-8.7
3	765 kV	JHARSUGUDA-DURG	2	0	1146	0.0	19.9	-19.9
4	400 kV	JHARSUGUDA-RAIGARH	4	354	199	0.6	0.0	0.6
5	400 kV	RANCHI-SIPAT	2	129	259	0.0	2.1	-2.1
6	400 kV	JEYPORE-JACDALPUR	2	241	409	0.0	0.2	-0.2
7	220 kV	BUDHIPADAR-RAIGARH	1	0	123	0.0	1.5	-1.5
8	220 kV	BUDHIPADAR-KORBA	2	51	42	0.2	0.0	0.2
ER-WR						0.8	37.1	-36.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	123	0.0	2.9	-2.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1482	0.0	29.9	-29.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2697	0.0	44.3	-44.3
4	400 kV	TALCHER/IC	2	733	221	7.7	0.0	7.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	77.1	-77.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	299	181	1.7	0.4	1.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	563	120	4.7	0.0	4.7
3	220 kV	ALIPURDUAR-SALAKATI	2	116	7	1.2	0.0	1.2
ER-NER						7.6	0.4	7.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4018	0.0	62.9	-62.9
2	HVDC	VINDHYACHAL B/B	-	0	58	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1925	0.0	39.4	-39.4
4	765 kV	GWALIOR-AGRA	2	0	1830	0.0	24.9	-24.9
5	765 kV	GWALIOR-PHAGI	2	629	2058	1.2	26.7	-25.6
6	765 kV	JABALPUR-ORAI	2	0	1047	0.0	32.4	-32.4
7	765 kV	GWALIOR-ORAI	1	1031	0	17.1	0.0	17.1
8	765 kV	SATNA-ORAI	1	0	1133	0.0	20.6	-20.6
9	765 kV	BANASKANTHA-CHITORGARH	2	2009	200	24.1	0.1	24.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2300	0.0	38.3	-38.3
11	400 kV	ZERDA-KANKROLI	1	303	0	4.1	0.0	4.1
12	400 kV	ZERDA -BHINMAL	1	209	0	2.8	0.0	2.8
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	21.3	0.0	21.3
14	400 kV	RAPP-SHUJALPUR	2	608	341	3.2	1.8	1.5
15	400 kV	NEEMUCH-Chittorgarh	2	626	406	3.2	2.6	0.6
16	220 kV	BHANPURA-RANPUR	1	0	128	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	146	0	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	111	12	0.1	0.1	0.0
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						78.8	254.5	-175.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	430	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	40.4	-40.4
3	765 kV	SOLAPUR-RAICHUR	2	657	1261	2.2	5.2	-3.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2229	0.0	25.4	-25.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2593	0.0	33.9	-33.9
6	400 kV	KOLHAPUR-KUDGI	2	1500	0	28.4	0.0	28.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	2	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	2.1	0.0	2.1
WR-SR						32.7	112.1	-79.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-200	48	-81	-1.93
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	338	-104	80	1.91
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-329	-251	-296	-7.10
	NER	132kV GELEPHU-SALAKATI	-64	-48	-57	-1.36
	NER	132kV MOTANGA-RANGIA	-24	-6	-17	-0.40
NEPAL	NR	NEPAL IMPORT (FROM UP)	-29	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	54	0	27	0.65
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	390	212	264	6.34
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-890	-604	-818	-19.63
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1371	-815	-1045	-25.09
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-120	0	-100	-2.40

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 11-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	8.24	0.00	0.00	0.81	0.00	0.00	9.36
Nepal	0.12	0.00	0.00	0.00	0.00	0.24	0.00	0.00	0.36
Bangladesh	20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.52	0.31	8.24	0.00	0.00	1.05	0.00	0.00	30.12

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.71	0.00	0.00	5.87	0.00	0.00	6.58
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.71	0.00	0.00	5.87	0.00	0.00	6.58

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-8.24	0.00	0.00	-0.81	0.00	0.00	-9.36
Nepal	-0.12	0.00	0.71	0.00	0.00	5.64	0.00	0.00	6.23
Bangladesh	-20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.52	-0.31	-7.53	0.00	0.00	4.83	0.00	0.00	-23.53

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.04	150989	5079	11207	0	7853	2234	124661	3135	139782	154169	-828
0:15	50.04	150012	5084	10968	0	7797	2229	124092	3179	139044	153349	-1038
0:30	49.99	149610	5081	10905	0	8227	2235	123338	3120	138705	152906	-964
0:45	49.94	148569	5094	10814	0	8030	2237	122596	3164	137755	151935	-938
1:00	50.04	148426	5087	10732	0	8001	2232	122489	3270	137694	151811	-1000
1:15	49.99	147568	5085	10453	0	8076	2219	121966	3146	137115	150945	-989
1:30	49.99	147177	5096	10336	0	7864	2230	121762	3221	136841	150509	-1015
1:45	49.99	146718	5096	10232	0	7710	2230	121855	3203	136486	150326	-989
2:00	49.99	145368	5084	10067	0	7661	2230	121089	3152	135301	149283	-1005
2:15	49.99	145532	5090	9876	0	7602	2275	120947	3174	135656	148964	-980
2:30	49.99	145546	5096	9506	0	7480	2271	121619	3167	136040	149139	-973
2:45	49.99	145743	5083	9503	0	7343	2275	121890	3141	136240	149235	-901
3:00	49.99	145165	5098	9306	0	7323	2271	121528	3143	135859	148669	-850
3:15	49.94	145551	5070	9100	0	7085	2286	122467	3127	136451	149135	-882
3:30	49.99	145362	5086	9036	0	7084	2272	122540	3141	136326	149159	-842
3:45	49.94	145877	5089	8798	0	7240	2291	122853	3150	137079	149421	-840
4:00	49.99	146529	5082	8550	0	7464	2284	123553	3144	137979	150077	-862
4:15	49.89	148937	5090	8318	0	7917	2295	125730	3125	140619	152475	-849
4:30	49.99	150450	5094	8070	0	8522	2306	132911	3126	142380	160029	-729
4:45	49.99	151759	5096	7875	0	9062	2286	128351	3123	143884	155793	-808
5:00	50.09	154136	5093	7728	104	9706	2284	130011	3143	146304	158069	-872
5:15	49.99	158746	5100	7730	103	10052	2293	134268	3132	150913	162678	-951
5:30	50.04	164379	5078	7747	108	11422	2331	138268	3179	156524	168133	-692
5:45	49.99	169668	5093	7816	92	11569	2380	143262	3123	161760	173335	-575
6:00	50.09	174344	5090	7616	96	12482	2357	146578	3155	166632	177374	-462
6:15	49.99	180042	5090	8162	423	13743	2329	150963	3122	171457	183832	-474
6:30	50.04	187327	5079	8040	437	17306	2335	154865	3019	178850	191081	-512
6:45	49.89	193514	5079	8005	566	20084	2349	158436	3085	184943	197604	-619
7:00	49.94	199046	5076	8046	1194	22556	2344	160815	3082	189806	203113	-658
7:15	49.79	203871	5075	8134	2392	24786	2371	162070	3132	192345	207960	-607
7:30	49.99	206911	5076	8115	4846	25278	2358	161996	3149	193950	210818	-647
7:45	50.04	208598	5088	8216	8595	24611	2357	160509	3175	191787	212551	-873
8:00	50.14	209088	5093	8256	13868	21483	2374	158464	3122	186964	212660	-950
8:15	50.04	211449	5103	7889	20443	19223	2298	156138	3197	183117	214291	-784
8:30	50.04	213063	5096	7600	27346	15989	2291	153675	3122	178117	215119	-756
8:45	49.99	213316	5089	7134	34460	13027	2281	149888	3048	171722	214927	-730
9:00	50.04	214311	5098	6829	40749	11583	2261	145878	3089	166733	215487	-817
9:15	49.99	218732	5084	6559	46364	10815	2250	145945	3068	165809	220085	-786
9:30	49.99	220096	5085	6232	50795	9867	2251	143779	3095	163069	221104	-829
9:45	49.99	222229	5069	6064	54534	9125	2243	143165	3040	161631	223240	-1058
10:00	50.09	221715	5077	5958	57679	8581	2245	140350	3036	158078	222926	-1204
10:15	49.99	222029	5065	5854	59819	7455	2245	139483	3061	156356	222982	-1455
10:30	49.99	222398	5063	5817	61636	7035	2236	138556	3035	154945	223378	-1491
10:45	50.04	221757	5059	5862	63103	6744	2236	136934	3058	152792	222996	-1471
11:00	49.99	220519	5067	5734	64613	6622	2234	134415	3079	150172	221764	-1519
11:15	49.94	219183	5060	5712	65883	6478	2237	132204	3043	147588	220617	-1568
11:30	49.94	218368	5053	5732	66747	6723	2232	130404	3018	145889	219909	-1671
11:45	49.99	216704	5064	5538	67245	6409	2215	128745	3116	143921	218332	-1729
12:00	50.04	215059	5071	5542	67504	6487	2205	126743	3039	142013	216591	-1722
12:15	49.94	212491	5052	5556	67573	6222	2208	124288	3022	139362	213921	-1651
12:30	49.99	210930	5066	5598	67902	5898	2209	120452	2649	137430	209774	-1683
12:45	49.99	209199	5064	5668	67631	6282	2210	121151	2998	135900	211004	-1680
13:00	50.09	206359	5060	5644	67092	6562	2190	118473	2989	133623	208010	-1688
13:15	49.99	202345	5074	5603	65957	6282	2199	115763	3015	130785	203893	-1686
13:30	49.99	201753	5054	5639	65856	6320	2206	115351	3067	130258	203493	-1661
13:45	49.99	202283	5055	5666	65241	5653	2203	117559	2980	131376	204357	-1655
14:00	49.99	201810	5053	5568	64655	5703	2205	118564	3018	131587	204766	-1682
14:15	49.99	202709	5052	5447	62964	6040	2225	121071	3097	134298	205896	-1653
14:30	49.99	203990	5026	5349	61112	6406	2219	124267	3011	137529	207390	-1668
14:45	49.99	204881	5024	5125	59374	6559	2218	126943	3072	140382	208315	-1680
15:00	50.04	206023	5013	4884	57302	6708	2220	129565	2995	143837	208687	-1690
15:15	49.99	204514	5040	4646	54449	6668	2078	132158	2997	145419	208036	-1732
15:30	50.04	206290	5230	4510	50613	7235	2377	136899	3031	151167	209895	-1732
15:45	49.99	205986	5031	4414	45972	7604	2621	141152	3099	155600	209893	-1748
16:00	50.04	205472	5030	4229	40673	8853	2881	144534	3068	160570	209268	-1598
16:15	49.94	202863	5023	4251	34638	9217	3138	146912	3088	163974	206267	-1576
16:30	49.99	203540	5024	4169	27758	11814	3226	152130	3126	171613	207247	-1592
16:45	49.89	203783	5028	4082	20383	15471	3292	156483	3094	179318	207833	-1516
17:00	49.99	203125	5007	4086	13581	18841	3580	158878	3103	185458	207076	-1245
17:15	50.04	200368	5036	4089	7968	21982	3937	158158	3133	188311	204303	-1053
17:30	50.09	202839	5039	4045	4071	26529	4057	159694	3148	194723	206583	-817
17:45	49.94	205930	5034	4220	1845	28634	4159	162640	3106	199865	209638	-628
18:00	49.99	207810	5025	4463	784	30133	4206	163331	3148	202563	211090	-561
18:15	49.94	206580	5034	4838	415	29138	4209	163399	3136	201327	210169	-540
18:30	50.04	207295	5045	5142	311	29744	4133	163271	3177	201842	210823	-508
18:45	50.04	205995	5043	5313	224	29527	3513	162865	3184	200458	209669	-466
19:00	50.04	201945	5044	5531	139	27313	2769	162000	3194	196275	205990	-481
19:15	49.99	200090	5047	5859	180	25899	2415	161413	3200	194051	204013	-502
19:30	49.99	197323	5048	6217	0	23121	2335	161340	3183	191106	201244	-534
19:45	49.99	193872	5041	6336	0	20576	2341	160084	3241	187536	197619	-527
20:00	50.04	189551	5050	6402	0	17951	2359	158237	3224	183149	193223	-492
20:15	50.04	186173	5056	6578	0	16693	2323	155901	3192	179595	189743	-459
20:30	50.04	183497	5055	6629	0	15159	2342	154729	3236	176868	187150	-572
20:45	50.03	180576	5048	6686	0	13491	2343	153435	3170	173890	184173	-579
21:00	50.03	177740	5047	6876	0	12688	2335	150882	3235	170864	181063	-552
21:15	50.04	174619	5068	6817	0	11464	2342	148960	3261	167802	177912	-526
21:30	50.04	171636	5066	7042	0	10769	2303	146511	3235	164594	174926	-548
21:45	50.04	169115	5076	7243	0	10100	2271	144456	3228	161872	172374	-509
22:00	50.09	165508	5073	7446	0	8813	2136	141741	3271	158062	168480	-506
22:15	49.99	164555	5075	7666	0	9512	2146	140279	3275	156889	167953	-771
22:30	50.04	163211	5067	7864	0	9145	2145	139196	3220	155347	166637	-959
22:45	49.99	161250	5082	8006	0							