National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, क़ुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report दिनांक: 03.03.2025

To,

1. कार्यकारी निदेशक, पू .क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 02.03.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 2-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 02.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day **Date of Reporting: 03-Mar-2025**

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	51154	66732	47390	24084	2499	191859
Peak Shortage (MW)	0	106	0	0	30	136
Energy Met (MU)	1101	1610	1302	503	44	4559
Hydro Gen (MU)	125	45	76	21	7	274
Wind Gen (MU)	23	66	46	-	-	135
Solar Gen (MU)*	204.07	132.59	137.55	3.75	0.93	479
Energy Shortage (MU)	0.09	1.00	0.00	0.01	0.32	1.42
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	54799	74329	62601	23324	2642	212879
Time Of Maximum Demand Met	10:14	10:43	09:29	18:44	18:06	10:25

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.00	3.34	3.34	79.50	17.15

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6872	0	125.5	46.7	-1.0	263	0.00
	Haryana	6161	0	120.2	77.6	-2.7	288	0.00
	Rajasthan	16934	0	325.0	91.4	-1.6	737	0.00
	Delhi	3705	0	67.9	59.2	0.6	376	0.00
	UP	17854	0	326.7	88.8	-2.2	473	0.00
	Uttarakhand	1979	0	36.9	24.5	-0.6	108	0.00
	HP	1746	0	30.8	20.4	-0.2	412	0.00
	J&K(UT) & Ladakh(UT)	2908	0	61.0	58.9	-3.2	1261	0.09
	Chandigarh	191	0	3.2	3.3	-0.1	13	0.00
	Railways_NR ISTS	196	0	4.1	3.7	0.4	29	0.00
WR	Chhattisgarh	6112	0	139.3	73.6	0.8	262	0.00
	Gujarat	21397	0	432.8	187.9	-2.9	537	0.00
	MP	16069	0	328.3	200.7	-0.8	717	1.00
	Maharashtra	28076	0	630.9	245.4	0.4	564	0.00
	Goa	686	0	14.6	14.1	0.0	83	0.00
	DNHDDPDCL	1232	0	29.0	28.9	0.1	36	0.00
	AMNSIL	761	0	17.4	10.0	0.4	253	0.00
	BALCO	530	0	12.7	12.7	0.0	8	0.00
	RIL JAMNAGAR	196	0	4.7	5.1	-0.4	0	0.00
SR	Andhra Pradesh	12311	0	235.6	72.5	-0.4	439	0.00
	Telangana	15985	0	308.3	196.1	-1.0	585	0.00
	Karnataka	16705	0	321.2	133.7	-0.5	1219	0.00
	Kerala	4412	0	90.6	71.3	0.7	724	0.00
	Tamil Nadu	15350	0	337.3	213.3	-3.6	940	0.00
	Puducherry	394	0	9.1	8.6	-0.2	31	0.00
ER	Bihar	4920	0	97.1	89.7	0.7	328	0.01
	DVC	3257	0	69.6	-41.1	-0.2	250	0.00
	Jharkhand	1976	0	39.4	30.7	0.2	296	0.00
	Odisha	5889	0	121.4	50.7	-1.8	400	0.00
	West Bengal	8154	0	173.7	35.4	-1.3	336	0.00
	Sikkim	86	0	1.3	1.6	-0.3	10	0.00
	Railways_ER ISTS	14	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	146	0	2.1	3.3	-1.2	0	0.00
	Assam	1586	0	28.9	20.0	3.1	186	0.00
	Manipur	185	59	2.0	2.7	-0.7	31	0.32
	Meghalaya	294	0	4.1	4.2	-0.8	54	0.00
	Mizoram	139	0	1.6	1.8	-0.5	33	0.00
	Nagaland	136	0	1.3	1.9	-0.7	33	0.00
	Tripura	254	0	3.8	4.0	-0.3	78	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.5	-11.5	-24.2	-19.2
Day Peak (MW)	-516.0	-661.9	-1042.0	-1372.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	48.1	-178.2	256.3	-197.8	8.5	-63.1
Actual(MU)	28.0	-163.0	254.8	-175.4	7.3	-48.3
O/D/U/D(MU)	-20.0	15.2	-1.5	119.4	-1.2	111.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5093	9311	3628	3616	1161	22809	45
State Sector	8663	10077	6696	2599	181	28216	55
Total	13756	19388	10324	6215	1342	51025	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	726	1555	698	706	9	3694	75
Lignite	27	13	51	0	0	91	2
Hydro	125	45	76	21	7	274	6
Nuclear	21	65	71	0	0	156	3
Gas, Naptha & Diesel	7	12	5	0	24	48	1
RES (Wind, Solar, Biomass & Others)	249	201	213	6	1	670	14
Total	1154	1891	1114	732	41	4933	100

Share of RES in total generation (%)	21.56	10.65	19.12	0.77	2.25	13.58
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.17	16.45	32.32	3.57	20.05	22.31

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.022
Based on State Max Demands	1.061

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212879	10:25	0
Non-Solar hr	193375	18:59	129

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 03-Mar-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	412	943	0.0	10.2	-10.2
4	765 kV	SASARAM-FATEHPUR	1	116	545	0.0	7.1	-7.1
5	765 kV	GAYA-BALIA	1	62	463	0.0	5.5	-5.5
6	400 kV	PUSAULI-VARANASI	1	0	135	0.0	2.3	-2.3
7	400 kV	PUSAULI -ALLAHABAD	1	43	39	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	409	339	0.0	0.3	-0.3
9	400 kV	PATNA-BALIA	2	68	691	0.0	9.9	-9.9
10	400 kV	NAUBATPUR-BALIA	2	44	308	0.0	2.9	-2.9
11	400 kV	BIHARSHARIFF-BALIA	2	296	157	1.0	0.0	1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	102	331	0.0	3.8	-3.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	3.5	-3.5
14	220 kV	SAHUPURI-KARAMNASA	1	0	55	0.0	0.3	-0.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
					ER-NR	**1.9**	**48.0**	**-46.1**
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	800	453	7.1	0.0	7.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	351	1234	0.0	13.1	-13.1
3	765 kV	JHARSUGUDA-DURG	2	0	793	0.0	14.8	-14.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	785	0.0	12.2	-12.2
5	400 kV	RANCHI-SIPAT	2	28	476	0.0	5.8	-5.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	99	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	115	73	0.0	0.3	-0.3
					ER-WR	**7.1**	**47.6**	**-40.5**
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	312	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1809	0.0	71.3	-71.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	3080	0.0	57.1	-57.1
4	400 kV	TALCHER-I/C	2	0	142	0.0	32.6	-32.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
					ER-SR	**0.0**	**135.8**	**-135.8**
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	272	21	2.2	0.0	2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	455	0	4.6	0.0	4.6
3	220 kV	ALIPURDUAR-SALAKATI	2	92	0	1.3	0.0	1.3
					ER-NER	**8.1**	**0.0**	**8.1**
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	660	0	15.7	0.0	15.7
					NER-NR	**15.7**	**0.0**	**15.7**
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1970	0.0	30.2	-30.2
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.3	-1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	983	0.0	17.6	-17.6
4	765 kV	GWALIOR-AGRA	2	1182	874	8.7	2.5	6.2
5	765 kV	GWALIOR-PHAGI	2	1199	1133	5.8	11.1	-5.3
6	765 kV	JABALPUR-ORAI	2	531	631	0.0	0.9	-0.9
7	765 kV	GWALIOR-ORAI	1	647	0	10.7	0.0	10.7
8	765 kV	SATNA-ORAI	1	0	839	0.0	10.2	-10.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1657	0	20.9	0.0	20.9
10	765 kV	VINDHYACHAL-VARANASI	2	340	1417	0.0	11.3	-11.3
11	400 kV	ZERDA-KANKROLI	1	309	0	4.3	0.0	4.3
12	400 kV	ZERDA -BHINMAL	1	214	0	3.0	0.0	3.0
13	400 kV	VINDHYACHAL -RIHAND	1	487	0	10.4	0.0	10.4
14	400 kV	RAPP-SHUJALPUR	2	811	88	8.5	0.1	8.4
15	400 kV	NEEMUCH-Chittorgarh	2	853	47	9.2	0.0	9.2
16	220 kV	BHANPURA-RANPUR	1	0	167	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	156	0	2.5	0.0	2.5
19	220 kV	MALANPUR-AURAIYA	1	116	0	1.8	0.0	1.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	**85.7**	**90.5**	**-4.8**
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4511	0.0	87.0	-87.0
3	765 kV	SOLAPUR-RAICHUR	2	614	1713	1.8	14.9	-13.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2937	0.0	46.6	-46.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2887	0.0	47.0	-47.0
6	400 kV	KOLHAPUR-KUDGI	2	1223	0	17.6	0.0	17.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	115	2.0	0.0	2.0
					WR-SR	**21.4**	**219.3**	**-197.9**

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	180	-31	71	1.70
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-275	51	-109	-2.62
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-262	-133	-184	-4.42
	NER	132kV GELEPHU-SALAKATI	-21	0	-15	-0.37
	NER	132kV MOTANGA-RANGIA	15	-3	7	0.17
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-38	-0.92
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-40	-0.97
	ER	NEPAL IMPORT (FROM BIHAR)	-184	-117	-158	-3.80
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-478	35	-243	-5.82
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-950	-894	-934	-22.43
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1372	-507	-798	-19.16
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-92	0	-75	-1.80

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 03-Mar-2025**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.38	7.01	0.00	0.00	0.00	0.00	0.00	7.39
Nepal	4.19	0.00	4.00	0.00	0.00	2.36	0.00	0.00	10.55
Bangladesh	23.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.54	0.38	11.01	0.00	0.00	2.36	0.00	0.00	41.29

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.37
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.37

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.37	-0.38	-7.01	0.00	0.00	0.00	0.00	0.00	-6.02
Nepal	-4.19	0.00	-4.00	0.00	0.00	-2.36	0.00	0.00	-10.55
Bangladesh	-23.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.17	-0.38	-11.01	0.00	0.00	-2.36	0.00	0.00	-39.92

Date of Reporting: 03-Mar-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.09	174344	6181	9628	96	10344	2107	146272	2779	164620	177407	-1756
0:15	49.94	174746	6155	9576	99	9989	1977	147019	2739	165071	177554	-1685
0:30	49.94	173980	6161	9467	95	9581	2078	146617	2722	164418	176721	-1639
0:45	49.89	174025	6158	9372	93	9256	2090	147017	2711	164560	176697	-1687
1:00	49.99	173472	6163	9410	91	9189	2081	146610	2734	163971	176278	-1584
1:15	49.94	172602	6186	9233	88	8756	2075	146004	2691	163281	175033	-1499
1:30	49.99	171545	6183	9161	93	8417	1989	145650	2680	162291	174173	-1488
1:45	50.04	171583	6186	9195	95	8249	2074	145666	2773	162293	174238	-1567
2:00	50.04	170230	6183	9253	101	7976	1978	144696	2718	160876	172905	-1576
2:15	49.99	169416	6157	9354	106	7793	2075	143903	2736	159956	172124	-1607
2:30	49.99	169020	6163	9401	111	7611	1994	143839	2774	159508	171893	-1609
2:45	49.99	168902	6168	9445	111	7372	2098	143812	2738	159346	171744	-1532
3:00	49.94	168465	6161	9369	109	7362	1985	143591	2710	158987	171287	-1554
3:15	49.89	168761	6160	9486	106	7263	2179	143869	2764	159169	171827	-1550
3:30	49.94	168845	6173	9525	100	6972	2136	144182	2674	159220	171762	-1560
3:45	49.89	169526	6157	9646	104	6973	2140	144708	2714	159776	172442	-1574
4:00	49.99	169719	6167	9685	108	7346	1968	144396	2777	159926	172447	-1587
4:15	49.94	172091	6170	9445	104	8275	1968	146133	2774	162542	174869	-1588
4:30	50.04	173609	6171	9306	103	9182	2176	146787	2807	164200	176532	-1557
4:45	50.04	174181	6184	9003	96	9098	2163	147720	2797	165082	177061	-1579
5:00	50.04	174653	6185	8592	89	9510	2161	148339	2835	165972	177711	-1546
5:15	49.99	176514	6172	8321	90	10185	1954	149583	2855	168103	179160	-1414
5:30	50.04	178338	6173	8022	94	10476	1959	151265	2815	170222	180804	-1264
5:45	50.03	179992	6184	7801	94	11307	1946	152286	2819	172097	182437	-1277
6:00	50.08	180218	6187	7658	100	11719	1955	152394	2835	172460	182848	-1289
6:15	50.03	182543	6184	7532	195	13200	1956	153231	2808	174816	185106	-1333
6:30	50.08	186704	6186	7486	235	16357	1959	154392	2859	178983	189474	-1333
6:45	50.03	189214	6198	7348	341	18507	1954	154652	2849	181525	191849	-1313
7:00	50.03	190741	6193	7150	829	18512	1952	155974	2825	182762	193435	-1371
7:15	50.03	192669	6194	6933	2052	18990	1956	155857	2879	183684	194861	-1249
7:30	50.03	193889	6203	6795	4373	19142	1959	154974	2885	182721	196331	-1256
7:45	50.09	196337	6200	6437	8428	18953	1959	153581	2956	181472	198514	-1241
8:00	50.14	197505	6118	6373	13045	17643	2055	151099	3011	178087	199344	-1259
8:15	50.03	200870	6183	5916	18243	16139	1942	150808	2997	176711	202228	-1234
8:30	50.03	202462	6195	5157	23635	14477	1958	149359	3038	173670	203819	-1244
8:45	50.07	205353	6198	4133	29152	13501	1948	147678	3014	172068	205624	-1240
9:00	50.12	206463	6192	3403	34456	12605	1935	147986	2994	168604	209571	-1262
9:15	49.97	210392	6189	2914	39556	11669	1968	148441	3024	167922	213761	-1577
9:30	50.02	211231	6195	2736	43786	10882	1890	146454	3039	164709	214982	-1454
9:45	50.02	212253	6190	2640	47058	9662	1898	145241	3015	162555	215704	-1488
10:00	50.12	211985	6204	2442	50867	9000	1895	142316	3109	158676	215833	-1637
10:15	50.01	212285	6234	2401	53538	8267	1892	140448	3046	156346	215826	-1602
10:30	50.01	212643	6218	2238	56323	8026	1889	138864	3062	154082	216620	-1837
10:45	49.96	211935	6207	2059	58005	7890	1967	137044	3041	151871	216213	-1939
11:00	50.01	211499	6199	1950	59491	8062	1893	134796	3067	150058	215458	-2127
11:15	49.96	210713	6214	1938	60828	7479	1880	133503	3039	147947	214881	-2129
11:30	49.96	209478	6200	1988	61182	7535	1869	132031	3043	146308	213848	-2107
11:45	49.96	208353	6189	2145	61854	7612	1880	130153	3041	144354	212874	-2127
12:00	50.01	205997	6189	2193	62222	7569	1868	127384	2966	141582	210391	-2200
12:15	49.96	205343	6182	2245	62640	6560	1869	126921	2997	140458	209414	-2212
12:30	50.01	205404	6177	2239	62713	6729	1859	126920	2970	140452	209607	-2172
12:45	50.01	203745	6169	2280	62949	6349	1862	125745	2984	138516	208338	-2120
13:00	50.06	202272	6163	2336	62947	6342	1872	124178	3036	136989	206874	-2150
13:15	50.01	200059	6159	2372	62574	6089	1868	122509	2998	135113	204569	-2147
13:30	50.06	198825	6152	2441	62576	5875	1870	121310	3037	133808	203261	-2131
13:45	50.06	199384	6142	2522	62421	6441	1866	121235	3053	134441	203680	-2094
14:00	50.06	198647	6142	2604	62001	6677	1878	121003	2981	134042	203286	-2131
14:15	49.96	198249	6147	2740	60602	6925	1870	121212	2953	134907	202449	-2137
14:30	49.96	198961	6133	2740	59410	7201	1872	123371	3017	136811	203744	-2159
14:45	49.91	199777	6166	2693	57662	7498	1866	125191	2909	139422	203985	-2167
15:00	49.96	199217	6150	2649	55660	7878	1879	126917	2863	140908	203996	-2132
15:15	49.91	198392	6157	2650	53555	7192	1893	128518	2861	142187	202826	-2140
15:30	49.91	197833	6133	2698	50821	7679	1891	130688	2854	144314	202764	-2156
15:45	49.91	197477	6156	2626	47504	8180	1902	133121	2763	147347	202252	-2124
16:00	50.01	197169	6094	2552	44197	8890	1922	135659	2746	150420	202060	-2098
16:15	49.96	194376	6159	2631	40465	8465	1943	136843	2715	151280	199221	-2022
16:30	49.91	193569	6179	2670	36255	9093	1945	139956	2770	154644	198868	-1997
16:45	49.91	192690	6186	2680	31187	9831	1913	143158	2752	158823	197707	-1785
17:00	50.00	191630	6174	2766	26108	11020	1906	145725	2733	162756	196432	-1447
17:15	50.00	188733	6187	2806	20850	12309	1910	146127	2647	165077	192836	-977
17:30	50.10	187439	6192	2766	15381	15279	1914	148012	2647	169292	192191	-1093
17:45	50.00	187061	6208	2852	10423	17290	1926	149739	2682	173786	191120	-789
18:00	50.10	186360	6203	2845	6162	18049	1927	153014	2651	177353	190851	-1047
18:15	50.00	186218	6246	3159	3041	17525	1927	156116	2765	180018	190779	-974
18:30	50.05	188826	6267	3348	1404	18536	1925	159121	2690	184074	193291	-997
18:45	49.95	191597	6263	3576	806	18709	1936	161936	2766	187215	195992	-1012
19:00	50.00	193279	6263	3675	695	19496	1948	163108	2766	188909	197951	-972
19:15	50.05	193257	6275	3723	714	18786	1935	163181	2794	188820	197408	-980
19:30	50.00	191325	6271	3633	674	17567	1934	163251	2788	187018	196118	-963
19:45	50.00	190059	6261	3618	679	16092	1954	162786	2790	185762	194180	-957
20:00	50.05	187130	6256	3709	613	14696	1940	161700	2807	182808	191721	-1003
20:15	50.05	185142	6240	3783	135	13814	1950	160482	2782	181224	189186	-1078
20:30	50.00	183006	6250	3969	141	12435	1946	159645	2796	178896	187182	-1083
20:45	49.95	181185	6238	4055	144	11224	1967	158638	2794	176986	185060	-1085
21:00	50.05	179162	6233	4081	138	10836	1946	157343	2798	174943	183375	-1129
21:15	50.00	178318	6185	4208	111	10195	1966	157170	2811	173999	182646	-1527
21:30	50.05	177256	6177	4539	104	10065	1977	156309	2737	172613	181908	-1611
21:45	50.05	176628	6174	4651	102	9932	1984	155744	2766	171875	181353	-1871
22:00	50.05	174465	6186	4835	99	9513	1974	154213	2760	169531	179580	-1882
22:15	50.00	176865	6171	5011	92	9962	1983	155611	2772	171762	181602	-1822
22:30	50.00	176674	6197	5047	90	9837	1978	155645	2801	171537	181595	-1824
22:45	50.05	175687	6188	5281	88	10011	1988	154167	2753	170318	180476	-1798
23:00	50.00	174469	6173	5375	88	9857	1975	153128	2769	169006	179365	-1810
23:15	50.00	173127	6179	5461	86	9575	1980	151845	2750	167580	177876	-1859
23:30	50.00	172056	6178	5544	85	9560	1990	151038	2711	166427	177106	-1819
23:45	50.00	171648	6181	5435	81	9392	1983	150695	2707	166132	176474	-1801

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
** Hydro generation is excluding Bhutan hydro.
***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.