



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-फरवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60254	66697	52233	24183	2830	206197
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1257	1574	1283	503	53	4669
Hydro Gen (MU)	108	42	79	24	13	265
Wind Gen (MU)	29	162	122	-	-	313
Solar Gen (MU)*	213.56	159.89	165.36	3.35	1.26	543
Energy Shortage (MU)	0.03	0.00	0.00	0.00	0.00	0.03
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65562	80194	64610	24871	2980	234928
Time Of Maximum Demand Met	09:46	09:57	09:28	18:12	17:48	09:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.00	0.00	3.97	3.97	73.93	22.10

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8876	0	168.2	70.8	-1.1	450	0.00
	Haryana	8477	0	167.0	119.0	-1.1	206	0.00
	Rajasthan	18302	0	329.8	103.8	-8.2	825	0.00
	Delhi	5044	0	86.6	78.9	-1.2	464	0.00
	UP	19296	0	345.8	65.3	-2.6	474	0.00
	Uttarakhand	2539	0	45.4	38.0	0.0	80	0.00
	HP	2227	0	42.9	33.1	-0.3	144	0.00
	J&K(UT) & Ladakh(UT)	2980	0	63.2	58.4	-0.5	448	0.03
	Chandigarh	274	0	4.3	4.2	0.0	14	0.00
	Railways_NR ISTS	218	0	4.1	3.8	0.2	53	0.00
WR	Chhattisgarh	6009	0	125.1	67.3	2.2	330	0.00
	Gujarat	23797	0	438.7	192.5	-4.1	634	0.00
	MP	17259	0	307.1	185.2	0.0	363	0.00
	Maharashtra	30014	0	619.6	209.3	-7.6	1369	0.00
	Goa	753	0	15.1	12.5	2.2	34	0.00
	DNHDDPDCL	1387	0	31.7	31.4	0.3	54	0.00
	AMNSIL	805	0	17.1	13.0	0.2	247	0.00
	BALCO	601	0	14.4	14.5	-0.1	35	0.00
	RIL JAMNAGAR	234	0	5.6	5.6	0.0	0	0.00
	Andhra Pradesh	12702	0	234.7	71.0	-0.3	650	0.00
SR	Telangana	15859	0	281.6	140.5	-2.7	490	0.00
	Karnataka	17247	0	316.8	119.6	-0.9	932	0.00
	Kerala	4769	0	90.6	70.1	1.6	554	0.00
	Tamil Nadu	17651	0	350.0	185.3	-3.5	680	0.00
	Puducherry	415	0	8.9	8.6	-0.2	27	0.00
	Bihar	5829	0	104.9	87.6	-3.9	141	0.00
ER	DVC	3171	0	70.2	-27.3	1.2	367	0.00
	Jharkhand	2197	0	39.1	28.9	-0.9	189	0.00
	Odisha	5621	0	112.3	28.9	-2.5	483	0.00
	West Bengal	8295	0	174.2	62.3	-2.4	243	0.00
	Sikkim	107	0	1.8	1.9	-0.1	17	0.00
	Railways_ER ISTS	31	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	181	0	3.0	3.1	-0.2	30	0.00
	Assam	1659	0	30.6	24.0	0.4	74	0.00
	Manipur	265	0	3.8	4.0	-0.2	28	0.00
	Meghalaya	388	0	6.6	5.8	0.0	58	0.00
	Mizoram	134	0	2.1	2.1	-0.2	12	0.00
	Nagaland	161	0	2.6	2.7	-0.1	3	0.00
	Tripura	241	0	4.0	5.0	-0.1	37	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-15.0	-9.9	-24.3	-13.5
Day Peak (MW)	-1046.6	-704.6	-1029.5	-766.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	170.0	-238.0	168.8	-113.0	12.2	0.0
Actual(MU)	162.9	-224.6	148.7	-109.5	11.0	-11.6
O/D/U/D(MU)	-7.1	13.4	-20.1	3.4	-1.2	-11.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5850	10590	4368	3295	435	24538	44
State Sector	8114	13081	6526	3225	205	31151	56
Total	13964	23671	10894	6520	640	55688	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	735	1464	689	689	12	3588	70
Lignite	26	15	48	0	0	89	2
Hydro	108	42	79	24	13	265	5
Nuclear	42	62	71	0	0	175	3
Gas, Naptha & Diesel	10	19	8	0	22	59	1
RES (Wind, Solar, Biomass & Others)	268	325	322	7	1	923	18
Total	1188	1927	1218	719	48	5099	100

Share of RES in total generation (%)	22.53	16.88	26.46	0.92	2.65	18.10
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.12	22.27	38.77	4.26	29.68	26.73

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.047

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	234928	9:45	0
Non-Solar hr	211947	18:51	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 05-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	580	1337	0.0	13.5	-13.5
4	765 kV	SASARAM-FATEHPUR	1	204	612	0.0	6.4	-6.4
5	765 kV	GAYA-BALIA	1	0	885	0.0	10.9	-10.9
6	400 kV	PUSAULI-VARANASI	1	1	117	0.0	1.3	-1.3
7	400 kV	PUSAULI-ALLAHABAD	1	23	99	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	633	574	0.0	0.2	-0.2
9	400 kV	PATNA-BALIA	2	103	945	0.0	11.1	-11.1
10	400 kV	NAUBATPUR-BALIA	2	197	199	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	497	176	3.2	0.0	3.2
12	400 kV	MOTIHARI-GORAKHPUR	2	130	546	0.0	5.4	-5.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	227	482	0.0	3.8	-3.8
14	220 kV	SAHUPURI-KARAMNANA	1	24	14	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						3.9	61.0	-57.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	550	692	0.0	1.7	-1.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1177	710	7.7	0.0	7.7
3	765 kV	JHARSUGUDA-DURG	2	0	1256	0.0	21.5	-21.5
4	400 kV	JHARSUGUDA-RAIGARH	4	240	551	0.0	3.5	-3.5
5	400 kV	RANCHI-SIPAT	2	227	262	0.0	0.1	-0.1
6	400 kV	JEYPORE-JAGDALPUR	2	371	148	3.3	0.0	3.3
7	220 kV	BUDHIPADAR-RAIGARH	1	0	152	0.0	2.3	-2.3
8	220 kV	BUDHIPADAR-KORBA	2	72	133	0.0	0.9	-0.9
ER-WR						11.0	29.9	-18.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	524	0.0	12.4	-12.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1431	0.0	38.6	-38.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	1851	0.0	30.6	-30.6
4	400 kV	TALCHER-I/C	2	284	591	2.3	0.0	2.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	81.6	-81.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	169	197	0.6	1.1	-0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	325	101	3.4	0.0	3.4
3	220 kV	ALIPURDUAR-SALAKATI	2	37	46	0.1	0.0	0.1
ER-NER						4.1	1.1	3.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	948	0	15.8	0.0	15.8
NER-NR						15.8	0.0	15.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2008	0.0	38.8	-38.8
2	HVDC	VINDHYACHAL B/B	-	0	253	0.0	6.0	-6.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	792	0.0	19.5	-19.5
4	765 kV	GWALIOR-AGRA	2	399	2281	0.7	20.3	-19.6
5	765 kV	GWALIOR-PHAGI	2	888	2128	2.6	24.4	-21.9
6	765 kV	JABALPUR-ORAI	2	259	1178	0.0	20.9	-20.9
7	765 kV	GWALIOR-ORAI	1	906	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	1182	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1870	440	14.6	0.5	14.1
10	765 kV	VINDHYACHAL VARANASI	2	0	2278	0.0	30.3	-30.3
11	400 kV	ZERDA-KANKROLI	1	320	0	3.5	0.0	3.5
12	400 kV	ZERDA BHINMAL	1	220	0	2.4	0.0	2.4
13	400 kV	VINDHYACHAL -RIHAND	1	489	0	10.1	0.0	10.1
14	400 kV	RAPP-SHUJALPUR	2	851	368	6.2	1.3	4.9
15	400 kV	NEEMUCH-Chittorgarh	2	802	538	5.2	2.6	2.7
16	220 kV	BHANPURA-RANPUR	1	0	118	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	87	25	0.7	0.1	0.7
19	220 kV	MALANPUR-AURAIYA	1	60	35	0.5	0.1	0.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						60.5	187.1	-126.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1004	0.0	21.2	-21.2
2	HVDC	RAIGARH-PUGALUR	2	0	4012	0.0	63.9	-63.9
3	765 kV	SOLAPUR-RAICHUR	2	1843	1389	11.8	6.7	5.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2731	0.0	32.6	-32.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2950	0.0	38.3	-38.3
6	400 kV	KOLHAPUR-KUDGI	2	2128	0	32.1	0.0	32.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.3	0.0	2.3
WR-SR						46.1	162.7	-116.7

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-339	8	-217	-5.20
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-390	109	-173	-4.14
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-203	-89	-166	-3.98
	NER	132kV GELEPHU-SALAKATI	-75	-5	-49	-1.17
	NER	132kV MOTANGA-RANGIA	-29	-4	-20	-0.48
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-35	-0.83
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-48	-1.16
	ER	NEPAL IMPORT (FROM BIHAR)	-132	-66	-98	-2.36
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-463	-110	-231	-5.54
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-918	-913	-915	-21.96
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-414	-562	-13.48
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-116	0	-95	-2.29

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Feb-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.36	19.21	0.00	0.00	0.00	0.00	0.00	19.57	
Nepal	2.47	1.54	1.46	0.00	0.00	0.00	3.19	0.00	0.00	8.66
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.42	1.90	20.67	0.00	0.00	0.00	3.19	0.00	0.00	51.18

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-19.21	0.00	0.00	0.00	0.00	0.00	-19.23
Nepal	-2.47	-1.54	-1.46	0.00	0.00	-3.19	0.00	0.00	-8.66
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.08	-1.90	-20.67	0.00	0.00	-3.19	0.00	0.00	-50.84

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.03	161683	6645	13326	0	6252	2230	134620	4340	148357	167413	-2156
0:15	49.97	161878	6646	13408	0	6130	2219	134998	4260	148470	167661	-2155
0:30	49.92	161860	6659	13471	0	6169	2232	134805	4222	148389	167558	-2100
0:45	49.98	161658	6666	13336	0	5837	2226	135140	4201	148322	167406	-2112
1:00	49.99	160698	6656	13275	0	5833	2218	134054	4233	147423	166269	-2140
1:15	49.93	159629	6649	13284	0	5740	2226	133128	4228	146345	165255	-2154
1:30	49.98	159388	6655	12991	0	5954	2224	132786	4212	146397	164822	-2181
1:45	49.97	158859	6650	12904	0	6057	2228	132463	4246	145955	164548	-2156
2:00	50.01	157549	6646	13010	0	5689	2227	131388	4167	144539	163127	-2151
2:15	49.99	157222	6656	13114	0	5386	2231	131032	4199	144108	162618	-2151
2:30	50.01	157134	6647	13354	0	5619	2231	130518	4179	143780	162548	-2167
2:45	49.97	157107	6660	13342	0	5556	2237	130346	4184	143765	162325	-2169
3:00	50.03	157151	6654	13372	0	5380	2235	130630	4156	143779	162427	-2153
3:15	49.99	157529	6662	13790	0	5320	2240	130684	4193	143739	162889	-2146
3:30	49.98	157362	6673	13717	0	5512	2239	130285	4167	143645	162593	-2147
3:45	49.97	157718	6653	13965	0	5651	2231	129931	4132	143753	162563	-2173
4:00	50.03	158421	6641	14224	0	5791	2227	130477	4129	144197	163489	-2166
4:15	50.00	160868	6655	14648	0	6127	2224	131903	4130	146220	165687	-2187
4:30	50.04	162265	6639	14658	0	6491	2231	133111	4111	147607	167241	-2209
4:45	49.95	164216	6671	14615	0	6764	2227	134872	4130	149601	169279	-2169
5:00	50.11	166262	6650	14571	148	7201	2214	136783	4060	151543	171627	-2257
5:15	50.09	169982	6621	14527	126	7361	2228	140675	4143	155329	175681	-2314
5:30	49.99	173570	6641	14375	130	7577	2236	143929	4198	159065	179086	-2320
5:45	50.01	178529	6651	14167	134	8646	2219	147761	4155	164228	183733	-2343
6:00	50.06	182717	6649	13929	167	9790	2233	150843	4180	168621	187791	-2317
6:15	49.97	188893	6626	13956	393	10516	2249	156112	4156	174544	194008	-2351
6:30	50.04	196075	6620	13804	402	12298	2258	161510	4193	181869	201085	-2207
6:45	50.04	204227	6655	13873	408	16113	2249	165148	4181	189946	208627	-1832
7:00	50.07	210123	6636	13977	654	19373	2264	167228	4213	195492	214345	-1336
7:15	49.97	215970	6646	13961	1389	22804	2322	168210	4170	200620	219502	-1284
7:30	50.04	219160	6646	13650	2785	24286	2358	168969	4167	202725	222861	-1317
7:45	50.05	221879	6653	13180	5713	24602	2409	168391	4218	202986	225166	-1215
8:00	50.09	221514	6652	12599	9942	22491	2395	166635	4244	198973	224958	-1341
8:15	50.05	224998	6671	11887	15643	21593	2396	165057	4240	197468	227487	-1350
8:30	50.12	228057	6661	11453	22368	20614	2347	163246	4260	194236	230949	-1362
8:45	50.12	228442	6660	11152	29652	16624	2326	160513	4211	187638	231138	-1377
9:00	50.27	229161	6649	10733	36627	13918	2258	157983	4175	181801	232343	-1854
9:15	50.02	232587	6643	10365	43429	11862	2249	157288	4170	178793	236006	-2336
9:30	50.02	234029	6647	9626	49251	10786	2239	155087	4141	175152	237777	-2419
9:45	50.04	234928	6638	9069	54123	10173	2249	152655	4003	171736	238910	-2460
10:00	50.12	234059	6639	8809	58188	9111	2250	149343	4051	167062	238391	-2444
10:15	50.11	233567	6637	8696	61802	8226	2118	146457	3999	163069	237935	-2410
10:30	50.11	233020	6624	8630	65371	7601	2255	142561	3992	159019	237034	-2454
10:45	49.88	230108	6629	8566	65570	6854	2257	140651	3985	155972	234512	-2648
11:00	49.95	228375	6622	8517	68245	6374	2250	136654	3944	151613	232606	-2642
11:15	49.84	225794	6589	8114	69994	5997	2244	132581	3949	147686	229468	-2612
11:30	49.90	222460	6586	8030	71638	5705	2256	128271	3990	142792	226476	-2647
11:45	49.97	220694	6636	7837	72803	5681	2248	126172	3902	140054	225279	-2535
12:00	49.98	219037	6636	7800	73396	5881	2239	123468	3954	137841	223374	-2497
12:15	49.98	216503	6631	7922	74294	6160	2216	119529	3939	134287	220691	-2506
12:30	49.97	216140	6621	8177	73931	6381	2216	119211	3942	134032	220479	-2485
12:45	49.97	215646	6623	8377	74031	6303	2219	118187	4025	133238	219765	-2493
13:00	50.12	212584	6596	8265	73981	6133	2226	115594	3941	130338	216736	-2503
13:15	50.11	208886	6616	8340	73799	5968	2090	112145	4013	126747	212971	-2405
13:30	50.10	206893	6630	8385	73252	5956	2222	110689	3939	125256	211073	-2480
13:45	49.97	206760	6601	8517	72780	5569	2226	111471	3942	125463	211106	-2503
14:00	50.06	206942	6619	8576	72097	5508	2214	112498	3929	126269	211441	-2503
14:15	49.99	206996	6603	8508	71230	5385	2214	113521	3975	127258	211436	-2537
14:30	50.05	208810	6599	8523	69151	5894	2216	117083	3988	131136	213454	-2564
14:45	49.98	208483	6608	8439	66832	5698	2082	118816	3950	133212	212425	-2434
15:00	50.12	208744	6594	8393	64823	5956	2084	121358	3981	135528	213189	-2446
15:15	50.05	207598	6589	8416	61856	5885	2083	123021	4010	137326	211860	-2468
15:30	50.07	207240	6605	8445	58318	6733	2102	125835	4034	140477	212072	-2499
15:45	50.09	207774	6608	8497	55234	7218	2086	128687	4016	144043	212346	-2515
16:00	50.11	208742	6601	8738	50967	8106	2090	132416	4036	149037	212954	-2510
16:15	50.01	206821	6612	8997	46522	7783	2087	134267	4033	151302	210301	-2506
16:30	50.07	207733	6582	9248	41465	9181	2079	138897	3999	157020	211451	-2478
16:45	50.02	206548	6596	9053	35465	10598	2099	142246	4022	162030	210079	-2405
17:00	50.05	205726	6586	9496	29025	12391	2133	145949	4078	167205	209658	-2407
17:15	50.02	204587	6588	10007	22070	14342	2153	148788	4102	172510	208050	-2380
17:30	50.05	205783	6590	10107	15378	16202	2194	154946	4071	180298	209488	-2279
17:45	50.03	209090	6585	10438	9744	18035	2176	161528	4130	188908	212636	-2026
18:00	50.08	213033	6599	10817	5118	20261	2323	164060	4162	194368	213340	-1222
18:15	49.96	208928	6620	11192	2182	21375	2379	164030	4217	195554	211995	-1256
18:30	49.89	210644	6598	11053	1169	21658	2450	167331	4182	198422	214441	-1250
18:45	49.90	210854	6585	11479	807	22287	2494	167043	4180	198568	214875	-1249
19:00	50.05	211168	6609	12010	719	22108	2470	166838	4283	198439	215037	-1211
19:15	50.06	209532	6611	12748	698	20891	2475	165528	4241	196086	213192	-1195
19:30	49.97	206709	6619	13292	0	17428	2487	165331	4253	193417	209410	-1189
19:45	50.03	203770	6609	13942	0	16290	2464	162904	4266	189828	206475	-1238
20:00	50.05	200495	6606	14444	0	15290	2236	160216	4316	186051	203108	-1343
20:15	50.03	196566	6618	15200	0	14264	2154	158026	4336	181366	200598	-1708
20:30	50.04	193954	6625	15567	0	13737	2148	156290	4317	178387	198684	-2233
20:45	50.00	191497	6628	16069	0	12709	2141	154651	4290	175428	196488	-2221
21:00	50.06	188492	6633	16178	0	11752	2133	152446	4348	172314	193490	-2216
21:15	50.02	185667	6621	16482	0	10834	2148	150400	4308	169185	190793	-2199
21:30	49.98	183166	6638	16531	0	9898	2158	148784	4314	166635	188323	-2226
21:45	49.98	180456	6637	16631	0	8999	2156	146909	4313	163825	185645	-2278
22:00	50.05	176501	6622	16494	0	8111	2154	144183	4267	160007	181831	-2273
22:15	50.01	176756	6630	16514	0	8372	2205	144616	4208	160242	182545	-2269
22:30	49.94	174801	6623	16423	0	8061						