



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 18.07.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.07.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 17-जुलाई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17.07.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 18-Jul-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79351	58317	43553	25576	3513	210310
Peak Shortage (MW)	1290	0	0	0	0	1290
Energy Met (MU)	1871	1375	1061	609	71	4987
Hydro Gen (MU)	390	49	110	80	36	665
Wind Gen (MU)	15	79	288	-	-	383
Solar Gen (MU)*	143.14	69.46	85.22	2.87	1.08	302
Energy Shortage (MU)	9.03	0.00	0.00	0.00	0.00	9.03
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	82919	59151	50712	29858	3669	219587
Time Of Maximum Demand Met	11:50	11:35	09:43	23:24	19:19	11:32

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.00	7.11	7.11	83.90	8.99

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15833	0	358.9	213.8	-0.4	273	0.00
	Haryana	12138	0	275.5	204.7	-4.0	203	0.00
	Rajasthan	15405	0	325.4	120.8	5.6	1168	7.91
	Delhi	7267	0	151.7	137.8	0.8	435	0.00
	UP	28992	0	600.5	304.1	0.1	373	0.00
	Uttarakhand	2288	0	51.7	26.3	-0.4	102	0.91
	HP	1854	0	39.1	2.0	2.4	184	0.00
	J&K(UT) & Ladakh(UT)	2618	0	56.1	31.7	-1.4	217	0.21
	Chandigarh	354	0	7.6	7.8	-0.2	12	0.00
WR	Railways_NR ISTS	217	0	4.3	3.5	0.8	117	0.00
	Chhattisgarh	5499	0	126.9	77.1	-1.4	184	0.00
	Gujarat	17951	0	393.8	142.1	-2.0	809	0.00
	MP	12204	0	273.1	149.5	-3.5	314	0.00
	Maharashtra	22800	0	507.4	161.0	-1.0	688	0.00
	Goa	644	0	13.5	12.4	0.9	80	0.00
	DNHDDPDCL	1274	0	29.7	29.8	-0.1	37	0.00
	AMNSIL	830	0	18.4	6.6	0.2	274	0.00
	BALCO	526	0	12.5	12.4	0.1	41	0.00
SR	Andhra Pradesh	9412	0	202.1	20.7	-2.1	621	0.00
	Telangana	11764	0	232.8	140.7	0.6	629	0.00
	Karnataka	11283	0	204.1	5.4	-3.5	582	0.00
	Kerala	3577	0	73.6	41.4	0.7	297	0.00
	Tamil Nadu	15967	0	337.9	118.1	-6.0	686	0.00
	Puducherry	443	0	10.1	9.4	0.1	55	0.00
	Railways_SR ISTS	16	0	0.1	0.1	0.0	1	0.00
ER	Bihar	7000	0	143.6	133.7	-1.4	410	0.00
	DVC	3359	0	70.5	-41.8	0.0	400	0.00
	Jharkhand	1989	0	38.6	27.6	-1.1	281	0.00
	Odisha	5800	0	122.2	38.7	-2.3	397	0.00
	West Bengal	11065	0	232.6	91.3	-1.4	222	0.00
	Sikkim	85	0	1.3	1.3	0.0	39	0.00
	Railways_ER ISTS	16	0	0.1	0.1	0.0	1	0.00
NER	Arunachal Pradesh	162	0	3.0	2.7	-0.1	30	0.00
	Assam	2384	0	47.0	38.6	0.2	159	0.00
	Manipur	208	0	3.1	3.0	0.1	41	0.00
	Meghalaya	308	0	5.6	-0.8	-0.1	85	0.00
	Mizoram	120	0	1.5	0.6	-0.6	18	0.00
	Nagaland	176	0	3.2	2.8	-0.1	23	0.00
	Tripura	460	0	7.7	5.7	1.5	98	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	42.7	16.7	-24.5	-27.3
Day Peak (MW)	2049.0	797.9	-1035.0	-1147.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	463.9	-276.5	-84.3	-107.4	4.3	0.0
Actual(MU)	479.3	-281.2	-92.8	-117.8	2.9	-9.7
O/D/U/D(MU)	15.5	-4.8	-8.5	-10.4	-1.5	-9.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3561	13359	6938	4876	694	29427	55
State Sector	5256	9744	7293	1574	233	24099	45
Total	8816	23103	14231	6450	926	53526	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	859	1463	584	709	16	3630	68
Lignite	29	15	50	0	0	95	2
Hydro	390	49	110	80	36	665	12
Nuclear	29	57	76	0	0	163	3
Gas, Naptha & Diesel	21	40	5	0	22	87	2
RES (Wind, Solar, Biomass & Others)	166	150	397	5	1	719	13
Total	1495	1774	1222	794	74	5359	100

Share of RES in total generation (%)	11.09	8.43	32.51	0.61	1.46	13.41
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.16	14.42	47.71	10.73	49.65	28.86

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.030
Based on State Max Demands	1.066

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	219587	11:32	0
Non-Solar hr	212585	22:23	1427

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 18-Jul-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	351	0.0	8.4	-8.4
2	HVDC	PUSAULI B/B	-	0	97	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	123	997	0.0	11.7	-11.7
4	765 kV	SASARAM-FATEHPUR	1	19	561	0.0	6.6	-6.6
5	765 kV	GAYA-BALIA	1	0	745	0.0	13.2	-13.2
6	400 kV	PUSAULI-VARANASI	1	26	50	0.0	0.3	-0.3
7	400 kV	PUSAULI -ALLAHABAD	1	0	122	0.0	2.1	-2.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	872	0.0	14.5	-14.5
9	400 kV	PATNA-BALIA	2	0	695	0.0	12.2	-12.2
10	400 kV	NAUBATPUR-BALIA	2	0	202	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	203	178	0.0	0.6	-0.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	604	0.0	9.1	-9.1
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	23	77	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	84.7	-84.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1796	0.0	30.0	-30.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2236	0	33.7	0.0	33.7
3	765 kV	JHARSUGUDA-DURG	2	0	541	0.0	7.5	-7.5
4	400 kV	JHARSUGUDA-RAIGARH	4	162	373	0.0	2.1	-2.1
5	400 kV	RANCHI-SIPAT	2	498	0	7.4	0.0	7.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	144	0.0	2.6	-2.6
7	220 kV	BUDHIPADAR-KORBA	2	0	110	0.0	1.8	-1.8
ER-WR						41.0	44.0	-2.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	749	0	17.9	0.0	17.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1243	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1758	0.0	28.3	-28.3
4	400 kV	TALCHER-I/C	2	182	0	2.7	0.0	2.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						17.9	58.5	-40.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	425	0.0	5.5	-5.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	713	0.0	10.3	-10.3
3	220 kV	ALIPURDUAR-SALAKATI	2	0	123	0.0	1.9	-1.9
ER-NER						0.0	17.8	-17.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	704	0.0	16.9	-16.9
NER-NR						0.0	16.9	-16.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5033	0.0	105.6	-105.6
2	HVDC	VINDHYACHAL B/B	-	488	0	6.8	0.0	6.8
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2356	0.0	60.4	-60.4
4	765 kV	GWALIOR-AGRA	2	0	2827	0.0	50.0	-50.0
5	765 kV	GWALIOR-PHAGI	2	153	1839	0.2	26.4	-26.2
6	765 kV	JABALPUR-ORAI	2	0	1491	0.0	55.3	-55.3
7	765 kV	GWALIOR-ORAI	1	750	0	12.8	0.0	12.8
8	765 kV	SATNA-ORAI	1	0	1118	0.0	23.0	-23.0
9	765 kV	BANASKANTHA-CHITORGARH	2	689	986	2.3	10.3	-8.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	3861	0.0	70.2	-70.2
11	400 kV	ZERDA-KANKROLI	1	132	207	0.5	1.8	-1.3
12	400 kV	ZERDA -BHINMAL	1	91	144	0.3	1.4	-1.1
13	400 kV	VINDHYACHAL -RIHAND	1	967	0	22.2	0.0	22.2
14	400 kV	RAPP-SHUJALPUR	2	53	668	0.1	8.6	-8.5
15	400 kV	NEEMUCH-Chittorgarh	2	87	749	0.1	9.4	-9.4
16	220 kV	BHANPURA-RANPUR	1	0	188	0.0	3.6	-3.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	62	23	0.5	0.0	0.5
19	220 kV	MALANPUR-AURAIYA	1	35	40	0.2	0.4	-0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						45.8	428.2	-382.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	998	0	23.9	0.0	23.9
2	HVDC	RAIGARH-PUGALUR	2	0	607	0.0	11.3	-11.3
3	765 kV	SOLAPUR-RAICHUR	2	2675	0	46.2	0.0	46.2
4	765 kV	WARDHA-NIZAMABAD	2	534	1368	2.6	9.5	-6.9
5	765 kV	WARORA-WARANGAL(NEW)	2	787	1088	4.8	6.6	-1.8
6	400 kV	KOLHAPUR-KUDGI	2	2350	0	47.0	0.0	47.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
WR-SR						126.6	27.4	99.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	729	674	708	17.00	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	1046	801	904	21.70	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	154	9	71	1.71	
	NER	132kV GELEPHU-SALAKATI	43	28	38	0.90	
	NER	132kV MOTANGA-RANGIA	67	38	56	1.35	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-66	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	67	0	22	0.53	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	731	595	673	16.14	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-933	-930	-933	-22.39	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1147	-1117	-1137	-27.28	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-102	0	-89	-2.14	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13
Bangladesh	22.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.38
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.51

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	38.30	0.00	1.49	0.00	0.00	0.00	0.00	0.00	39.79	
Nepal	2.63	0.00	13.28	0.00	0.00	0.00	0.07	0.00	0.00	15.98
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	40.93	0.00	14.77	0.00	0.00	0.00	0.07	0.00	0.00	55.77

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	38.30	0.00	1.49	0.00	0.00	0.00	0.00	0.00	39.79	
Nepal	2.50	0.00	13.28	0.00	0.00	0.00	0.07	0.00	0.00	15.85
Bangladesh	-22.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.38
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	18.42	0.00	14.77	0.00	0.00	0.00	0.07	0.00	0.00	33.26