



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 15.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 14.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 14-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 14.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 15-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57114	68126	49506	23382	2666	200794
Peak Shortage (MW)	0	97	0	0	32	129
Energy Met (MU)	1243	1629	1337	478	49	4735
Hydro Gen (MU)	104	55	89	27	10	284
Wind Gen (MU)	7	50	25	-	-	81
Solar Gen (MU)*	180.74	125.34	152.83	3.63	0.84	463
Energy Shortage (MU)	0.00	0.59	0.00	0.00	0.22	0.81
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66875	79032	65775	23769	2733	234581
Time Of Maximum Demand Met	10:30	10:29	09:49	18:31	18:16	10:34

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.00	0.01	4.03	4.04	75.77	20.19

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8971	0	163.0	84.9	-0.1	467	0.00
	Haryana	8793	0	164.5	102.5	-1.0	301	0.00
	Rajasthan	18331	0	349.6	121.1	-1.2	789	0.00
	Delhi	4165	0	75.2	66.5	-0.5	360	0.00
	UP	18269	0	335.9	94.8	0.8	490	0.00
	Uttarakhand	2369	0	43.6	34.1	-0.4	122	0.00
	HP	2176	0	38.6	32.4	-0.5	157	0.00
	J&K(UT) & Ladakh(UT)	3035	59	65.2	61.4	-0.1	907	0.00
	Chandigarh	249	0	3.8	3.8	0.0	33	0.00
WR	Railways_NR ISTS	194	0	4.2	4.0	0.2	34	0.00
	Chhattisgarh	5873	0	132.0	69.5	0.2	399	0.26
	Gujarat	23257	0	442.7	185.9	0.0	553	0.00
	MP	18085	0	353.8	233.8	-3.5	518	0.33
	Maharashtra	28470	0	619.8	229.6	-1.6	846	0.00
	Goa	741	0	15.4	14.4	0.8	50	0.00
	DNHDDPDCL	1325	0	30.7	30.7	0.0	62	0.00
	AMNSIL	803	0	17.2	8.6	0.0	272	0.00
	BALCO	534	0	12.7	12.7	0.0	26	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12171	0	238.0	69.2	1.1	516	0.00
	Telangana	15721	0	302.5	167.7	-1.2	725	0.00
	Karnataka	18057	0	328.8	130.7	-0.8	1348	0.00
	Kerala	4646	0	90.4	67.5	1.7	417	0.00
	Tamil Nadu	17714	0	368.9	216.6	1.1	696	0.00
	Puducherry	392	0	8.7	8.5	-0.3	31	0.00
ER	Bihar	5237	0	99.3	87.2	-0.5	130	0.00
	DVC	3276	0	70.1	-45.0	-0.2	347	0.00
	Jharkhand	2135	0	39.5	27.0	-0.7	210	0.00
	Odisha	5244	0	101.2	30.5	-1.9	383	0.00
	West Bengal	7768	0	165.1	30.5	-1.8	156	0.00
	Sikkim	134	0	2.3	2.2	0.1	34	0.00
	Railways_ER ISTS	12	0	0.1	0.2	-0.1	4	0.00
NER	Arunachal Pradesh	195	0	3.4	3.4	-0.2	15	0.00
	Assam	1564	0	28.1	21.9	0.1	120	0.00
	Manipur	200	29	2.9	3.0	-0.1	31	0.22
	Meghalaya	328	0	5.7	4.4	-0.1	39	0.00
	Mizoram	148	0	2.1	1.9	-0.2	19	0.00
	Nagaland	162	0	2.5	2.5	0.0	37	0.00
	Tripura	235	0	4.0	3.5	-0.1	15	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.9	-12.3	-22.9	-17.5
Day Peak (MW)	-584.9	-701.3	-1004.0	-763.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	201.4	-245.1	235.4	-194.9	3.3	0.0
Actual(MU)	192.0	-243.5	244.0	-202.7	2.3	-7.9
O/D/U/D(MU)	-9.4	1.6	8.6	-7.8	-1.0	-7.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5582	6649	3718	2541	938	19427	42
State Sector	8328	11098	4837	2299	197	26758	58
Total	13910	17746	8555	4840	1134	46186	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	756	1678	737	746	17	3934	77
Lignite	25	13	56	0	0	94	2
Hydro	104	55	89	27	10	284	6
Nuclear	32	55	66	0	0	152	3
Gas, Naptha & Diesel	9	16	10	0	24	60	1
RES (Wind, Solar, Biomass & Others)	214	178	214	7	1	614	12
Total	1140	1994	1172	780	52	5138	100

Share of RES in total generation (%)	18.77	8.92	18.27	0.88	1.68	11.95
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.68	14.40	31.47	4.28	20.71	20.43

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.028

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	234581	10:34	0
Non-Solar hr	207185	18:54	48

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 15-Feb-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	49	0.0	0.8	-0.8
3	765 kV	GAYA-VARANASI	2	64	1195	0.0	18.6	-18.6
4	765 kV	SASARAM-FATEHPUR	1	0	715	0.0	12.8	-12.8
5	765 kV	GAYA-BALIA	1	0	638	0.0	8.8	-8.8
6	400 kV	PUSAULI-VARANASI	1	29	92	0.0	0.5	-0.5
7	400 kV	PUSAULI -ALLAHABAD	1	40	53	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	354	607	0.0	5.7	-5.7
9	400 kV	PATNA-BALIA	2	0	942	0.0	16.3	-16.3
10	400 kV	NAUBATPUR-BALIA	2	0	313	0.0	5.2	-5.2
11	400 kV	BIHARSHARIFF-BALIA	2	317	268	0.0	2.1	-2.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	515	0.0	7.6	-7.6
13	400 kV	BIHARSARIFE-SAHUPURI	2	0	0	0.0	6.9	-6.9
14	220 kV	SAHUPURI-KARAMNASA	1	0	72	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	86.8	-86.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	814	490	5.7	0.0	5.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	15	1449	0.0	14.8	-14.8
3	765 kV	JHARSUGUDA-DURG	2	0	1250	0.0	24.2	-24.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	949	0.0	15.8	-15.8
5	400 kV	RANCHI-SIPAT	2	0	383	0.0	4.0	-4.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	130	0.0	2.0	-2.0
7	220 kV	BUDHIPADAR-KORBA	2	43	142	0.0	0.9	-0.9
ER-WR						5.7	61.6	-55.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	367	0.0	5.6	-5.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1995	0.0	43.3	-43.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	3067	0.0	59.4	-59.4
4	400 kV	TALCHER-I/C	2	0	672	0.0	10.2	-10.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	108.3	-108.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	335	0	4.1	0.0	4.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	569	0	7.2	0.0	7.2
3	220 kV	ALIPURDUAR-SALAKATI	2	134	0	2.1	0.0	2.1
ER-NER						13.4	0.0	13.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4034	0.0	57.1	-57.1
2	HVDC	VINDHYACHAL B/B	-	171	0	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1913	0.0	32.2	-32.2
4	765 kV	GWALIOR-AGRA	2	801	1998	2.5	15.2	-12.7
5	765 kV	GWALIOR-PHAGI	2	535	1804	1.4	21.9	-20.4
6	765 kV	JABALPUR-ORAI	2	358	1051	0.0	18.4	-18.4
7	765 kV	GWALIOR-ORAI	1	833	0	14.7	0.0	14.7
8	765 kV	SATNA-ORAI	1	0	1103	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1559	530	15.9	0.9	15.0
10	765 kV	VINDHYACHAL-VARANASI	2	350	1730	0.0	17.1	-17.1
11	400 kV	ZERDA-KANKROLI	1	313	100	3.1	0.2	2.9
12	400 kV	ZERDA -BHINMAL	1	217	69	2.1	0.1	2.0
13	400 kV	VINDHYACHAL -RIHAND	1	485	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	743	312	6.1	0.7	5.3
15	400 kV	NEEMUCH-Chittorgarh	2	790	307	6.3	0.6	5.7
16	220 kV	BHANPURA-RANPUR	1	0	210	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	115	4	1.1	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	130	0	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						65.0	191.3	-126.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1013	0.0	19.6	-19.6
2	HVDC	RAIGARH-PUGALUR	2	0	5018	0.0	58.5	-58.5
3	765 kV	SOLAPUR-RAICHUR	2	1210	1753	2.5	16.7	-14.2
4	765 kV	WARDHA-NIZAMABAD	2	0	3147	0.0	50.7	-50.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2873	0.0	49.1	-49.1
6	400 kV	KOLHAPUR-KUDGI	2	1553	0	17.7	0.0	17.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	80	0.0	0.6	-0.6
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.2	0.0	2.2
WR-SR						22.3	195.2	-172.9
INTERNATIONAL EXCHANGES								
State		Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	306	101	177	4.24	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-313	74	-158	-3.80	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-404	-234	-332	-7.98	
	NER		132kV GELEPHU-SALAKATI	-15	14	-4	-0.09	
	NER		132kV MOTANGA-RANGIA	-44	6	-12	-0.28	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-66	0	-45	-1.07	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-43	-1.04	
	ER		NEPAL IMPORT (FROM BIHAR)	-199	-15	-149	-3.57	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-502	2	-275	-6.61	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-944	-752	-901	-21.62	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-764	-615	-730	-17.52	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-52	-1.24	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.35	9.28	0.00	0.00	0.00	0.00	0.00	9.63	
Nepal	3.75	0.00	4.29	0.00	0.00	0.00	2.72	0.00	0.00	10.76
Bangladesh	22.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.11	0.35	13.57	0.00	0.00	0.00	2.72	0.00	0.00	42.75

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.25
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.25

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.25	-0.35	-9.28	0.00	0.00	0.00	0.00	0.00	-8.38
Nepal	-3.75	0.00	-4.29	0.00	0.00	-2.72	0.00	0.00	-10.76
Bangladesh	-22.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.86	-0.35	-13.57	0.00	0.00	-2.72	0.00	0.00	-41.50

