



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	65391	67110	49618	25108	2889	210116
Peak Shortage (MW)	330	0	0	206	0	536
Energy Met (MU)	1396	1574	1234	509	53	4766
Hydro Gen (MU)	105	39	87	22	14	266
Wind Gen (MU)	37	135	102	-	-	274
Solar Gen (MU)*	170.04	170.72	143.12	3.27	1.01	488
Energy Shortage (MU)	0.82	0.00	0.00	0.80	0.00	1.62
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	75383	81066	64021	25377	2985	245416
Time Of Maximum Demand Met	10:59	10:31	09:42	19:06	17:31	09:52

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	1.04	0.66	3.36	5.06	76.03	18.91

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10410	0	180.3	80.7	-1.5	548	0.00
	Haryana	9333	0	178.8	115.0	-1.7	665	0.00
	Rajasthan	19282	0	347.5	119.7	0.8	1006	0.00
	Delhi	5929	0	98.4	89.5	0.2	514	0.00
	UP	22480	0	422.4	106.5	-1.7	382	0.00
	Uttarakhand	2684	0	49.7	41.1	0.6	145	0.62
	HP	2302	0	41.8	34.9	-0.3	121	0.00
	J&K(UT) & Ladakh(UT)	3294	0	68.1	63.8	-0.4	140	0.20
	Chandigarh	308	0	5.1	5.1	0.0	19	0.00
	Railways NR ISTS	204	0	3.9	3.4	0.6	60	0.00
WR	Chhattisgarh	5524	0	109.0	52.5	-1.7	359	0.00
	Gujarat	24121	0	444.3	183.5	-6.6	1073	0.00
	MP	19498	0	351.1	216.5	-0.9	705	0.00
	Maharashtra	29045	0	585.3	157.9	-7.6	693	0.00
	Goa	717	0	14.3	11.7	2.1	59	0.00
	DNHDDPDCL	1352	0	31.1	31.2	-0.1	36	0.00
	AMNSIL	911	0	19.7	11.9	0.8	316	0.00
	BALCO	599	0	14.3	14.5	-0.2	5	0.00
	RIL JAMNAGAR	225	0	5.1	5.2	-0.1	0	0.00
	Andhra Pradesh	12024	0	218.8	47.9	0.8	794	0.00
SR	Telangana	15528	0	273.4	110.2	0.0	1299	0.00
	Karnataka	17063	0	301.3	96.9	-2.9	580	0.00
	Kerala	4416	0	80.8	62.9	-0.1	382	0.00
	Tamil Nadu	17313	0	350.5	216.4	1.6	1235	0.00
	Puducherry	412	0	8.8	8.5	-0.3	23	0.00
	Bihar	6628	206	123.6	100.6	1.4	392	0.80
	DVC	3143	0	67.3	-38.0	-0.2	510	0.00
ER	Jharkhand	2291	0	43.1	31.8	0.1	267	0.00
	Odisha	5549	0	105.9	15.4	-1.3	383	0.00
	West Bengal	8153	0	166.6	51.5	-1.6	418	0.00
	Sikkim	117	0	1.9	1.8	0.1	13	0.00
	Railways ER ISTS	13	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	185	0	3.3	3.4	-0.2	17	0.00
	Assam	1632	0	29.8	23.4	0.2	74	0.00
	Manipur	256	0	4.1	4.0	0.1	36	0.00
	Meghalaya	383	0	6.8	5.9	0.0	55	0.00
	Mizoram	158	0	2.4	2.4	-0.2	19	0.00
	Nagaland	169	0	2.7	2.7	0.0	16	0.00
	Tripura	236	0	4.2	5.1	0.0	46	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-13.2	-7.2	-10.7	-26.9
Day Peak (MW)	-933.0	-685.0	-966.0	-1462.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	260.0	-251.8	132.7	-150.5	9.5	0.0
Actual(MU)	259.7	-272.1	130.0	-140.4	7.6	-15.3
O/D/U/D(MU)	-0.3	-20.4	-2.7	10.1	-1.9	-15.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6240	11734	6508	5342	295	30119	51
State Sector	7314	10358	7530	3529	205	28935	49
Total	13554	22091	14038	8871	500	59054	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	815	1516	709	704	15	3758	73
Lignite	22	14	48	0	0	84	2
Hydro	105	39	87	22	14	266	5
Nuclear	53	52	46	0	0	152	3
Gas, Naptha & Diesel	12	23	10	0	22	67	1
RES (Wind, Solar, Biomass & Others)	232	309	290	8	1	840	16
Total	1238	1954	1190	733	51	5168	100

Share of RES in total generation (%)	18.72	15.84	24.38	1.03	1.96	16.25
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.46	20.52	35.56	4.04	28.55	24.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.034

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	245416	9:52	0
Non-Solar hr	215097	17:59	140

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 10-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	315	1050	0.0	12.3	-12.3
4	765 kV	SASARAM-FATEHPUR	1	240	363	0.0	3.9	-3.9
5	765 kV	GAYA-BALIA	1	0	880	0.0	15.2	-15.2
6	400 kV	PUSAULI-VARANASI	1	2	119	0.0	1.2	-1.2
7	400 kV	PUSAULI-ALLAHABAD	1	28	98	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	341	548	0.0	3.2	-3.2
9	400 kV	PATNA-BALIA	2	0	865	0.0	12.0	-12.0
10	400 kV	NAUBATPUR-BALIA	2	178	218	0.0	4.0	-4.0
11	400 kV	BIHARSHARIEFF-BALIA	2	266	264	0.0	0.6	-0.6
12	400 kV	MOTIHARI-GORAKHPUR	2	85	467	0.0	4.6	-4.6
13	400 kV	BIHARSARIEFF-SAHUPURI	2	152	356	0.0	3.7	-3.7
14	220 kV	SAHU PURI-KARAMNASA	1	23	16	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAULI	1	0	54	0.0	0.8	-0.8
ER-NR						0.1	66.6	-66.5
Import/Export of ER (With WR)								
1	765 kV	JHARSI/GUDA-DHARAMJAIGARH	4	0	2022	0.0	30.2	-30.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1405	681	5.2	0.0	5.2
3	765 kV	JHARSI/GUDA-DURG	2	0	1264	0.0	23.0	-23.0
4	400 kV	JHARSI/GUDA-RAIGARH	4	265	249	0.0	0.4	-0.4
5	400 kV	RANCHI-SIPAT	2	367	175	1.3	0.0	1.3
6	400 kV	JEYPORE-JAGDALPUR	2	432	120	4.6	0.0	4.6
7	220 kV	BUDHIPADAR-RAIGARH	1	0	121	0.0	1.8	-1.8
8	220 kV	BUDHIPADAR-KORBA	2	81	75	0.3	0.0	0.3
ER-WR						11.4	55.3	-44.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	742	0.0	14.3	-14.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1613	0.0	39.4	-39.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	1762	0.0	26.1	-26.1
4	400 kV	TALCHER-I/C	2	647	215	5.2	0.0	5.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	2	0.0	0.0	0.0
ER-SR						0.0	79.8	-79.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	223	117	0.8	0.7	0.1
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	836	131	4.7	0.0	4.7
3	220 kV	ALIPURDUAR-SALAKATI	2	0	295	0.0	3.0	-3.0
ER-NER						5.5	3.7	1.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	465	0	10.5	0.0	10.5
NER-NR						10.5	0.0	10.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4049	0.0	94.5	-94.5
2	HVDC	VINDHYACHAL B/B	-	390	104	0.0	6.1	-6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1176	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	225	2187	0.0	25.2	-25.2
5	765 kV	GWALIOR-PHAGI	2	547	1868	1.4	23.3	-21.9
6	765 kV	JABALPUR-ORAI	2	0	1159	0.0	26.1	-26.1
7	765 kV	GWALIOR-ORAI	1	890	0	14.7	0.0	14.7
8	765 kV	SATNA-ORAI	1	0	1153	0.0	20.9	-20.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1878	1082	10.4	4.7	5.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2805	0.0	40.5	-40.5
11	400 kV	ZERDA-KANKROLI	1	305	71	2.6	0.2	2.5
12	400 kV	ZERDA -BHINMAL	1	211	49	1.8	0.1	1.7
13	400 kV	VINDHYACHAL-RIHAND	1	959	0	20.8	0.0	20.8
14	400 kV	RAPP-SHUJALPUR	2	769	271	6.9	0.5	6.4
15	400 kV	NEEMUCH-Chittorgarh	2	704	508	4.8	1.6	3.2
16	220 kV	BHANPURA-RANPUR	1	0	130	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	132	5	0.9	0.1	0.8
19	220 kV	MALANPUR-AURAIYA	1	95	20	0.5	0.2	0.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						64.8	276.6	-211.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	22.0	-22.0
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	49.8	-49.8
3	765 kV	SOLAPUR-RAICHUR	2	1650	1880	10.0	12.3	-2.3
4	765 kV	WARDHA-NIZAMABAD	2	915	2595	2.6	25.6	-23.1
5	765 kV	WARORA-WARANGAL(NEW)	2	441	3147	0.4	35.3	-34.9
6	400 kV	KOLHAPUR-KUDGI	2	1757	0	27.7	0.0	27.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.0	0.0	2.0
WR-SR						42.6	145.0	-102.4
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-303	31	-195	-4.67		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-293	146	-112	-2.70		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-255	-108	-203	-4.86		
	NER	132kV GELEPHU-SALAKATI	-55	-3	-33	-0.80		
	NER	132kV MOTANGA-RANGIA	-28	0	-7	-0.17		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-24	-0.58		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-43	-1.04		
	ER	NEPAL IMPORT (FROM BIHAR)	-178	-33	-98	-2.35		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-377	16	-133	-3.20		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-865	-4	-355	-8.51		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1462	-821	-1120	-26.89		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-123	0	-91	-2.18		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 10-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.28	14.32	0.00	0.00	0.00	0.00	0.00	14.60	
Nepal	2.26	0.00	1.08	0.00	0.00	0.00	2.43	0.00	0.00	5.77
Bangladesh	8.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.93
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	11.19	0.28	15.40	0.00	0.00	0.00	2.43	0.00	0.00	29.30

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.43
Nepal	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.43	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.48

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	-0.28	-14.32	0.00	0.00	0.00	0.00	0.00	-14.17
Nepal	-2.26	0.00	-1.08	0.00	0.00	-2.38	0.00	0.00	-5.72
Bangladesh	-8.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-8.93
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-10.76	-0.28	-15.40	0.00	0.00	-2.38	0.00	0.00	-28.82

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.01	160214	5661	15048	0	5105	2147	133381	3624	145166	164966	-1424
0:15	50.01	160019	5652	14852	0	4786	2073	133604	3696	145167	164663	-1464
0:30	50.01	158688	5658	14827	0	5215	2145	131821	3661	143861	163327	-1455
0:45	49.96	157606	5672	14900	0	5418	2149	130455	3657	142706	162251	-1450
1:00	50.01	156885	5674	15024	0	5637	2148	129339	3617	141861	161439	-1419
1:15	50.01	155613	5663	15015	0	5562	2081	128207	3634	140598	160162	-1468
1:30	50.01	154773	5663	15032	0	5560	2092	127220	3600	139741	159167	-1491
1:45	50.01	153937	5684	14763	0	5358	2086	126928	3615	139174	158434	-1483
2:00	50.06	152530	5670	14635	0	5279	2077	125584	3542	137895	156787	-1394
2:15	50.01	152410	5678	14592	0	5082	2090	125481	3654	137818	156577	-1299
2:30	50.01	152709	5663	14408	0	5075	2171	126056	3633	138301	157006	-1217
2:45	50.01	152655	5666	14213	0	5168	2077	126248	3629	138442	157001	-1203
3:00	50.01	152199	5680	14155	0	5167	2148	125748	3646	138044	156544	-1242
3:15	49.96	152416	5687	13998	0	4550	2155	126791	3655	138418	156836	-1216
3:30	50.01	152192	5689	13698	0	4446	2084	126870	3734	138494	156521	-1218
3:45	50.01	152577	5682	13543	0	4567	2070	127210	3655	139034	156727	-1159
4:00	50.01	153145	5679	13449	0	4570	2062	127887	3667	139696	157314	-1184
4:15	49.96	155286	5678	13400	0	4882	2075	129701	3684	141886	159420	-1184
4:30	50.06	156721	5696	13283	0	5180	2078	131205	3644	143438	161086	-1206
4:45	50.01	158525	5686	13155	0	5143	2103	133074	3666	145370	162827	-1172
5:00	50.06	160962	5683	13098	159	5041	2095	135676	3696	147705	165448	-1230
5:15	50.01	165144	5682	13069	120	5608	2085	139670	3633	151955	169867	-1219
5:30	50.06	169116	5663	12983	114	5984	1950	143229	3595	156019	173518	-1294
5:45	50.01	173302	5675	12966	112	6437	1959	146968	3644	160224	177761	-1319
6:00	50.01	176019	5702	12848	195	7371	1948	149069	3632	162976	180765	-1222
6:15	49.86	183200	5670	12708	230	8440	2036	154868	3639	170262	187591	-865
6:30	49.96	190329	5677	12574	230	10909	1993	159205	3628	177525	194216	-571
6:45	49.91	197783	5672	12361	258	13747	2198	163586	3650	185164	201472	-459
7:00	49.96	203679	5679	12247	431	16418	2108	166766	3688	191001	207337	-460
7:15	49.91	211282	5691	12369	1137	20823	2190	168380	3717	197776	214307	-414
7:30	49.91	215601	5671	12296	2392	22808	2243	169393	3750	200913	218553	-334
7:45	49.91	218958	5697	12048	4527	23436	2282	169897	3795	202383	221682	-269
8:00	50.01	221257	5684	11714	7822	23327	2434	169255	3753	201721	223989	-196
8:15	50.01	226065	5676	11181	12371	24102	2302	168958	3770	202513	228360	-187
8:30	50.07	228933	5670	10500	17796	22543	2309	168197	3784	200637	230799	-252
8:45	50.07	231884	5667	9948	23576	21231	2332	167251	3798	198360	233803	-309
9:00	50.07	233402	5690	9412	29345	17930	2239	166992	3843	194645	235451	-328
9:15	49.96	239187	5678	8738	34820	17341	2241	168447	3772	195629	241037	-343
9:30	50.06	243016	5674	8168	40318	16331	2219	168171	3819	194530	244700	-375
9:45	50.01	244801	5691	7890	44425	15486	2156	166744	3789	192486	246181	-292
10:00	50.06	245068	5693	7810	48016	13860	2112	164960	3802	189242	246253	-384
10:15	50.06	243787	5667	7920	52136	11013	2114	162485	3821	183731	245156	-878
10:30	50.06	243440	5675	8405	56228	9862	2089	159458	3841	178807	245558	-1342
10:45	50.06	243124	5681	8687	60294	7945	2067	156490	3843	174143	245007	-1354
11:00	50.06	241798	5655	8970	63536	6546	2077	153033	3783	169292	243600	-1461
11:15	50.06	240018	5681	9329	65474	6219	2107	149258	3772	165215	241840	-1549
11:30	49.91	238275	5872	9717	67402	5707	2066	149717	3819	161156	244300	-1561
11:45	49.61	236046	5638	9598	68554	5819	2090	142684	3695	157894	238078	-1584
12:00	49.91	234788	5631	9348	69503	6229	2053	140473	3716	155937	236953	-1575
12:15	49.91	234078	5652	8976	70323	6068	2082	139350	3778	154779	236229	-1541
12:30	49.96	231930	5656	8768	70581	5925	2082	137381	3708	152581	234101	-1567
12:45	50.01	230046	5644	8460	70839	6039	2076	135506	3728	150747	232292	-1544
13:00	50.01	226486	5640	8017	70082	5922	2050	132917	3777	148387	228405	-1527
13:15	50.01	221997	5627	7840	69486	5887	2053	129511	3745	144671	224149	-1527
13:30	50.11	220110	5632	7668	69014	5929	2051	128439	3736	143428	222469	-1532
13:45	50.11	220013	5648	7563	68646	5756	2054	128981	3690	143804	222338	-1517
14:00	50.11	219370	5644	7358	67901	6104	2041	128663	3737	144111	221448	-1530
14:15	50.01	218486	5629	7272	66601	5626	2055	129765	3754	144613	220702	-1537
14:30	50.06	219665	5618	7127	64855	5626	2052	132809	3765	147683	221852	-1535
14:45	50.01	220597	5607	7063	62674	6194	2076	135469	3746	150860	222829	-1521
15:00	50.01	221226	5614	7001	59736	6276	2053	138846	3740	154489	223266	-1516
15:15	50.06	219685	5613	6991	56981	6911	2056	139614	3765	155713	221931	-1585
15:30	50.06	218205	5613	7049	53600	6502	2034	142575	3720	157556	221093	-1720
15:45	50.06	218937	5620	6916	49988	7305	2106	146054	3713	162033	221702	-1860
16:00	50.06	218137	5608	6831	45074	8381	2085	148910	3701	166232	220590	-1894
16:15	50.01	214133	5632	6831	39703	8246	2147	151221	3697	167599	217477	-1865
16:30	50.06	213552	5631	6726	33014	10416	2457	154952	3702	173812	216898	-1883
16:45	50.01	212822	5636	6893	26289	11172	2779	159515	3753	179640	216037	-1898
17:00	50.07	212350	5621	6898	19185	13858	3241	162988	3712	186267	215503	-2022
17:15	49.92	210291	5626	7004	13042	16826	3477	163853	3689	190245	213517	-1419
17:30	50.07	212886	5641	7010	7745	20729	3681	166915	3706	198131	215427	-1046
17:45	50.02	214116	5644	7055	4064	23211	4295	169050	3728	202997	217047	-979
18:00	50.07	214272	5649	7291	1523	23887	4381	169654	3653	205458	216038	-967
18:15	49.97	213113	5642	7519	554	24180	4390	169730	3714	205040	215729	-1013
18:30	50.02	213310	5643	8083	430	24763	3619	169898	3694	204797	216130	-1018
18:45	50.02	214091	5655	8527	404	25596	2884	170414	3682	205160	217162	-1057
19:00	50.07	212190	5660	9043	248	24252	2731	169373	3699	202899	215006	-1024
19:15	49.97	210071	5663	9773	232	21321	2697	169488	3697	200066	212871	-968
19:30	50.02	208137	5658	9925	0	20115	2615	168439	3702	198212	210454	-983
19:45	50.01	205236	5649	10398	0	18797	2271	166816	3777	194838	207708	-1038
20:00	50.06	204171	5656	10463	0	17479	2247	166962	3714	193708	206521	-987
20:15	50.06	201238	5667	11077	0	15662	2203	166020	3755	190161	204384	-1026
20:30	50.01	198869	5660	11379	0	14206	2168	164672	3723	187490	201808	-1097
20:45	50.01	196440	5673	11377	0	12683	2184	164025	3768	185063	199710	-1112
21:00	50.01	193569	5680	11722	0	11522	2211	162021	3710	181847	196866	-1104
21:15	50.01	190239	5669	11766	0	10719	2209	159546	3686	178473	193595	-1141
21:30	50.02	186514	5666	11603	0	10245	2099	156612	3640	174911	189865	-1173
21:45	50.01	182695	5678	11811	0	8862	2108	154533	3636	170884	186628	-1942
22:00	50.06	178503	5671	11904	0	7426	2101	151951	3664	166599	182717	-1928
22:15	49.96	177299	5670	12281	0	7047	2102	150880	3600	165018	181580	-1875
22:30	49.91	175213	5675	12260	0	7299	2211	148317	3631	162953	179393	