



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.06.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 1-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	64454	60178	43848	27864	2905	199249
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1487	1387	1003	642	52	4571
Hydro Gen (MU)	297	17	101	64	40	517
Wind Gen (MU)	45	287	211	-	-	543
Solar Gen (MU)*	148.68	121.72	133.12	3.65	0.48	408
Energy Shortage (MU)	0.00	0.00	0.00	0.01	0.00	0.01
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71705	61685	45522	29977	3037	207975
Time Of Maximum Demand Met	00:00	00:00	21:46	22:59	19:03	00:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.091	0.57	0.94	8.45	9.95	64.59	25.46

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10565	0	216.6	129.8	-6.0	391	0.00
	Haryana	8889	0	174.2	141.5	-6.8	719	0.00
	Rajasthan	14856	0	319.0	121.0	-5.4	864	0.00
	Delhi	5693	0	113.8	105.8	-5.7	127	0.00
	UP	26501	0	520.6	242.7	0.7	651	0.00
	Uttarakhand	2239	0	46.3	26.9	2.4	358	0.00
	HP	1639	0	36.0	8.0	0.7	281	0.00
	J&K(UT) & Ladakh(UT)	2607	0	50.5	28.5	-3.6	228	0.00
	Chandigarh	289	0	5.5	5.5	0.0	43	0.00
	Railways NR ISTS	210	0	4.3	4.0	0.4	41	0.00
WR	Chhattisgarh	4953	0	107.2	51.6	-1.0	268	0.00
	Gujarat	19836	0	440.3	155.2	-6.1	703	0.00
	MP	11799	0	253.0	133.8	-5.0	556	0.00
	Maharashtra	23147	0	510.0	169.1	-7.0	876	0.00
	Goa	556	0	12.5	12.5	-0.4	53	0.00
	DNHDDPDCL	1300	0	28.9	29.1	-0.2	77	0.00
	AMNSIL	813	0	18.1	8.1	0.8	298	0.00
	BALCO	533	0	12.7	12.7	0.0	10	0.00
	RIL JAMNAGAR	200	0	3.9	4.0	-0.1	0	0.00
	Andhra Pradesh	9865	0	206.1	48.2	-2.3	451	0.00
SR	Telangana	8745	0	185.3	87.7	0.4	2077	0.00
	Karnataka	9580	0	195.6	65.2	-1.0	671	0.00
	Kerala	3900	0	73.3	31.4	0.1	491	0.00
	Tamil Nadu	15464	0	332.9	149.2	-1.4	621	0.00
	Puducherry	494	0	9.9	9.7	0.1	80	0.00
	Bihar	7298	0	155.6	146.8	-1.5	402	0.01
ER	DVC	3287	0	70.7	-22.9	0.0	364	0.00
	Jharkhand	2119	0	44.8	36.8	-0.1	127	0.00
	Odisha	6801	0	140.0	92.0	1.1	820	0.00
	West Bengal	11111	0	230.2	104.8	-1.1	473	0.00
	Sikkim	59	0	0.9	1.4	-0.5	7	0.00
	Railways ER ISTS	41	0	0.3	0.2	0.1	4	0.00
NER	Arunachal Pradesh	160	0	3.2	3.5	-0.8	5	0.00
	Assam	1991	0	34.0	29.2	1.2	181	0.00
	Manipur	161	0	1.9	2.6	-0.7	30	0.00
	Meghalaya	285	0	5.0	-0.2	-0.5	84	0.00
	Mizoram	89	0	2.2	2.3	-0.6	8	0.00
	Nagaland	153	0	2.0	2.8	-0.8	13	0.00
	Tripura	251	0	4.3	4.0	-0.4	25	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	41.5	1.6	-23.2	-25.9
Day Peak (MW)	2153.0	267.9	-983.0	-1847.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	310.4	-333.8	8.2	24.0	-8.8	0.0
Actual(MU)	329.4	-342.7	-2.4	20.9	-12.9	-7.7
O/D/UD(MU)	18.9	-8.9	-10.6	-3.0	-4.1	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6214	8583	4568	2580	335	22280	38
State Sector	7899	12296	13715	2609	179	36698	62
Total	14113	20879	18283	5189	514	58978	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	672	1328	462	621	12	3095	63
Lignite	25	18	38	0	0	81	2
Hydro	297	17	101	64	40	517	11
Nuclear	32	59	66	0	0	157	3
Gas, Naptha & Diesel	14	9	4	0	18	44	1
RES (Wind, Solar, Biomass & Others)	203	412	371	5	0	992	20
Total	1243	1843	1041	690	70	4886	100

Share of RES in total generation (%)	16.35	22.36	35.61	0.79	0.69	20.29
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.81	26.49	51.60	9.99	57.55	34.10

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.050

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	195175	15:14	0
Non-Solar hr	207975	0:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 02-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI-BB	2	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	1123	467	4.7	0.0	4.7
4	765 kV	SASARAM-FATEHPUR	1	397	245	1.0	0.0	1.0
5	765 kV	GAYA-BALIA	1	0	739	0.0	9.7	-9.7
6	400 kV	PUSAULI-VARANASI	1	0	123	0.0	2.3	-2.3
7	400 kV	PUSAULI-ALLAHABAD	1	33	28	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	348	810	0.0	7.6	-7.6
9	400 kV	PATNA-BALIA	2	289	788	0.0	7.5	-7.5
10	400 kV	NAUBATPUR-BALIA	2	205	236	0.0	1.7	-1.7
11	400 kV	BIHARSHARIFF-BALIA	2	400	284	0.0	0.3	-0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	193	487	0.0	4.8	-4.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	180	153	0.0	0.4	-0.4
14	220 kV	SAHUPURI-KARAMNESA	1	0	111	0.0	2.4	-2.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	6.3	38.9
								-32.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1527	204	12.0	0.0	12.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2823	0	39.5	0.0	39.5
3	765 kV	JHARSUGUDA-DURG	2	508	315	1.0	0.0	1.0
4	400 kV	JHARSUGUDA-RAIGARH	4	723	0	7.7	0.0	7.7
5	400 kV	RANCHI-SIPAT	2	744	0	9.6	0.0	9.6
6	220 kV	BUDHIPADAR-RAIGARH	1	146	34	0.9	0.0	0.9
7	220 kV	BUDHIPADAR-KORBA	2	293	0	3.3	0.0	3.3
						ER-WR	73.9	0.0
								73.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	358	0	8.5	0.0	8.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1760	0.0	40.0	-40.0
3	765 kV	ANGUL-SRIKAKULAM	2	450	2462	0.0	28.6	-28.6
4	400 kV	TALCHER-I/C	2	663	209	0.0	3.0	-3.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	8.5	68.6
								-60.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	310	143	3.6	0.1	3.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	216	464	0.0	2.3	-2.3
3	220 kV	ALIPURDUAR-SALAKATI	2	51	76	0.1	0.0	0.1
						ER-NER	3.7	2.5
								1.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	504	0.0	12.1	-12.1
						NER-NR	0.0	12.1
								-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3060	0.0	57.2	-57.2
2	HVDC	VINDHYACHAL B/B	-	336	0	1.2	0.0	1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1450	0.0	24.6	-24.6
4	765 kV	GWALIOR-AGRA	2	0	2472	0.0	41.2	-41.2
5	765 kV	GWALIOR-PHAGI	2	706	1246	2.1	13.9	-11.9
6	765 kV	JABALPUR-ORAI	2	0	1193	0.0	36.6	-36.6
7	765 kV	GWALIOR-ORAI	1	603	0	8.6	0.0	8.6
8	765 kV	SATNA-ORAI	1	0	1037	0.0	17.6	-17.6
9	765 kV	BANASKANTHA-CHITORGARH	2	0	2279	0.0	27.5	-27.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3553	0.0	62.7	-62.7
11	400 kV	ZERDA-KANKROLI	1	62	315	0.1	2.6	-2.5
12	400 kV	ZERDA-BHINMAL	1	176	403	0.0	4.9	-4.8
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	134	398	0.4	3.9	-3.6
15	400 kV	NEEMUCH-Chittorgarh	2	19	533	0.0	5.7	-5.7
16	220 kV	BHANPURA-RANPUR	1	0	168	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	66	36	0.2	0.0	0.2
19	220 kV	MALANPUR-AURAIYA	1	46	44	0.0	0.1	-0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	12.6	303.8
								-291.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1003	0	14.8	0.0	14.8
2	HVDC	RAIGARH-PUGALUR	2	0	1500	0.0	25.0	-25.0
3	765 kV	SOLAPUR-RAICHUR	2	2678	393	24.6	0.4	24.2
4	765 kV	WARDHA-NIZAMABAD	2	1352	1922	5.4	15.5	-10.1
5	765 kV	WARORA-WARANGAL(NEW)	2	1206	2116	5.1	18.6	-13.5
6	400 kV	KOLHAPUR-KUDGI	2	2105	0	30.3	0.0	30.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	1.9	0.0	1.9
						WR-SR	82.1	59.6
								22.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1196	875	1009	24.22	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	866	441	625	15.01	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	96	41	63	1.52	
	NER	132kV GELEPHU-SALAKATI	29	9	16	0.39	
	NER	132kV MOTANGA-RANGIA	39	0	17	0.40	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-34	-0.81	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-55	-1.32	
	ER	NEPAL IMPORT (FROM BIHAR)	-110	0	-29	-0.69	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	378	-156	185	4.43	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-890	-931	-22.34	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1847	-462	-1080	-25.91	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-42	0	-34	-0.82	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 02-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.79	0.00	0.00	0.00	0.00	2.34	0.00	0.00	3.13
Bangladesh	23.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.12
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.91	0.00	0.00	0.00	0.00	2.34	0.00	0.00	26.25

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	42.61	0.00	0.38	0.00	0.00	0.13	0.00	0.00	43.12
Nepal	4.27	0.00	2.08	0.00	0.00	0.10	0.00	0.00	6.45
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	46.88	0.00	2.46	0.00	0.00	0.23	0.00	0.00	49.57

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	42.61	0.00	0.38	0.00	0.00	0.13	0.00	0.00	43.12
Nepal	3.48	0.00	2.08	0.00	0.00	-2.24	0.00	0.00	3.32
Bangladesh	-23.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.12
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	22.97	0.00	2.46	0.00	0.00	-2.11	0.00	0.00	23.32

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.01	207975	6067	25321	0	24851	2463	148999	1861	182654	209562	1220
0:15	50.01	206505	6066	24998	0	23632	2296	149330	1807	181507	208129	1244
0:30	49.96	204891	6064	25019	0	23503	2456	148638	1850	179872	207530	1272
0:45	50.01	202324	6069	25070	0	23271	2416	148081	1796	178154	206703	1306
1:00	50.01	201500	6067	25070	0	22768	2379	147355	1850	176430	205489	1257
1:15	49.96	199205	6072	25099	0	22229	2372	146098	1838	174106	203708	1027
1:30	49.96	198373	6075	25017	0	22063	2375	145249	1818	173356	202597	1001
1:45	49.96	195913	6071	24970	0	22069	2326	144040	1875	170943	201351	886
2:00	49.96	196001	6068	25072	0	21628	2272	143080	1824	170929	199944	1076
2:15	49.96	194880	6064	24992	0	20870	2044	142763	1852	169888	198585	1134
2:30	49.96	192856	6067	24938	0	20762	1992	141943	1835	167918	197537	1093
2:45	49.96	191925	6068	23356	0	20626	2208	139799	1783	168569	193840	1022
3:00	50.01	190543	6070	23045	0	20347	1955	138839	1824	167498	192080	1101
3:15	49.96	189737	6070	22585	0	20405	1998	138202	1836	167152	191096	1081
3:30	50.04	188931	6073	22456	0	20325	2246	137555	1819	166475	190474	1077
3:45	50.04	187585	6075	22296	0	20015	2017	136590	1854	165289	188847	1200
4:00	50.09	186697	6073	22368	0	19909	1985	135739	1832	164329	187906	1243
4:15	50.04	186070	6061	22389	0	19534	1995	135499	1816	163681	187294	1173
4:30	50.04	185717	6069	22191	0	19620	1992	135261	1828	163526	186961	1136
4:45	50.04	185622	6074	22089	0	19383	1999	135596	1826	163533	186967	1152
5:00	50.04	184403	6082	21805	183	18712	1968	135333	1828	162415	185911	1189
5:15	49.99	183929	6075	21577	-4	18455	1980	135336	1798	162356	185217	1115
5:30	49.94	183934	6081	21198	6	18644	1987	135495	1808	162730	185219	1119
5:45	49.99	183741	6062	20747	43	18890	1989	135424	1838	162951	184993	1285
6:00	50.04	182699	6090	20438	187	18992	1999	134048	1881	162074	183635	1277
6:15	49.99	182677	6081	20165	1782	19083	1963	133015	1730	160730	183819	1140
6:30	50.04	182061	6067	19779	3689	18880	1965	131229	1696	158593	183305	1110
6:45	50.04	180256	6085	19186	6135	18850	2249	127449	1721	154935	181675	1142
7:00	49.89	178665	6069	19033	8744	18999	2255	123018	1728	150888	179846	1105
7:15	49.79	178082	6050	18857	11992	18860	2268	119311	1754	147233	179092	1243
7:30	49.99	178290	6092	18929	15877	18525	2250	115529	1758	143484	178960	1228
7:45	50.09	178256	6083	19752	19811	18153	2265	111050	1754	138693	178868	1148
8:00	50.29	177820	6085	20704	23625	16836	1970	107224	1715	133491	178159	1178
8:15	50.24	178081	6095	21347	26709	15972	2256	104319	1745	130025	178443	1186
8:30	50.14	177795	6083	21620	30627	16016	2257	99811	1732	125548	178146	1132
8:45	50.09	177801	6080	21725	31727	16515	2257	98381	1764	124349	178449	1124
9:00	50.19	177406	6087	22106	32991	15767	2255	97070	1757	122309	178033	1173
9:15	50.14	178756	6075	22390	34422	15651	2261	96837	1778	121944	179414	1113
9:30	50.25	180345	6082	22305	36199	15572	2259	96389	1754	121841	180560	1145
9:45	50.15	180970	6094	22376	37898	15227	2275	96147	1762	120696	181779	964
10:00	50.25	181900	6076	22267	39744	15009	2269	95728	1777	119889	182870	905
10:15	50.04	181949	6079	22187	39670	15199	2278	95875	1783	120092	183071	890
10:30	50.04	181995	6062	22024	39859	15373	2260	95829	1815	120112	183222	889
10:45	50.04	182685	6077	21967	40480	15216	2298	96186	1858	120238	184082	876
11:00	49.99	183497	6078	21572	41252	15390	2297	96281	1845	120673	184715	834
11:15	49.94	183657	6074	21375	41586	15266	2296	96678	1848	120696	185123	820
11:30	49.99	184250	6045	21790	41891	15246	2280	96922	1887	120569	186061	786
11:45	49.99	184328	6043	21649	42427	15262	2300	96425	1869	120252	185975	754
12:00	49.99	185081	6069	21576	42510	15612	2307	97041	1845	120995	186960	680
12:15	49.94	185693	6076	21471	42903	15567	2293	97229	1832	121319	187371	704
12:30	49.89	186933	6075	21259	42561	15752	2306	98361	1824	123113	188138	701
12:45	49.89	186866	6076	21274	42338	15666	2186	99153	1810	123254	188503	707
13:00	49.99	187009	6071	21102	42106	15694	2151	99745	1824	123801	188693	633
13:15	49.99	185881	6037	21539	41553	16170	2171	98362	1804	122789	187636	650
13:30	50.04	187407	6069	21655	44367	15826	2194	97333	1765	121385	189209	632
13:45	49.99	187839	6064	21971	44814	15442	2179	97373	1830	121054	189673	625
14:00	50.04	189477	6062	22537	45644	15556	1854	97524	1816	121296	190993	705
14:15	49.99	190405	6065	22950	46080	15552	1841	97361	1798	121375	191647	721
14:30	50.04	192197	6068	23197	47802	15294	1862	97761	1770	121198	193754	745
14:45	50.09	193615	6073	23372	49108	14985	1853	98201	1745	121135	195337	527
15:00	50.09	194465	6047	23668	48536	15275	1825	99252	1756	122261	196359	405
15:15	50.04	195023	6085	23877	46648	15684	1842	101039	1726	124498	196901	433
15:30	49.99	194202	6066	23856	44227	16266	1851	101975	1717	126119	195958	430
15:45	49.94	193967	6052	24137	41700	16899	1848	103543	1713	128130	195892	448
16:00	49.94	192131	6065	24341	38949	17453	1838	103757	1695	128841	194098	465
16:15	50.04	189468	6075	24404	35197	17156	1881	104977	1697	129867	191387	453
16:30	49.99	188069	6049	24365	31834	17450	1881	106666	1672	131870	189917	482
16:45	50.09	185531	6047	24541	28415	17056	1875	108033	1628	132575	187595	486
17:00	50.15	182567	5999	24593	24931	16372	1878	109081	1631	133043	184485	492
17:15	50.09	180284	5983	24890	21266	16005	1866	109934	1647	134128	181591	864
17:30	50.04	178308	5987	24768	17814	16232	1879	111618	1620	135726	179918	852
17:45	49.94	177139	5980	24553	14403	16938	1875	113419	1654	138183	178822	851
18:00	49.99	176412	5974	24196	10792	17414	1843	116093	1679	141424	177991	909
18:15	50.04	174856	5977	23994	7660	17641	1865	117620	1703	143202	176460	1054
18:30	49.99	176747	5979	24055	4948	18101	1873	121957	1730	147744	178643	1003
18:45	49.99	180215	5980	23624	2901	18818	1888	126901	1780	153690	181892	876
19:00	50.09	183841	5984	23382	1620	19705	2118	131215	1698	158839	185722	822
19:15	50.04	188764	5979	23212	781	21869	1912	134952	1712	164771	190417	826
19:30	49.99	192292	5987	23154	406	23579	2115	137247	1740	168732	194228	805
19:45	49.99	194875	5989	22985	349	24543	1995	139036	1704	171541	196601	831
20:00	50.04	195843	5975	22928	350	24892	2049	139655	1731	172565	197580	879
20:15	49.99	196206	5988	22723	0	25527	2199	139656	1726	173483	197819	786
20:30	49.94	197627	5988	22681	0	25927	2057	140771	1689	174946	199113	717
20:45	50.04	198297	5978	22632	0	25786	2158	141778	1702	175665	200034	712
21:00	50.04	199395	5984	22328	0	25938	2193	143062	1690	177067	201195	692
21:15	49.99	200132	5984	22193	0	25786	2057	144185	1659	177939	201864	740
21:30	49.99	201044	5991	21717	0	25249	2184	146622	1695	179327	203458	705
21:45	49.89	202717	5986	21498	0	25707	2190	147263	1699	181219	204343	743
22:00	49.99	203657	5993	21285	0	26340	2077	147799	1678	182372	205172	748
22:15	49.83	205163	5995	21005	0	26273	2200	149705	1696	184158	206874	761
22:30	49.83	206301	5984</									