



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55098	59982	43704	21498	2699	182981
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1081	1363	1100	437	49	4030
Hydro Gen (MU)	101	34	68	15	12	230
Wind Gen (MU)	8	113	76	-	-	197
Solar Gen (MU)*	127.83	73.53	116.83	2.98	1.11	322
Energy Shortage (MU)	0.00	0.00	0.00	0.04	0.00	0.04
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58546	65814	54092	22580	2863	197742
Time Of Maximum Demand Met	18:26	09:57	09:53	17:57	17:47	09:41

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.038	0.00	0.45	5.05	5.50	76.16	18.34

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7423	0	141.0	67.2	1.3	503	0.00
	Haryana	7279	0	130.0	87.5	-0.9	602	0.00
	Rajasthan	14623	0	277.1	97.9	-5.4	714	0.00
	Delhi	4649	0	78.6	76.6	-0.5	497	0.00
	UP	18407	0	316.5	95.2	-2.8	483	0.00
	Uttarakhand	2236	0	42.1	33.7	-0.9	186	0.00
	HP	1932	0	36.8	29.8	-1.7	132	0.00
	J&K(UT) & Ladakh(UT)	3112	0	50.9	52.1	-5.2	193	0.00
	Chandigarh	247	0	4.4	4.4	0.0	46	0.00
WR	Railways_NR ISTS	212	0	4.1	3.8	0.3	45	0.00
	Chhattisgarh	5115	0	104.1	51.5	-0.2	252	0.00
	Gujarat	21482	0	408.8	180.4	-5.3	750	0.00
	MP	11076	0	213.5	137.3	-10.0	347	0.00
	Maharashtra	26223	0	550.8	198.4	-1.7	578	0.00
	Goa	738	0	16.2	14.9	0.7	55	0.00
	DNHDDPDCL	1323	0	30.5	30.4	0.1	42	0.00
	AMNSIL	752	0	16.2	7.1	0.3	272	0.00
	BALCO	1436	0	20.3	12.7	7.6	480	0.00
SR	RIL JAMNAGAR	100	0	2.4	2.3	0.1	0	0.00
	Andhra Pradesh	9177	0	187.8	45.4	-2.0	370	0.00
	Telangana	13749	0	260.8	167.0	-0.9	648	0.00
	Karnataka	13568	0	243.4	81.3	-1.9	635	0.00
	Kerala	4287	0	84.4	73.0	0.5	414	0.00
	Tamil Nadu	15329	0	314.1	186.1	-3.8	596	0.00
	Puducherry	406	0	9.1	8.8	-0.3	28	0.00
ER	Bihar	5061	0	94.7	83.5	-1.1	175	0.04
	DVC	3162	0	67.7	-34.6	0.2	412	0.00
	Jharkhand	2020	0	37.2	27.7	-1.8	219	0.00
	Odisha	4824	0	93.6	27.2	-2.4	526	0.00
	West Bengal	7129	0	141.8	7.4	-1.5	163	0.00
	Sikkim	116	0	1.8	2.0	-0.2	30	0.00
	Railways_ER ISTS	14	0	0.2	0.2	0.0	2	0.00
NER	Arunachal Pradesh	157	0	2.8	2.9	-0.3	12	0.00
	Assam	1563	0	27.4	20.3	0.2	131	0.00
	Manipur	269	0	4.0	4.0	0.1	27	0.00
	Meghalaya	392	0	6.6	5.9	-0.1	136	0.00
	Mizoram	149	0	2.2	1.8	-0.2	12	0.00
	Nagaland	164	0	2.5	2.4	0.0	27	0.00
	Tripura	233	0	3.9	2.9	-0.2	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-9.4	-4.5	-21.3	-11.8
Day Peak (MW)	-532.3	-292.0	-986.0	-762.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	211.3	-254.1	192.5	-157.7	7.9	0.0
Actual(MU)	197.0	-244.3	182.1	-149.7	6.0	-8.9
O/D/U/D(MU)	-14.4	9.7	-10.3	8.0	-1.9	-8.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5395	10506	5518	4518	518	26454	45
State Sector	10138	11020	8644	2624	161	32586	55
Total	15533	21525	14162	7142	679	59040	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	645	1421	571	648	9	3294	75
Lignite	27	17	46	0	0	90	2
Hydro	101	34	68	15	12	230	5
Nuclear	31	54	70	0	0	155	4
Gas, Naptha & Diesel	2	8	6	0	25	40	1
RES (Wind, Solar, Biomass & Others)	162	189	225	5	1	582	13
Total	968	1723	985	668	47	4392	100

Share of RES in total generation (%)	16.70	10.97	22.83	0.81	2.40	13.26
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.34	16.08	36.82	3.07	28.38	22.03

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.031
Based on State Max Demands	1.062

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	197742	9:41	0
Non-Solar hr	192725	18:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 29-Dec-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	249	0.0	5.3	-5.3
3	765 kV	GAYA-VARANASI	2	259	834	0.0	7.0	-7.0
4	765 kV	SASARAM-FATEHPUR	1	19	595	0.0	5.4	-5.4
5	765 kV	GAYA-BALIA	1	0	777	0.0	11.6	-11.6
6	400 kV	PUSAULI-VARANASI	1	16	214	0.0	3.5	-3.5
7	400 kV	PUSAULI -ALLAHABAD	1	7	109	0.0	1.6	-1.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	93	680	0.0	6.1	-6.1
9	400 kV	PATNA-BALIA	2	0	933	0.0	13.3	-13.3
10	400 kV	NAUBATPUR-BALIA	2	0	308	0.0	4.2	-4.2
11	400 kV	BIHARSHARIFF-BALIA	2	16	311	0.0	4.6	-4.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	501	0.0	6.2	-6.2
13	400 kV	BIHARSHARIFF-VARANASI	2	0	301	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	97	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	69.8	-69.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	505	909	0.0	5.6	-5.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	876	702	0.3	0.0	0.3
3	765 kV	JHARSUGUDA-DURG	2	0	640	0.0	10.8	-10.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	622	0.0	8.5	-8.5
5	400 kV	RANCHI-SIPAT	2	183	287	0.0	1.4	-1.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	120	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	107	92	0.3	0.0	0.3
ER-WR						0.6	27.8	-27.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	210	0.0	5.0	-5.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1996	0.0	42.9	-42.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	3079	0.0	54.0	-54.0
4	400 kV	TALCHER-I/C	2	315	1006	0.0	6.0	-6.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	101.9	-101.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	360	101	2.0	0.1	2.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	708	30	5.9	0.0	5.9
3	220 kV	ALIPURDUAR-SALAKATI	2	122	1	1.1	0.0	1.1
ER-NER						9.0	0.1	9.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1550	0.0	33.0	-33.0
2	HVDC	VINDHYACHAL B/B	-	0	56	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1169	0.0	18.9	-18.9
4	765 kV	GWALIOR-AGRA	2	19	2418	0.0	27.5	-27.5
5	765 kV	GWALIOR-PHAGI	2	282	1832	0.3	18.9	-18.6
6	765 kV	JABALPUR-ORAI	2	46	989	0.0	21.9	-21.9
7	765 kV	GWALIOR-ORAI	1	781	0	11.4	0.0	11.4
8	765 kV	SATNA-ORAI	1	0	1171	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	673	850	3.9	4.7	-0.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2841	0.0	41.7	-41.7
11	400 kV	ZERDA-KANKROLI	1	151	151	1.1	0.5	0.6
12	400 kV	ZERDA -BHINMAL	1	104	105	0.8	0.4	0.4
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	19.4	0.0	19.4
14	400 kV	RAPP-SHUJALPUR	2	260	458	1.8	3.0	-1.2
15	400 kV	NEEMUCH-Chittorgarh	2	470	307	4.2	1.4	2.8
16	220 kV	BHANPURA-RANPUR	1	0	128	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	87	26	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	68	36	0.3	0.0	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						43.8	194.9	-151.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	13.8	-13.8
2	HVDC	RAIGARH-PUGALUR	2	0	2504	0.0	55.7	-55.7
3	765 kV	SOLAPUR-RAICHUR	2	1026	1366	4.2	7.3	-3.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2824	0.0	38.8	-38.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2689	0.0	37.9	-37.9
6	400 kV	KOLHAPUR-KUDGI	2	1589	0	26.5	0.0	26.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	123	2.5	0.0	2.5
WR-SR						33.1	153.4	-120.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	193	-186	-62	-1.48		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-251	192	-82	-1.97		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-258	-120	-219	-5.25		
	NER	132kV GELEPHU-SALAKATI	-33	-17	-25	-0.61		
	NER	132kV MOTANGA-RANGIA	-9	8	-2	-0.05		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-58	0	-48	-1.15		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-58	0	-30	-0.72		
	ER	NEPAL IMPORT (FROM BIHAR)	-168	-5	-83	-1.99		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-124	-3	-28	-0.66		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-938	-554	-853	-20.47		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-763	-404	-493	-11.83		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-48	0	-33	-0.80		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Dec-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	9.49	0.00	0.00	0.58	0.00	0.00	10.07
Nepal	2.21	0.00	0.98	0.00	0.00	0.33	0.00	0.00	3.52
Bangladesh	21.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.62	0.00	10.47	0.00	0.00	0.91	0.00	0.00	35.00

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.67
Nepal	0.00	0.00	0.00	0.00	0.00	0.34	0.00	0.00	0.34
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.67	0.00	0.00	0.00	0.00	0.34	0.00	0.00	1.01

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.67	0.00	-9.49	0.00	0.00	-0.58	0.00	0.00	-9.40
Nepal	-2.21	0.00	-0.98	0.00	0.00	0.02	0.00	0.00	-3.17
Bangladesh	-21.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.95	0.00	-10.47	0.00	0.00	-0.56	0.00	0.00	-33.98

Date of Reporting: 29-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.14	140760	6092	11846	42	6914	1924	116337	3144	128872	146299	-1458
0:15	50.04	139528	6084	11741	39	6387	1907	115778	3086	127748	145022	-1383
0:30	50.04	138548	6084	11585	42	6625	1905	114788	3088	126921	144117	-1404
0:45	49.98	137509	6079	11553	43	6732	1903	113698	3104	125913	143112	-1412
1:00	50.03	136252	6081	11328	41	6660	1891	112581	3115	124883	141697	-1402
1:15	49.98	135281	6083	11433	42	6464	1911	111582	3169	123806	140684	-1401
1:30	49.98	134239	6062	11182	38	6258	1915	111304	3121	123019	139880	-1423
1:45	49.93	133226	6064	10993	42	6138	1906	110654	3114	122191	138911	-1421
2:00	49.98	132543	6062	10769	40	5854	1911	110172	3128	121734	137936	-1356
2:15	50.03	131212	6081	10568	42	5680	1887	109460	3108	120602	136826	-1218
2:30	50.03	131063	6060	10659	44	5765	1898	109076	3111	120360	136613	-1180
2:45	50.08	130370	6086	10739	40	5670	1913	108098	3167	119591	135713	-1158
3:00	50.08	130180	6082	10812	42	5588	1889	108074	3100	119326	135587	-1170
3:15	50.03	130251	6076	10890	40	5782	1988	107785	3145	119321	135706	-1159
3:30	50.03	129992	6068	10777	43	5672	1937	107686	3176	119172	135359	-1145
3:45	49.98	130129	6070	10862	44	5996	1862	107519	3113	119223	135466	-1196
4:00	50.03	130317	6070	10726	41	6162	1904	107537	3099	119550	135539	-1214
4:15	49.93	132318	6076	10643	44	6448	1897	109289	3108	121631	137505	-1216
4:30	50.03	133677	6067	10588	41	6684	1901	110578	3078	123048	138937	-1217
4:45	50.03	135013	6061	10604	46	6829	1880	112016	3072	124363	140508	-1290
5:00	50.03	136745	6071	10333	45	6887	1915	113664	3105	126367	142020	-1294
5:15	49.98	140376	6075	10154	46	6938	1970	117179	3099	130176	145461	-1335
5:30	50.03	143724	6055	9765	50	7694	1957	120021	3110	133909	148652	-1427
5:45	49.93	146594	6063	9501	52	8208	1981	122395	3075	137041	151275	-1495
6:00	50.08	149327	6078	9372	56	9300	1941	124422	3071	139899	154240	-1555
6:15	50.08	152987	6083	9260	87	10373	1874	127202	3105	143640	157984	-1545
6:30	50.08	158433	6085	9090	84	13043	1856	130097	3047	149259	163302	-1469
6:45	49.98	162872	6083	8848	227	13773	1832	132928	3067	153797	166758	-1064
7:00	50.03	166396	6089	8571	436	14668	1864	135761	3076	157389	170465	-1050
7:15	49.98	170818	6068	8352	968	15156	1883	138961	3146	161498	174534	-1051
7:30	49.93	175044	6060	8284	1945	15760	1885	141593	3166	164815	178693	-1014
7:45	49.93	177984	6082	8273	3704	15666	1891	142828	3191	166007	181635	-1124
8:00	50.03	180223	6079	8012	5794	15160	1884	143801	3190	166417	183920	-1141
8:15	49.88	183668	6072	7918	8452	14056	1901	145710	3176	167298	187285	-1150
8:30	49.98	186525	6068	7676	11422	12820	1904	146964	3227	167427	190081	-1130
8:45	50.03	188588	6088	7362	14688	12022	1903	146734	3167	166538	191964	-1146
9:00	50.03	190528	6075	6983	17695	10802	1923	147269	3211	165850	193958	-1143
9:15	50.03	194485	6078	6968	21158	10873	1934	147696	3220	166359	197927	-1128
9:30	50.03	196906	6073	6642	24633	10883	1919	146891	3270	165631	200311	-1135
9:45	50.03	197504	6083	6397	27236	10677	1908	145183	3263	163871	200747	-1177
10:00	50.08	197067	6075	6226	30271	9732	1916	142627	3252	160570	200099	-1182
10:15	50.03	196521	6072	6269	33207	8629	1933	140113	3275	157045	199498	-1209
10:30	50.03	196440	6075	6391	35068	8329	1916	138218	3299	154981	199296	-1183
10:45	50.08	196023	6080	6585	37530	8247	1931	135487	3276	151908	199136	-1154
11:00	50.08	195102	6066	6780	39887	7663	1890	132291	3247	148435	197824	-1147
11:15	50.03	193773	6082	6915	41926	7395	1883	129682	3264	144932	197147	-1441
11:30	50.03	192805	6086	7083	43352	6927	1863	128251	3247	142370	196809	-1615
11:45	50.03	192149	6077	7184	45250	6926	1868	126117	3248	139715	196670	-1875
12:00	50.03	191402	6069	7179	46237	6399	1880	124854	3251	137986	195869	-1873
12:15	50.08	188967	6063	7187	47128	6402	1888	121424	3247	134652	193339	-1872
12:30	50.08	187814	6064	7288	48401	5932	1853	119364	3241	132125	192143	-1882
12:45	50.08	186908	6061	7315	48800	5765	1865	118592	3226	130793	191624	-1879
13:00	50.08	185145	6067	7313	48858	5762	1861	117156	3301	128974	190318	-1863
13:15	49.98	181747	6075	7296	48626	5591	1892	114567	3195	125825	187242	-1892
13:30	50.03	180764	6076	7307	47717	5874	1897	114165	3189	125740	186225	-1761
13:45	49.98	181357	6070	7271	47129	5959	1878	115127	3288	126957	186722	-1821
14:00	49.98	180938	6058	7169	45794	6075	1908	115938	3187	127975	186129	-1850
14:15	49.98	180669	6054	6982	44203	6402	1905	117192	3181	129484	185919	-1837
14:30	49.93	181798	6059	6794	42874	6994	1931	119155	3195	132130	187002	-1860
14:45	49.98	182519	6055	6709	41128	7431	1912	120932	3183	134682	187350	-1856
15:00	49.93	182622	6065	6555	39185	7507	1928	122877	3118	136882	187235	-1850
15:15	49.93	182155	6058	6280	36859	7012	1917	125315	3145	139016	186586	-1848
15:30	49.93	182913	6046	6214	33863	7729	1935	128648	3091	142836	187526	-1859
15:45	49.88	183543	6059	6106	30545	8348	1943	131867	3121	146892	187989	-1819
16:00	49.88	183885	6034	6037	26911	8958	1959	135221	3076	150937	188196	-1790
16:15	49.98	183074	6028	5810	23355	9091	1971	137820	3067	153909	187142	-1722
16:30	49.88	184392	6042	5629	19136	9242	2012	142843	3011	159627	187915	-1492
16:45	49.93	184809	6045	5345	14666	11074	2023	146995	2973	164798	189121	-1480
17:00	50.08	185934	6046	5029	10452	13086	1992	149837	3023	170453	189465	-1155
17:15	49.92	185907	6063	4812	6596	14751	2044	152062	3024	174499	189352	-1054
17:30	49.93	187679	6062	4694	3473	17833	2061	154165	3058	179512	191346	-1027
17:45	49.97	190068	6066	4644	1487	20088	2051	156258	3018	183937	193612	-1004
18:00	49.97	190853	6063	4702	586	21182	2065	156766	3015	185565	194379	-978
18:15	49.97	192211	6078	4975	289	21765	2048	157551	3059	186947	195765	-996
18:30	49.97	192559	6056	5305	244	21673	2060	157649	3071	187010	196058	-1049
18:45	50.02	192056	6074	5677	253	21216	2051	157112	3172	186126	195555	-1027
19:00	50.02	189785	6088	6105	248	20631	2042	155048	3080	183432	193242	-1032
19:15	50.02	186806	6073	6524	243	18954	2054	153283	3064	180039	190195	-1016
19:30	50.02	184473	6085	6928	247	17097	2045	151983	3120	177298	187505	-1005
19:45	50.02	181311	6082	7370	249	15708	2012	149834	3085	173692	184340	-1007
20:00	50.02	177339	6083	7695	128	13880	2004	147633	3065	169516	180488	-1004
20:15	50.02	173527	6076	8021	120	12262	1952	145261	3056	165386	176748	-1004
20:30	50.02	171845	6079	8380	121	11709	1929	143407	3084	163344	174709	-997
20:45	50.02	169359	6092	8695	98	11437	1929	140765	3076	160566	172092	-995
21:00	50.07	166515	6082	8908	82	11282	1933	137791	3102	157525	169180	-1046
21:15	49.97	163996	6080	9323	79	10299	1930	136149	3082	154594	166942	-1270
21:30	49.97	161695	6076	9570	138	10146	1929	134071	3123	151987	165053	-1462
21:45	49.97	159263	6085	9798	136	9517	1929	132281	3088	149329	162834	-1647
22:00	50.02	155945	6077	10143	135	8562	1945	129738	3102	145667	159702	-1616
22:15	49.97	154949	6087	10497	138	8652	1966	128306	3109	144314	158755	-1681
22:30	49.97	153309	6069	10630	133	8602						