



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 10-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54629	65245	44111	22067	2553	188605
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1223	1594	1230	460	46	4553
Hydro Gen (MU)	96	44	72	19	9	241
Wind Gen (MU)	6	23	90	-	-	118
Solar Gen (MU)*	183.73	120.64	139.30	3.83	1.08	449
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65513	78837	61233	22846	2604	228285
Time Of Maximum Demand Met	09:51	10:25	09:55	18:26	17:45	09:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.25	4.76	5.01	79.03	15.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9487	0	165.9	84.8	-0.7	388	0.00
	Haryana	8446	0	150.7	93.4	-1.2	562	0.00
	Rajasthan	18086	0	341.1	117.8	-2.0	532	0.00
	Delhi	4229	0	70.4	62.6	-1.2	313	0.00
	UP	19248	0	349.2	93.6	-0.5	291	0.00
	Uttarakhand	2194	0	40.3	30.8	-0.2	109	0.00
	HP	1945	0	35.0	29.1	-0.6	114	0.00
	J&K(UT) & Ladakh(UT)	2895	0	62.3	60.0	-1.6	150	0.00
	Chandigarh	218	0	3.5	3.5	0.0	19	0.00
WR	Railways_NR ISTS	199	0	4.4	3.9	0.5	49	0.00
	Chhattisgarh	5875	0	127.2	75.7	-2.2	277	0.00
	Gujarat	22761	0	425.1	200.8	0.5	689	0.00
	MP	18125	0	348.3	232.8	-4.3	646	0.00
	Maharashtra	28722	0	614.5	223.6	-2.2	599	0.00
	Goa	664	0	13.6	13.4	-0.1	51	0.00
	DNHDDPDCL	1262	0	29.3	29.5	-0.2	68	0.00
	AMNSIL	844	0	18.6	8.6	0.7	272	0.00
	BALCO	535	0	12.7	12.7	0.0	36	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12321	0	230.8	57.6	0.7	658	0.00
	Telangana	15562	0	299.0	176.0	-0.4	761	0.00
	Karnataka	16147	0	292.0	99.7	0.1	494	0.00
	Kerala	3988	0	78.4	61.7	0.1	277	0.00
	Tamil Nadu	14994	0	322.0	170.3	-2.2	622	0.00
	Puducherry	362	0	8.2	7.7	-0.1	30	0.00
	Bihar	5193	0	97.2	85.7	-0.8	207	0.00
	DVC	3214	0	67.9	-41.4	-1.1	411	0.00
ER	Jharkhand	2010	0	39.2	26.7	0.0	148	0.00
	Odisha	4969	0	102.9	34.6	-0.1	476	0.00
	West Bengal	7100	0	151.3	27.2	-1.7	142	0.00
	Sikkim	115	0	1.9	1.8	0.1	30	0.00
	Railways_ER ISTS	14	0	0.2	0.3	-0.1	3	0.00
	Arunachal Pradesh	184	0	4.1	3.4	0.6	15	0.00
NER	Assam	1468	0	26.7	20.3	0.2	104	0.00
	Manipur	199	0	1.1	3.3	-2.2	43	0.00
	Meghalaya	309	0	5.4	4.9	-0.1	74	0.00
	Mizoram	126	0	2.0	1.8	-0.2	14	0.00
	Nagaland	141	0	2.5	2.5	-0.1	34	0.00
	Tripura	225	0	3.8	3.2	-0.2	26	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-8.4	-11.5	-22.9	-16.0
Day Peak (MW)	-641.0	-611.0	-1004.0	-770.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	188.9	-212.4	182.5	-163.1	4.0	0.0
Actual(MU)	179.2	-182.6	170.4	-166.8	3.2	3.4
O/D/U/D(MU)	-9.7	29.7	-12.1	-3.8	-0.8	3.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5248	7606	5198	4071	903	23026	49
State Sector	5923	11506	4562	2099	161	24251	51
Total	11171	19111	9760	6170	1064	47276	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	746	1643	661	695	15	3760	76
Lignite	30	13	40	0	0	83	2
Hydro	96	44	72	19	9	241	5
Nuclear	32	55	66	0	0	153	3
Gas, Naptha & Diesel	9	15	9	0	23	57	1
RES (Wind, Solar, Biomass & Others)	216	148	277	7	1	650	13
Total	1130	1918	1125	722	49	4944	100

Share of RES in total generation (%)	19.13	7.73	24.65	0.99	2.24	13.15
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.49	12.87	36.91	3.67	21.60	21.12

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.027

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	228285	9:56	0
Non-Solar hr	195386	18:45	48

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES							Import=(+ve) /Export =(-ve) for NET (MU)	
							Date of Reporting: 10-Feb-2025	
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	232	913	0.0	13.3	-13.3
4	765 kV	SASARAM-FATEHPUR	1	17	557	0.0	9.4	-9.4
5	765 kV	GAYA-BALIA	1	0	594	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	87	0.0	1.1	-1.1
7	400 kV	PUSAULI -ALLAHABAD	1	38	42	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	253	516	0.0	4.5	-4.5
9	400 kV	PATNA-BALIA	2	0	724	0.0	9.8	-9.8
10	400 kV	NAUBATPUR-BALIA	2	6	240	0.0	2.9	-2.9
11	400 kV	BIHARSHARIFF-BALIA	2	194	253	0.0	2.1	-2.1
12	400 kV	MOTIHARI-GORAKHPUR	2	36	377	0.0	4.7	-4.7
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	400 kV	BIHARSARIFF-SAHUPURI	2	276	417	0.0	4.8	-4.8
15	220 kV	SAHUPURI-KARAMNASA	1	0	63	0.0	0.6	-0.6
16	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
17	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
18	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
19	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	63.0	-62.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	474	755	0.0	3.7	-3.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	564	1307	0.0	13.6	-13.6
3	765 kV	JHARSUGUDA-DURG	2	0	1107	0.0	21.6	-21.6
4	400 kV	JHARSUGUDA-RAIGARH	4	0	847	0.0	14.0	-14.0
5	400 kV	RANCHI-SIPAT	2	148	430	0.0	4.8	-4.8
6	220 kV	BUDHIPADAR-RAIGARH	1	6	83	0.0	0.8	-0.8
7	220 kV	BUDHIPADAR-KORBA	2	81	81	0.0	0.0	0.0
ER-WR						0.0	58.6	-58.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	363	0.0	8.6	-8.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1245	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	3061	0.0	53.8	-53.8
4	400 kV	TALCHER-I/C	2	170	57	2.5	0.0	2.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	92.5	-92.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	273	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	558	0	7.4	0.0	7.4
3	220 kV	ALIPURDUAR-SALAKATI	2	109	0	1.7	0.0	1.7
ER-NER						12.6	0.0	12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	666	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4037	0.0	96.4	-96.4
2	HVDC	VINDHYACHAL B/B	-	193	0	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	30.1	-30.1
4	765 kV	GWALIOR-AGRA	2	696	1390	1.5	10.0	-8.5
5	765 kV	GWALIOR-PHAGI	2	450	1553	1.1	18.5	-17.4
6	765 kV	JABALPUR-ORAI	2	252	785	0.0	12.6	-12.6
7	765 kV	GWALIOR-ORAI	1	818	0	14.8	0.0	14.8
8	765 kV	SATNA-ORAI	1	0	931	0.0	16.5	-16.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1717	0	22.9	0.0	22.9
10	765 kV	VINDHYACHAL-VARANASI	2	40	1906	0.0	11.1	-11.1
11	400 kV	ZERDA-KANKROLI	1	298	0	4.5	0.0	4.5
12	400 kV	ZERDA -BHINMAL	1	206	0	3.1	0.0	3.1
13	400 kV	VINDHYACHAL -RIHAND	1	481	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	649	134	6.9	0.2	6.7
15	400 kV	NEEMUCH-Chittorgarh	2	677	168	6.9	0.3	6.6
16	220 kV	BHANPURA-RANPUR	1	0	209	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	135	0	2.1	0.0	2.1
19	220 kV	MALANPUR-AURAIYA	1	95	0	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						75.7	203.4	-127.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	15.8	-15.8
2	HVDC	RAIGARH-PUGALUR	2	0	2003	0.0	44.0	-44.0
3	765 kV	SOLAPUR-RAICHUR	2	1193	1424	7.5	9.1	-1.5
4	765 kV	WARDHA-NIZAMABAD	2	17	2783	0.0	38.1	-38.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2943	0.0	42.4	-42.4
6	400 kV	KOLHAPUR-KUDGI	2	1642	0	26.4	0.0	26.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	2.1	0.0	2.1
WR-SR						36.0	149.3	-113.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	186	-160	18	0.43		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-278	91	-131	-3.15		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-287	-141	-228	-5.47		
	NER	132kV GELEPHU-SALAKATI	0	0	0	0.00		
	NER	132kV MOTANGA-RANGIA	-18	0	-9	-0.22		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	-45	-1.08		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-42	-1.02		
	ER	NEPAL IMPORT (FROM BIHAR)	-187	-132	-159	-3.81		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-424	-8	-233	-5.58		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-945	-756	-907	-21.77		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-770	-402	-668	-16.03		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-59	0	-45	-1.08		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	8.68	0.00	0.00	0.61	0.00	0.00	9.64
Nepal	3.91	0.00	4.14	0.00	0.00	2.14	0.00	0.00	10.19
Bangladesh	22.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.44
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.35	0.35	12.82	0.00	0.00	2.75	0.00	0.00	42.27

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.76	-0.35	-8.68	0.00	0.00	-0.61	0.00	0.00	-8.88
Nepal	-3.91	0.00	-4.14	0.00	0.00	-2.14	0.00	0.00	-10.19
Bangladesh	-22.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.44
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.59	-0.35	-12.82	0.00	0.00	-2.75	0.00	0.00	-41.51

