



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 22.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 21.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 21-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 21.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 22-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58109	65597	45029	23347	2673	194755
Peak Shortage (MW)	0	280	0	310	0	590
Energy Met (MU)	1226	1572	1161	477	50	4487
Hydro Gen (MU)	89	47	83	23	10	251
Wind Gen (MU)	19	40	56	-	-	115
Solar Gen (MU)*	163.10	104.42	139.65	3.25	0.98	411
Energy Shortage (MU)	0.29	0.66	0.00	0.52	0.00	1.47
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65090	78593	58668	24570	2779	226044
Time Of Maximum Demand Met	10:12	09:56	09:11	18:01	17:35	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.032	0.00	0.57	4.19	4.76	77.93	17.31

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8127	0	150.3	67.2	1.1	522	0.00
	Haryana	8158	0	152.1	100.8	-1.5	207	0.00
	Rajasthan	18168	0	330.1	107.4	-3.9	551	0.00
	Delhi	4690	0	80.4	79.9	-1.5	368	0.00
	UP	19130	0	353.7	117.3	-0.8	552	0.00
	Uttarakhand	2514	0	45.0	36.7	-0.3	82	0.00
	HP	2142	0	39.3	32.9	-0.2	137	0.00
	J&K(UT) & Ladakh(UT)	3160	0	66.5	64.4	-1.8	996	0.29
	Chandigarh	278	0	4.5	4.5	-0.1	53	0.00
WR	Railways_NR ISTS	192	0	4.1	3.8	0.3	43	0.00
	Chhattisgarh	5658	0	115.0	62.8	-1.0	375	0.00
	Gujarat	23322	0	431.4	192.4	-5.1	682	0.00
	MP	18403	0	343.0	220.4	-1.6	958	0.66
	Maharashtra	29230	0	605.2	208.4	4.0	1040	0.00
	Goa	710	0	14.8	14.3	0.2	47	0.00
	DNHDDPDCL	1335	0	30.6	30.7	-0.1	35	0.00
	AMNSIL	713	0	15.2	5.7	0.5	270	0.00
	BALCO	534	0	12.7	12.7	0.0	14	0.00
SR	RIL JAMNAGAR	188	0	4.3	4.3	0.0	0	0.00
	Andhra Pradesh	11033	0	206.9	57.3	-1.7	481	0.00
	Telangana	14595	0	271.8	138.7	-0.7	779	0.00
	Karnataka	16150	0	284.0	84.9	-1.7	522	0.00
	Kerala	4409	0	86.8	68.4	1.0	511	0.00
	Tamil Nadu	15600	0	303.0	167.1	-2.3	976	0.00
	Puducherry	385	0	8.4	8.1	-0.3	35	0.00
ER	Bihar	5357	0	100.3	89.9	-1.1	317	0.52
	DVC	3293	0	69.1	-36.3	-1.6	314	0.00
	Jharkhand	2112	0	40.4	26.9	0.5	167	0.00
	Odisha	5351	0	105.9	35.1	-1.7	476	0.00
	West Bengal	7786	0	159.6	28.1	-1.3	224	0.00
	Sikkim	123	0	2.1	2.0	0.2	30	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	182	0	3.7	3.2	0.4	9	0.00
	Assam	1562	0	28.0	20.9	0.4	81	0.00
	Manipur	270	0	3.7	3.7	0.0	32	0.00
	Meghalaya	376	0	6.5	5.2	-0.3	17	0.00
	Mizoram	144	0	2.0	1.9	-0.3	19	0.00
	Nagaland	154	0	2.5	2.4	0.0	18	0.00
	Tripura	227	0	4.0	3.3	-0.1	13	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.3	-8.7	-22.9	-13.6
Day Peak (MW)	-331.0	-612.0	-1006.0	-766.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	236.8	-232.7	150.6	-160.7	6.0	0.0
Actual(MU)	206.7	-209.8	142.0	-152.5	5.5	-8.1
O/D/U/D(MU)	-30.1	22.9	-8.6	8.2	-0.4	-8.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5170	7776	6608	4065	673	24291	46
State Sector	8363	10749	5299	3819	222	28451	54
Total	13533	18524	11907	7883	894	52742	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	744	1632	644	689	15	3724	76
Lignite	30	21	45	0	0	95	2
Hydro	89	47	83	23	10	251	5
Nuclear	32	55	71	0	0	158	3
Gas, Naptha & Diesel	3	14	5	0	24	46	1
RES (Wind, Solar, Biomass & Others)	241	148	239	6	1	636	13
Total	1138	1917	1087	718	50	4909	100

Share of RES in total generation (%)	21.21	7.73	22.02	0.79	2.01	12.95
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.81	13.01	36.19	3.96	21.25	21.26

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.043

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226044	9:43	285
Non-Solar hr	203774	18:36	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 22-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.1	-1.1
3	765 kV	GAYA-VARANASI	2	299	981	0.0	10.7	-10.7
4	765 kV	SASARAM-FATEHPUR	1	26	662	0.0	9.7	-9.7
5	765 kV	GAYA-BALIA	1	0	569	0.0	10.1	-10.1
6	400 kV	PUSAULI-VARANASI	1	0	131	0.0	1.4	-1.4
7	400 kV	PUSAULI -ALLAHABAD	1	82	33	0.5	0.0	0.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	220	714	0.0	7.5	-7.5
9	400 kV	PATNA-BALIA	2	89	819	0.0	11.6	-11.6
10	400 kV	NAUBATPUR-BALIA	2	73	278	0.0	3.6	-3.6
11	400 kV	BIHARSHARIFF-BALIA	2	159	238	0.0	3.0	-3.0
12	400 kV	MOTIHARI-GORAKHPUR	2	6	424	0.0	5.4	-5.4
13	400 kV	BIHARSHARIFF-VARANASI	2	57	398	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	110	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						1.1	64.7	-63.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	595	1211	0.0	8.5	-8.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	396	896	0.0	4.7	-4.7
3	765 kV	JHARSUGUDA-DURG	2	0	1011	0.0	19.3	-19.3
4	400 kV	JHARSUGUDA-RAIGARH	4	0	701	0.0	9.5	-9.5
5	400 kV	RANCHI-SIPAT	2	101	287	0.0	2.4	-2.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	109	0.0	1.5	-1.5
7	220 kV	BUDHIPADAR-KORBA	2	139	41	1.5	0.0	1.5
ER-WR						1.5	45.9	-44.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	755	0.0	8.1	-8.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1984	0.0	34.1	-34.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2675	0.0	41.8	-41.8
4	400 kV	TALCHER-I/C	2	180	700	0.0	1.3	-1.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	84.0	-84.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	274	53	3.1	0.1	3.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	152	0	6.0	0.0	6.0
3	220 kV	ALIPURDUAR-SALAKATI	2	28	0	1.4	0.0	1.4
ER-NER						10.4	0.1	10.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.4	0.0	16.4
NER-NR						16.4	0.0	16.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3040	0.0	67.0	-67.0
2	HVDC	VINDHYACHAL B/B	-	408	226	6.7	1.6	5.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	126	2323	0.0	23.6	-23.6
5	765 kV	GWALIOR-PHAGI	2	0	1895	0.0	24.0	-24.0
6	765 kV	JABALPUR-ORAI	2	5	1189	0.0	25.1	-25.1
7	765 kV	GWALIOR-ORAI	1	863	0	15.6	0.0	15.6
8	765 kV	SATNA-ORAI	1	0	1092	0.0	19.7	-19.7
9	765 kV	BANASKANTHA-CHITORGARH	2	1708	234	18.7	0.2	18.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2703	0.0	36.7	-36.7
11	400 kV	ZERDA-KANKROLI	1	312	21	3.9	0.0	3.9
12	400 kV	ZERDA -BHINMAL	1	215	15	2.7	0.0	2.7
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	22.2	0.0	22.2
14	400 kV	RAPP-SHUJALPUR	2	553	370	4.3	1.3	3.0
15	400 kV	NEEMUCH-Chittorgarh	2	580	405	4.3	1.2	3.1
16	220 kV	BHANPURA-RANPUR	1	0	198	0.0	3.1	-3.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	106	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	74	21	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						80.5	241.9	-161.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	509	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	4507	0.0	63.7	-63.7
3	765 kV	SOLAPUR-RAICHUR	2	1754	1297	14.2	7.6	6.6
4	765 kV	WARDHA-NIZAMABAD	2	800	2210	1.2	25.7	-24.5
5	765 kV	WARORA-WARANGAL(NEW)	2	497	2297	0.5	28.8	-28.3
6	400 kV	KOLHAPUR-KUDGI	2	1790	0	27.4	0.0	27.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	100	2.1	0.0	2.1
WR-SR						45.3	137.8	-92.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	161	0	51	1.23		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-231	164	-74	-1.78		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-259	-83	-183	-4.39		
	NER	132kV GELEPHU-SALAKATI	-31	-5	-18	-0.42		
	NER	132kV MOTANGA-RANGIA	-27	14	0	0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-44	-1.05		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-46	-1.11		
	ER	NEPAL IMPORT (FROM BIHAR)	-202	-20	-91	-2.17		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-410	0	-182	-4.37		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-945	-750	-903	-21.68		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-407	-568	-13.64		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-61	0	-49	-1.18		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 22-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.30	5.36	0.00	0.00	0.00	0.70	0.00	0.00	6.36
Nepal	2.06	0.00	2.93	0.00	0.00	0.00	1.56	0.00	0.00	6.55
Bangladesh	22.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.47	0.30	8.29	0.00	0.00	0.00	2.26	0.00	0.00	35.32

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75
Nepal	0.00	0.00	0.00	0.00	0.00	0.04	0.00	0.00	0.04
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.75	0.00	0.00	0.00	0.00	0.04	0.00	0.00	0.79

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	-0.30	-5.36	0.00	0.00	-0.70	0.00	0.00	-5.61
Nepal	-2.06	0.00	-2.93	0.00	0.00	-1.52	0.00	0.00	-6.51
Bangladesh	-22.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.72	-0.30	-8.29	0.00	0.00	-2.22	0.00	0.00	-34.53

Date of Reporting: 22-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	155583	6256	6825	0	5763	1681	135534	3398	148692	159523	-1436
0:15	50.03	155592	6245	6829	0	5976	1676	135296	3400	148686	159499	-1485
0:30	50.03	154467	6245	6761	0	5868	1675	134685	3402	147621	158721	-1555
0:45	49.98	153114	6232	6745	0	5660	1675	133481	3382	146285	157259	-1585
1:00	50.03	152000	6249	6632	0	5447	1684	132779	3394	145284	156269	-1597
1:15	49.98	151351	6253	6373	0	5379	1675	132353	3387	144895	155503	-1500
1:30	49.98	149636	6252	6193	0	5324	1823	131075	3399	143371	154138	-1426
1:45	49.98	149598	6238	6084	0	5284	1674	130772	3416	143450	153532	-1387
2:00	50.03	148137	6247	5868	0	5151	1673	129838	3429	142208	152267	-1383
2:15	49.98	147724	6242	5830	0	4974	1676	129728	3441	141833	151952	-1430
2:30	50.03	147305	6251	5889	0	5018	1675	129093	3448	141357	151433	-1420
2:45	49.98	147319	6252	5890	0	5019	1688	129022	3453	141376	151377	-1385
3:00	50.03	146447	6242	5876	0	4947	1897	128473	3443	140519	150930	-1420
3:15	49.98	146454	6225	5858	0	4571	1777	128903	3460	140545	150845	-1444
3:30	50.03	146707	6264	5860	0	4715	1784	128858	3465	140798	150995	-1483
3:45	49.98	147007	6255	5921	0	4820	1777	128947	3432	141039	151199	-1435
4:00	50.03	146926	6252	5957	0	4857	1779	129011	3439	140926	151338	-1472
4:15	49.93	148951	6257	5868	0	5103	1784	130830	3359	143039	153245	-1466
4:30	50.03	150108	6234	5701	0	5082	1781	132417	3357	144387	154592	-1495
4:45	49.98	152244	6261	5743	0	5283	1775	134197	3358	146478	156640	-1496
5:00	50.03	154638	6256	5786	0	5867	1791	136078	3375	148826	159179	-1484
5:15	49.93	159192	6260	5804	0	6515	1966	139893	3376	153365	163837	-1494
5:30	50.03	162908	6289	5767	0	6739	1832	143557	3342	157118	167549	-1479
5:45	50.03	167727	6283	5845	0	7420	2064	147697	3398	161851	172738	-1571
6:00	50.03	170920	6284	5786	27	8152	1846	150354	3420	165107	175869	-1553
6:15	49.93	177299	6272	5774	145	9496	1899	154903	3422	171376	181915	-1423
6:30	49.98	184110	6277	5655	150	12201	1915	159180	3443	178310	188816	-1332
6:45	50.03	192144	6294	5585	162	16339	1945	162961	3421	186397	196707	-1316
7:00	49.93	197853	6292	5534	337	19457	1972	165517	3432	191982	202541	-1257
7:15	49.93	203318	6312	5521	983	22530	1998	167073	3469	196814	207886	-1236
7:30	49.83	207150	6304	5419	2295	23796	2025	167988	3520	199436	211347	-1155
7:45	50.03	210021	6330	5383	4386	24272	2011	167843	3534	200252	213759	-1152
8:00	50.08	211546	6330	5589	7487	23603	2017	166626	3547	198470	215199	-1140
8:15	50.08	213837	6341	5231	11566	22888	2079	165756	3610	197040	217471	-1141
8:30	50.13	214865	6338	4965	15998	20728	2118	164340	3627	193902	218114	-1073
8:45	50.08	217176	6349	4788	20838	18065	2113	164540	3638	191550	220331	-1047
9:00	50.13	219449	6350	4487	26150	15654	2113	164248	3640	188812	222642	-1078
9:15	50.08	223924	6340	4441	31068	14880	2106	164420	3652	188415	226907	-1078
9:30	50.08	225415	6347	4247	35376	13910	2007	163293	3649	185792	228829	-1283
9:45	50.08	225694	6314	3869	39363	12352	1864	161559	3657	182462	228978	-1458
10:00	50.03	225186	6312	3525	42936	10918	1858	159469	3623	178725	228641	-1498
10:15	49.93	224678	6292	3258	46308	9302	1854	157765	3627	175112	228406	-1490
10:30	49.98	225002	6287	3126	48863	8358	1850	156266	3660	173013	228410	-1454
10:45	50.03	224483	6276	2851	51234	7748	1859	154486	3625	170398	228079	-1501
11:00	50.03	222842	6266	2777	53224	7242	1859	151541	3680	166841	226589	-1504
11:15	49.98	220762	6140	2661	54766	6424	1883	149013	3641	163335	224528	-1539
11:30	49.98	220014	6259	2616	55857	6030	1747	147520	3606	161541	223635	-1585
11:45	49.98	218512	6266	2586	56846	5713	1640	145669	3633	159080	222353	-1703
12:00	50.03	216542	6255	2542	57494	5602	1584	143140	3601	156506	220218	-1684
12:15	49.98	214613	6155	2640	57657	5340	1562	141595	3614	154316	218563	-1780
12:30	50.03	213095	6269	2607	57715	5311	1586	139177	3599	152773	216264	-1726
12:45	50.03	210914	6256	2655	57699	5351	1648	136872	3622	150560	214103	-1867
13:00	50.08	207944	6242	2657	57817	5664	1640	133485	3589	147470	211094	-1844
13:15	49.98	203705	6230	2646	57361	5162	1655	130284	3659	143698	206997	-1861
13:30	50.03	202513	6251	2686	57303	5050	1646	128765	3601	142524	205302	-1855
13:45	49.98	202366	6251	2630	56654	5160	1662	129503	3616	143082	205476	-1828
14:00	49.98	201689	6251	2598	55708	5080	1641	130112	3576	143383	204966	-1847
14:15	49.98	201947	6254	2575	54805	5078	1645	131562	3572	144567	205491	-1862
14:30	49.98	202542	6240	2565	53182	5241	1640	133494	3610	146795	205972	-1883
14:45	49.98	202643	6259	2552	50976	5172	1646	136140	3540	149115	206285	-1872
15:00	49.98	202415	6242	2564	48591	5355	1646	137620	3532	151260	205550	-1877
15:15	49.93	201746	6259	2553	46018	5398	1668	139375	3532	153175	204803	-1750
15:30	49.98	202548	6276	2557	43472	5664	1652	142057	3444	156519	205122	-1736
15:45	49.93	201305	6266	2580	40289	6072	1728	142593	3443	158436	202971	-1727
16:00	50.03	201361	6254	2613	36571	6371	1770	144374	3451	162177	201404	-1717
16:15	50.03	198327	6263	2625	32630	6734	1744	146704	3346	163072	200046	-1534
16:30	50.03	199176	6281	2645	27826	7875	1770	148899	3292	168705	198588	-1487
16:45	49.93	200033	6286	2595	22764	8843	1783	150958	3290	174674	196519	-1268
17:00	49.98	200243	6281	2639	17348	10287	1824	153605	3343	180256	195327	-1133
17:15	50.03	198315	6302	2515	12317	14897	1860	160964	3290	183483	202145	-1011
17:30	50.03	199399	6299	2557	7825	18822	1864	162509	3281	189017	203157	-862
17:45	50.03	200872	6320	2655	4332	21820	1900	164362	3294	193885	204683	-891
18:00	50.03	201361	6322	2826	2157	22590	2010	165961	3231	196378	205097	-883
18:15	49.93	201862	6322	3033	907	23015	1932	167295	3323	197922	205827	-886
18:30	49.88	203338	6329	3324	232	23899	1963	167980	3291	199782	207018	-824
18:45	50.04	203027	6326	3602	137	23750	1897	167524	3321	199288	206557	-816
19:00	49.98	202506	6329	3887	92	22445	1865	167935	3308	198491	205897	-874
19:15	49.98	200587	6333	4114	0	20491	1868	167563	3257	196348	203751	-903
19:30	50.04	198053	6334	4334	0	19073	1789	166283	3271	193605	201198	-843
19:45	50.09	195342	6368	4591	0	17193	1906	165108	3263	190636	198544	-840
20:00	50.09	191517	6342	4739	0	15155	1889	163215	3315	186686	194747	-840
20:15	50.04	188289	6329	4923	0	12584	1894	162327	3309	183264	191468	-936
20:30	50.04	186218	6337	5016	0	11124	1639	161741	3230	181098	189191	-981
20:45	49.99	183583	6343	5145	0	10123	1793	159977	3273	178332	186760	-968
21:00	50.04	180351	6351	5306	0	9873	1657	157281	3228	174978	183763	-1046
21:15	49.99	177881	6322	5316	0	8979	1641	155644	3251	172501	181217	-1248
21:30	49.99	174577	6316	5671	0	8021	1580	153370	3239	168833	178270	-1254
21:45	49.99	172279	6303	5697	0	7508	1722	151799	3260	166501	176370	-1449
22:00	50.04	168998	6332	5689	0	7274	1652	148652	3257	163230	172935	-1430
22:15	49.89	168757	6331	5823	0	7216	1676	148032	3319	162852	172479	-1458
22:30	49.94	167007	6328	6031	0	7482	1870	145866	3269	160899	170923	-1471
22:45	49.99</											