



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 17-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.05.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 16-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 17-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71735	62390	46217	27567	3425	211334
Peak Shortage (MW)	132	0	0	0	0	132
Energy Met (MU)	1645	1545	1117	639	69	5016
Hydro Gen (MU)	295	52	33	27	14	420
Wind Gen (MU)	20	58	37	-	-	116
Solar Gen (MU)*	159.05	87.06	103.47	2.92	1.26	354
Energy Shortage (MU)	3.58	0.00	0.00	1.69	0.93	6.20
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74989	69972	51087	29450	3594	226371
Time Of Maximum Demand Met	14:31	15:46	11:51	22:53	18:46	14:31

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.019	0.00	0.00	1.40	1.40	89.21	9.39

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12245	0	238.6	102.1	0.6	245	0.00
	Haryana	10305	0	223.0	169.2	-5.8	196	0.00
	Rajasthan	15610	0	331.6	126.4	2.6	424	3.58
	Delhi	6756	0	134.8	109.7	-8.3	223	0.00
	UP	26950	0	564.7	247.1	0.1	405	0.00
	Uttarakhand	2549	0	53.8	32.1	-2.4	213	0.00
	HP	1593	0	33.9	2.2	-0.1	76	0.00
	J&K(UT) & Ladakh(UT)	2470	0	54.0	30.0	-0.1	316	0.00
	Chandigarh	350	0	6.8	6.7	0.1	36	0.00
WR	Railways_NR ISTS	207	0	4.2	3.7	0.5	73	0.00
	Chhattisgarh	5200	0	117.5	58.3	0.2	241	0.00
	Gujarat	22202	0	467.9	162.5	-3.8	638	0.00
	MP	13202	0	287.0	155.8	-3.2	555	0.00
	Maharashtra	26496	0	595.2	196.1	-7.6	735	0.00
	Goa	745	0	16.0	14.2	1.5	78	0.00
	DNHDDPDCL	1299	0	30.2	30.3	-0.1	94	0.00
	AMNSIL	856	0	19.0	8.5	0.4	201	0.00
	BALCO	522	0	12.5	12.5	0.0	7	0.00
SR	Andhra Pradesh	10539	0	221.3	59.0	-2.2	554	0.00
	Telangana	9219	0	187.5	70.0	-1.8	613	0.00
	Karnataka	12730	0	248.0	122.8	-4.0	491	0.00
	Kerala	4382	0	90.7	73.1	0.3	269	0.00
	Tamil Nadu	16480	0	359.7	236.0	-5.0	349	0.00
	Puducherry	435	0	10.0	9.8	-0.4	25	0.00
ER	Bihar	6997	435	146.0	130.8	3.6	511	1.05
	DVC	3546	0	77.4	-37.6	0.4	252	0.00
	Jharkhand	2117	0	46.6	32.6	0.5	286	0.64
	Odisha	6573	0	132.0	51.3	-0.4	467	0.00
	West Bengal	11328	0	236.4	88.9	-0.7	304	0.00
	Sikkim	73	0	1.0	1.2	-0.2	29	0.00
	Railways_ER ISTS	13	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	167	0	3.0	2.7	0.2	32	0.00
	Assam	2268	0	45.1	38.0	0.2	181	0.93
	Manipur	226	0	3.4	3.4	0.0	10	0.00
	Meghalaya	294	0	5.6	3.7	-0.1	59	0.00
	Mizoram	130	0	2.2	1.8	-0.1	17	0.00
	Nagaland	177	0	3.1	3.1	0.0	12	0.00
	Tripura	360	0	6.9	6.4	0.5	75	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-1.3	-11.7	-23.2	-12.5
Day Peak (MW)	187.0	-812.6	-1073.0	-1064.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	287.3	-377.7	118.6	-47.2	19.1	0.0
Actual(MU)	279.8	-411.0	134.1	-27.8	22.2	-2.6
O/D/U/D(MU)	-7.5	-33.3	15.5	19.4	3.2	-2.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2059	3731	3252	3266	351	12660	42
State Sector	5133	5389	4778	2281	110	17691	58
Total	7192	9120	8030	5547	461	30351	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	873	1705	741	732	13	4064	74
Lignite	20	20	59	0	0	99	2
Hydro	295	52	33	27	14	420	8
Nuclear	28	64	51	0	0	143	3
Gas, Naptha & Diesel	63	110	10	0	24	208	4
RES (Wind, Solar, Biomass & Others)	215	149	167	4	1	536	10
Total	1493	2101	1061	762	53	5470	100
Share of RES in total generation (%)	14.40	7.08	15.74	0.49	2.37	9.79	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.99	12.61	23.66	3.97	29.63	20.10	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.049

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226371	14:31	0
Non-Solar hr	217683	22:42	1219

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 17-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	734	290	0.8	0.0	0.8
4	765 kV	SASARAM-FATEHPUR	1	140	279	0.0	3.1	-3.1
5	765 kV	GAYA-BALIA	1	0	688	0.0	12.2	-12.2
6	400 kV	PUSAULI-VARANASI	1	0	75	0.0	0.8	-0.8
7	400 kV	PUSAULI -ALLAHABAD	1	70	0	0.8	0.0	0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	431	312	0.8	0.0	0.8
9	400 kV	PATNA-BALIA	2	212	530	0.0	5.8	-5.8
10	400 kV	NAUBATPUR-BALIA	2	174	336	0.0	1.1	-1.1
11	400 kV	BIHARSHARIFF-BALIA	2	412	0	4.1	0.0	4.1
12	400 kV	MOTIHARI-GORAKHPUR	2	124	278	0.0	3.0	-3.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	26	70	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						7.2	26.8	-19.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1426	19	19.0	0.0	19.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1692	0	28.2	0.0	28.2
3	765 kV	JHARSUGUDA-DURG	2	0	1129	0.0	18.8	-18.8
4	400 kV	JHARSUGUDA-RAIGARH	4	194	302	0.0	1.7	-1.7
5	400 kV	RANCHI-SIPAT	2	579	0	9.3	0.0	9.3
6	220 kV	BUDHIPADAR-RAIGARH	1	58	65	0.1	0.0	0.1
7	220 kV	BUDHIPADAR-KORBA	2	126	135	0.1	0.0	0.1
ER-WR						56.8	20.4	36.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	625	0.0	13.9	-13.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1484	0.0	29.8	-29.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2329	0.0	42.0	-42.0
4	400 kV	TALCHER-I/C	2	707	0	13.7	0.0	13.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	85.6	-85.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	113	188	2.0	0.3	1.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	258	384	0.0	2.6	-2.6
3	220 kV	ALIPURDUAR-SALAKATI	2	32	76	0.0	0.7	-0.7
ER-NER						2.0	3.6	-1.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	847	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5026	0.0	88.7	-88.7
2	HVDC	VINDHYACHAL B/B	-	50	28	0.3	0.0	0.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1661	0.0	37.9	-37.9
4	765 kV	GWALIOR-AGRA	2	0	2452	0.0	39.9	-39.9
5	765 kV	GWALIOR-PHAGI	2	135	1390	0.2	20.5	-20.3
6	765 kV	JABALPUR-ORAI	2	0	1122	0.0	32.5	-32.5
7	765 kV	GWALIOR-ORAI	1	634	0	11.7	0.0	11.7
8	765 kV	SATNA-ORAI	1	0	1123	0.0	22.5	-22.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1203	969	7.7	3.2	4.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3511	0.0	71.6	-71.6
11	400 kV	ZERDA-KANKROLI	1	235	167	2.1	0.5	1.6
12	400 kV	ZERDA -BHINMAL	1	235	166	2.1	0.5	1.6
13	400 kV	VINDHYACHAL -RIHAND	1	954	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	310	385	1.3	2.7	-1.4
15	400 kV	NEEMUCH-Chittorgarh	2	306	409	1.2	3.2	-2.0
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.4	-2.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.6	-2.6
18	220 kV	MEHGAON-AURAIYA	1	62	0	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	40	9	0.4	0.0	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						49.5	328.7	-279.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	306	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2001	0.0	40.5	-40.5
3	765 kV	SOLAPUR-RAICHUR	2	284	1028	0.2	9.2	-9.1
4	765 kV	WARDHA-NIZAMABAD	2	0	1578	0.0	27.0	-27.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1883	0.0	30.5	-30.5
6	400 kV	KOLHAPUR-KUDGI	2	1073	0	16.0	0.0	16.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	96	1.8	0.0	1.8
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
WR-SR						20.1	114.4	-94.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	315	10	111	2.66
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	264	-124	6	0.15
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-296	1	-200	-4.79
	NER	132kV GELEPHU-SALAKATI	-21	7	-5	-0.13
	NER	132kV MOTANGA-RANGIA	49	0	35	0.83
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	-47	-1.14
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-49	-1.18
	ER	NEPAL IMPORT (FROM BIHAR)	-300	-16	-142	-3.41
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-513	-11	-248	-5.94
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-953	-641	-859	-20.62
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1064	-60	-521	-12.51
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-120	0	-108	-2.58

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	3.59	0.00	0.00	0.00	0.00	0.00	3.59
Nepal	0.35	0.00	5.54	0.00	0.00	0.00	0.00	0.00	5.89
Bangladesh	20.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.66
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.01	0.00	9.13	0.00	0.00	0.00	0.00	0.00	30.14

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.42
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.42

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.42	0.00	-3.59	0.00	0.00	0.00	0.00	0.00	-2.17
Nepal	-0.35	0.00	-5.54	0.00	0.00	0.00	0.00	0.00	-5.89
Bangladesh	-20.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.66
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.59	0.00	-9.13	0.00	0.00	0.00	0.00	0.00	-28.72