



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59934	63681	44502	23053	2665	193835
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1296	1550	1128	475	50	4499
Hydro Gen (MU)	111	37	63	23	13	248
Wind Gen (MU)	6	65	38	-	-	109
Solar Gen (MU)*	179.89	159.15	163.68	4.27	1.01	508
Energy Shortage (MU)	0.36	0.00	0.00	0.48	0.00	0.84
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	70606	79718	57641	23804	2740	231836
Time Of Maximum Demand Met	09:44	10:12	09:40	18:20	17:31	09:53

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.045	0.50	1.30	4.05	5.84	82.48	11.68

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9498	0	166.5	79.7	-2.1	411	0.00
	Haryana	8469	0	157.8	104.6	-1.3	238	0.00
	Rajasthan	18602	0	332.8	133.5	-0.9	664	0.00
	Delhi	5367	0	87.5	79.5	-0.6	479	0.00
	UP	21826	0	397.3	86.4	0.7	713	0.00
	Uttarakhand	2510	0	44.8	35.8	-0.4	171	0.00
	HP	2034	0	36.0	30.7	-1.6	56	0.00
	J&K(UT) & Ladakh(UT)	3183	136	64.9	61.9	-1.8	166	0.36
	Chandigarh	260	0	4.4	4.5	-0.1	14	0.00
	Railways NR ISTS	180	0	3.6	3.7	-0.1	43	0.00
WR	Chhattisgarh	5497	0	111.4	55.0	-0.9	340	0.00
	Gujarat	23226	0	428.8	195.9	-6.3	1062	0.00
	MP	19522	0	347.0	208.6	0.0	592	0.00
	Maharashtra	28762	0	579.5	168.9	-4.9	706	0.00
	Goa	653	0	13.2	11.9	0.9	57	0.00
	DNHDDPDCL	1274	0	29.1	29.3	-0.2	97	0.00
	AMNSIL	952	0	21.7	13.9	0.7	300	0.00
	BALCO	601	0	14.4	14.5	-0.1	14	0.00
	RIL JAMNAGAR	238	0	5.3	5.3	0.0	0	0.00
	Andhra Pradesh	11549	0	215.1	71.7	-1.1	489	0.00
SR	Telangana	15191	0	264.9	125.5	-1.8	503	0.00
	Karnataka	15803	0	284.7	102.9	-2.2	430	0.00
	Kerala	4026	0	76.2	62.2	0.3	404	0.00
	Tamil Nadu	13972	0	279.8	154.7	-0.9	839	0.00
	Puducherry	321	0	7.1	6.7	-0.2	27	0.00
	Bihar	5990	0	110.6	88.7	-0.6	365	0.21
	DVC	3139	0	68.3	-19.9	-0.8	344	0.00
ER	Jharkhand	2126	0	39.4	31.6	0.1	389	0.27
	Odisha	5558	0	99.3	9.0	-2.8	358	0.00
	West Bengal	7473	0	155.5	38.3	-1.8	150	0.00
	Sikkim	98	0	1.7	1.6	0.1	23	0.00
	Railways ER ISTS	21	0	0.2	0.2	0.0	0	0.00
	Arunachal Pradesh	182	0	3.3	3.2	-0.1	19	0.00
	Assam	1488	0	27.5	21.6	-0.1	126	0.00
NER	Manipur	254	0	3.8	3.9	-0.1	35	0.00
	Meghalaya	333	0	6.1	5.9	-0.1	51	0.00
	Mizoram	127	0	2.1	2.1	-0.3	19	0.00
	Nagaland	162	0	2.5	2.5	-0.1	7	0.00
	Tripura	223	0	4.5	4.9	0.2	48	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-15.5	-6.6	-23.2	-17.1
Day Peak (MW)	-990.5	-527.5	-1032.6	-774.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	234.8	-213.4	142.8	-173.2	9.0	0.0
Actual(MU)	226.9	-210.4	128.4	-171.9	6.3	-20.6
O/D/U/D(MU)	-7.9	3.1	-14.4	1.3	-2.6	-20.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6010	9632	5198	4202	604	25646	48
State Sector	7864	10187	6235	3679	205	28170	52
Total	13874	19819	11433	7881	809	53816	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	767	1540	666	716	13	3702	75
Lignite	20	19	43	0	0	82	2
Hydro	111	37	63	23	13	248	5
Nuclear	53	55	66	0	0	173	4
Gas, Naptha & Diesel	9	11	9	0	22	51	1
RES (Wind, Solar, Biomass & Others)	211	227	232	8	1	679	14
Total	1171	1888	1079	747	48	4934	100
Share of RES in total generation (%)	18.05	12.02	21.45	1.12	2.10	13.76	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.04	16.88	33.40	4.18	29.53	22.29	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.038

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231836	9:53	410
Non-Solar hr	199807	18:44	0

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 19-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	310	1195	0.0	17.7	-17.7
4	765 kV	SASARAM-FATEHPUR	1	135	571	0.0	8.0	-8.0
5	765 kV	GAYA-BALIA	1	0	833	0.0	13.7	-13.7
6	400 kV	PUSAULI-VARANASI	1	0	103	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	7	81	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	393	565	0.0	8.3	-8.3
9	400 kV	PATNA-BALIA	2	0	1092	0.0	18.3	-18.3
10	400 kV	NAUBATPUR-BALIA	2	85	297	0.0	6.3	-6.3
11	400 kV	BIHARSHARIEFF-BALIA	2	239	263	0.0	1.9	-1.9
12	400 kV	MOTIHARI-GORAKHPUR	2	47	580	0.0	8.6	-8.6
13	400 kV	BIHARSARIEFF-SAHUPURI	2	129	379	0.0	4.5	-4.5
14	220 kV	SAHUPURI-KARAMNASHA	1	22	20	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASHA-CHANDAULI	1	0	36	0.0	0.8	-0.8
ER-NR						0.1	94.1	-94.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1627	0.0	26.8	-26.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1564	256	12.4	0.0	12.4
3	765 kV	JHARSUGUDA-DURG	2	0	1220	0.0	22.8	-22.8
4	400 kV	JHARSUGUDA-RAIGARH	4	192	359	0.0	2.6	-2.6
5	400 kV	RANCHI-SIPAT	2	353	158	1.0	0.0	1.0
6	400 kV	JEYPORE-JAGDALPUR	2	158	271	0.0	0.9	-0.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	136	0.0	1.9	-1.9
8	220 kV	BUDHIPADAR-KORBA	2	55	120	0.0	0.7	-0.7
ER-WR						13.5	55.6	-42.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	118	0.0	2.8	-2.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1629	0.0	39.5	-39.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	1655	0.0	28.2	-28.2
4	400 kV	TALCHER-I/C	2	111	1229	0.0	14.0	-14.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	70.5	-70.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	151	0.0	2.5	-2.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	660	0	8.3	0.0	8.3
3	220 kV	ALIPURDUAR-SALAKATI	2	19	70	0.0	0.5	-0.5
ER-NER						8.3	3.0	5.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	566	0	13.3	0.0	13.3
NER-NR						13.3	0.0	13.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3032	0.0	65.8	-65.8
2	HVDC	VINDHYACHAL B/B	-	0	256	0.0	6.0	-6.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1919	0.0	37.4	-37.4
4	765 kV	GWALIOR-AGRA	2	0	1943	0.0	22.9	-22.9
5	765 kV	GWALIOR-PHAGI	2	146	2239	0.1	25.3	-25.2
6	765 kV	JABALPUR-ORAI	2	0	987	0.0	29.3	-29.3
7	765 kV	GWALIOR-ORAI	1	984	0	15.2	0.0	15.2
8	765 kV	SATNA-ORAI	1	0	916	0.0	17.0	-17.0
9	765 kV	BANASKANTHA-CHITORGARH	2	2025	279	25.2	0.3	24.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	2220	0.0	28.0	-28.0
11	400 kV	ZERDA-KANKROLI	1	328	0	5.1	0.0	5.1
12	400 kV	ZERDA -BHINMAL	1	226	0	3.5	0.0	3.5
13	400 kV	VINDHYACHAL -RIHAND	1	962	0	0.0	18.4	-18.4
14	400 kV	RAPP-SHUJALPUR	2	737	218	4.8	0.6	4.1
15	400 kV	NEEMUCH-Chittorgarh	2	585	424	2.4	2.9	-0.5
16	220 kV	BHANPURA-RANPUR	1	0	123	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	96	13	1.0	0.1	0.9
19	220 kV	MALANPUR-AURAIYA	1	66	25	0.5	0.1	0.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						57.7	257.6	-199.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	812	0.0	16.3	-16.3
2	HVDC	RAIGARH-PUGALUR	2	0	3007	0.0	50.0	-50.0
3	765 kV	SOLAPUR-RAICHUR	2	2120	899	12.7	4.5	8.2
4	765 kV	WARDHA-NIZAMABAD	2	288	2001	0.1	23.9	-23.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2452	0.0	33.9	-33.9
6	400 kV	KOLHAPUR-KUDGI	2	1782	0	25.8	0.0	25.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	106	1.4	0.0	1.4
WR-SR						40.0	128.6	-88.6
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-298	26	-185	-4.43		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-301	179	-137	-3.29		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-290	-182	-254	-6.10		
	NER	132kV GELEPHU-SALAKATI	-64	-30	-50	-1.20		
	NER	132kV MOTANGA-RANGIA	-23	0	-15	-0.35		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-61	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-61	0	-43	-1.04		
	ER	NEPAL IMPORT (FROM BIHAR)	-175	-75	-104	-2.50		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-339	94	-126	-3.02		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-924	-462	-870	-20.89		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-774	-424	-712	-17.09		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-172	0	-98	-2.36		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 19-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	16.83	0.00	0.00	0.00	0.00	0.00	17.14
Nepal	2.82	1.75	0.00	0.00	0.00	2.44	0.00	0.00	7.01
Bangladesh	21.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.76
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.58	2.06	16.83	0.00	0.00	2.44	0.00	0.00	45.91

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39
Nepal	0.00	0.00	0.00	0.00	0.00	0.33	0.00	0.00	0.33
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.39	0.00	0.00	0.00	0.00	0.33	0.00	0.00	0.72

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	-0.31	-16.83	0.00	0.00	0.00	0.00	0.00	-16.75
Nepal	-2.82	-1.75	0.00	0.00	0.00	-2.11	0.00	0.00	-6.68
Bangladesh	-21.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.76
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.19	-2.06	-16.83	0.00	0.00	-2.11	0.00	0.00	-45.19

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												Date of Reporting: 19-Jan-2026
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I)=(A-(C+D))	(J)=B+C+D+E+F+G+H	(K)
0:00	50.04	159000	6432	5857	0	5629	1891	141410	3403	153143	164622	-2082
0:15	49.92	159071	6451	5700	0	5882	1933	141536	3371	153371	164873	-2066
0:30	49.94	158700	6447	5497	0	6384	1927	140809	3383	153203	164447	-2049
0:45	49.92	158112	6442	5369	0	6250	1947	140535	3424	152743	163967	-2027
1:00	50.00	156907	6440	5220	0	6303	1948	139484	3351	151687	162746	-2011
1:15	49.93	156055	6447	5166	0	5888	1952	138912	3432	150889	161797	-2016
1:30	49.97	155106	6443	5120	0	5661	1948	138518	3399	149986	161089	-2017
1:45	49.97	154917	6451	4996	0	5495	1945	138601	3384	149921	160872	-1995
2:00	50.00	153830	6450	4958	0	5617	1951	137423	3396	148872	159795	-1988
2:15	49.91	153455	6453	4905	0	5223	1951	137455	3417	148550	159404	-1964
2:30	49.95	153646	6444	4994	0	5215	1952	137634	3382	148652	159621	-1983
2:45	49.98	153607	6449	5093	0	5180	1939	137632	3363	148514	159656	-2002
3:00	50.02	153056	6466	5123	0	5034	1957	137264	3389	147933	159233	-1983
3:15	49.97	153444	6452	5185	0	4862	1962	137837	3378	148259	159676	-1977
3:30	49.98	153554	6452	5174	0	5034	1940	137803	3407	148380	159810	-1973
3:45	49.95	153956	6462	5050	0	4971	1948	138399	3409	148906	160239	-1949
4:00	50.04	154306	6471	5053	0	5171	1968	138525	3398	149253	160586	-1943
4:15	49.93	156343	6467	5095	0	5308	1990	140171	3446	151248	162477	-1936
4:30	50.00	157795	6468	5110	0	6205	2029	140913	3457	152685	164182	-1863
4:45	49.95	159526	6459	5068	0	6719	2034	142197	3457	154458	165934	-1914
5:00	50.05	161529	6469	5026	48	6883	2056	143976	3527	156455	167985	-1905
5:15	50.03	165437	6459	5141	75	6979	2108	147970	3437	160221	172169	-1939
5:30	50.05	168974	6442	5045	81	7170	2101	151069	3507	163848	175415	-1998
5:45	50.06	171655	6441	5089	81	7638	2092	153261	3555	166485	178157	-1961
6:00	50.09	173567	6474	4879	88	8369	2086	154841	3531	168600	180268	-2008
6:15	49.97	177384	6452	4645	100	9066	2025	157958	3544	172639	183790	-1962
6:30	50.04	183046	6440	4724	104	11075	1956	161861	3510	178218	189670	-1914
6:45	50.03	188708	6452	4810	127	13911	1929	163992	3563	183771	194784	-1309
7:00	50.08	194364	6465	4804	376	16900	2012	166012	3569	189184	200138	-1148
7:15	50.02	199256	6455	4626	1167	20144	2032	167081	3607	193463	205112	-1159
7:30	50.02	203643	6456	4590	2722	21404	1998	168533	3600	196331	209303	-1184
7:45	50.02	207091	6468	4540	5298	21332	1997	169713	3630	197253	212978	-1234
8:00	50.05	209501	6468	4318	9098	20120	1924	169416	3546	196085	214890	-1198
8:15	50.04	213788	6471	4433	13653	19968	1918	169087	3511	195702	219041	-1192
8:30	50.03	216513	6466	3902	19307	18837	1875	167133	3514	193304	221034	-1167
8:45	49.99	220277	6466	3665	24960	18308	1881	165806	3570	191652	224656	-1211
9:00	49.97	221808	6483	3261	30620	14892	1887	164771	3567	187927	225481	-1202
9:15	49.81	226556	6466	2864	36154	14493	1891	164498	3535	187538	229901	-1223
9:30	49.87	229181	6461	2467	41231	13424	1933	163547	3524	185483	232587	-1423
9:45	50.00	231558	6463	2288	46397	12315	1891	162446	3465	182873	235265	-1632
10:00	49.97	231020	6480	2285	50644	11036	1878	158804	3471	178091	234598	-1784
10:15	50.00	230208	6463	2311	55364	9387	1867	155576	3502	172533	234470	-1794
10:30	50.00	229810	6467	2410	58866	9254	1856	151542	3517	168534	233912	-2029
10:45	50.06	228644	6456	2562	62229	8782	1871	147594	3519	163853	233013	-2308
11:00	50.17	226583	6439	2804	64999	7833	1859	143688	3486	158780	231108	-2351
11:15	50.12	224158	6448	2896	66717	6978	1836	140024	3518	154545	228417	-2331
11:30	50.10	223036	6449	2936	68692	6840	1885	136811	3585	151408	227198	-2360
11:45	50.05	221040	6460	2753	70129	6164	1855	134349	3596	148158	225306	-2410
12:00	50.04	217909	6459	2652	70916	5990	1844	130641	3487	144341	221989	-2405
12:15	50.02	215671	6431	2628	71382	5525	1849	128286	3533	141661	219634	-2352
12:30	50.04	214357	6443	2652	72121	5556	1848	126312	3526	139584	218458	-2362
12:45	49.98	213787	6446	2544	71866	5548	1852	125871	3443	139377	217570	-2393
13:00	50.00	211937	6442	2500	71388	5549	1859	124712	3454	138049	215904	-2391
13:15	49.98	208065	6442	2563	71033	5296	1860	121435	3483	134469	212112	-2377
13:30	50.03	206435	6441	2606	70699	5471	1894	119586	3532	133130	210229	-2354
13:45	49.98	205212	6435	2607	69540	5539	1901	119626	3481	133065	209129	-2340
14:00	50.05	203554	6431	2588	67737	5712	1902	119530	3488	133229	207388	-2333
14:15	50.03	202229	6431	2575	66490	5551	1860	119602	3485	133164	205994	-2363
14:30	50.00	202613	6426	2597	64553	5477	1860	122005	3470	135463	206388	-2352
14:45	50.04	202126	6429	2625	62798	5059	1856	123834	3467	136703	206068	-2366
15:00	50.09	201117	6419	2724	59906	4983	1850	125806	3474	138487	205162	-2371
15:15	49.95	199075	6528	2781	56804	5227	1863	126257	3450	139490	202910	-2393
15:30	50.00	199385	6618	2777	53081	5445	1864	129923	3431	143527	203139	-2378
15:45	49.97	199058	6622	2743	48375	6029	1888	133830	3496	147940	202983	-2385
16:00	50.02	198135	6630	2747	43546	6350	1875	137228	3479	151842	201855	-2369
16:15	49.93	194646	6657	2812	38295	6399	1944	139218	3450	153539	198775	-2347
16:30	49.99	195782	6638	2804	32424	7502	1956	144930	3423	160554	199677	-2357
16:45	50.02	193794	6654	2827	26295	8418	1988	148030	3407	164672	197619	-2284
17:00	50.04	192105	6650	2787	19946	10099	1953	150958	3391	169372	195784	-2222
17:15	50.06	188313	6651	2868	13945	11883	1972	150862	3323	171500	191504	-1689
17:30	50.08	191071	6645	2957	8638	14936	1971	155763	3315	179476	194225	-1134
17:45	50.05	194500	6657	3047	4554	17125	1945	160796	3384	186899	197508	-1158
18:00	50.08	196999	6678	3222	1968	18848	1954	164098	3426	191809	200194	-1147
18:15	49.91	196699	6684	3448	541	19440	1950	164948	3326	192710	200337	-1154
18:30	49.92	198948	6684	3699	324	20571	1860	166239	3369	194925	202746	-1148
18:45	49.99	199559	6692	4019	217	20584	1865	166547	3380	195323	203304	-1172
19:00	50.04	198241	6708	4473	201	19489	1862	165760	3391	193567	201884	-1202
19:15	50.03	196227	6698	4619	232	17066	1873	165725	3448	191376	199661	-1133
19:30	50.04	193377	6709	4907	0	15509	1871	164132	3453	188470	196581	-1133
19:45	49.98	190313	6716	5170	0	14323	1870	162311	3434	185143	193824	-1149
20:00	49.97	187966	6723	5257	0	13922	1865	160111	3441	182709	191319	-1152
20:15	50.00	185388	6708	5365	0	13145	1871	158645	3384	180023	189118	-1352
20:30	49.99	183196	6725	5407	0	12704	1874	157374	3451	177789	187535	-1679
20:45	49.93	181155	6738	5382	0	11467	1868	156734	3506	175773	185695	-1653
21:00	49.88	177982	6740	5452	0	11497	1868	153491	3445	172530	182493	-1661
21:15	49.93	175494	6747	5437	0	11225	1874	151191	3446	170057	179920	-1662
21:30	49.99	172390	6756	5520	0	10539	1893	148847	3468	166870	177023	-1639
21:45	50.08	169741	6758	5666	0	8649	1885	147898	3443	164075	174299	-1473
22:00	50.09	165962	6782	5541	0	7982	1975	144757	3396	160421	170433	-1304
22:15	49.98	165886	6751	5565	0	8037	1986	144906	3390	160321	170635	-1579
22:30	50.04	163985	6769	5660	0	7729	1979	143325	3437	158325	168899	-1613
2												