



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 01.09.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 31.08.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 31-अगस्त-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 31.08.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 01-Sep-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	73978	58317	43898	28116	3436	207745
Peak Shortage (MW)	110	0	0	137	0	247
Energy Met (MU)	1618	1316	1043	622	65	4664
Hydro Gen (MU)	373	117	161	82	29	761
Wind Gen (MU)	4	70	218	-	-	292
Solar Gen (MU)*	137.08	85.03	73.00	3.10	0.63	299
Energy Shortage (MU)	0.15	0.00	0.00	0.47	0.00	0.62
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74868	59109	48970	28528	3478	206996
Time Of Maximum Demand Met	21:07	19:22	09:41	23:20	18:31	19:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.21	0.67	5.45	6.33	82.71	10.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	11986	0	249.3	154.9	0.0	834	0.00
	Haryana	11060	0	230.0	165.8	-1.3	240	0.00
	Rajasthan	12967	0	282.1	95.2	0.0	660	0.00
	Delhi	6246	0	128.6	114.0	2.2	452	0.00
	UP	28551	0	576.0	269.2	2.3	974	0.00
	Uttarakhand	2474	0	54.4	27.1	1.2	221	0.04
	HP	1702	0	36.1	1.9	0.0	83	0.00
	J&K(UT) & Ladakh(UT)	2620	0	50.2	24.7	1.4	346	0.11
	Chandigarh	345	0	7.0	6.6	0.4	86	0.00
WR	Railways_NR ISTS	213	0	4.2	3.9	0.4	44	0.00
	Chhattisgarh	5399	0	121.9	71.9	-1.4	217	0.00
	Gujarat	16418	0	353.7	176.2	-0.8	804	0.00
	MP	11636	0	252.7	135.6	0.0	606	0.00
	Maharashtra	23267	0	512.7	165.8	-4.6	802	0.00
	Goa	653	0	14.0	13.8	-0.1	43	0.00
	DNHDDPDCL	1291	0	30.0	30.4	-0.4	35	0.00
	AMNSIL	825	0	18.1	9.0	0.2	42	0.00
	BALCO	526	0	12.6	12.6	0.0	8	0.00
SR	Andhra Pradesh	8237	0	181.9	34.8	-0.9	885	0.00
	Telangana	11267	0	223.2	99.6	-1.5	384	0.00
	Karnataka	11694	0	210.3	51.9	-0.9	1117	0.00
	Kerala	3834	0	78.9	49.4	-0.1	250	0.00
	Tamil Nadu	15835	0	338.4	134.9	-5.6	580	0.00
	Puducherry	440	0	10.1	9.6	-0.2	37	0.00
ER	Bihar	7815	90	163.7	150.0	1.9	422	0.47
	DVC	3385	0	73.5	-42.0	0.1	503	0.00
	Jharkhand	2131	0	44.5	34.0	0.7	260	0.00
	Odisha	5414	0	114.5	37.2	-2.3	561	0.00
	West Bengal	10527	0	224.3	100.4	-2.5	290	0.00
	Sikkim	89	0	1.4	1.6	-0.2	36	0.00
	Railways_ER ISTS	13	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	174	0	3.0	2.8	-0.2	47	0.00
	Assam	2318	0	44.1	36.7	0.1	195	0.00
	Manipur	210	0	1.4	2.9	-1.5	63	0.00
	Meghalaya	323	0	5.7	2.4	0.0	119	0.00
	Mizoram	136	0	1.9	0.5	-0.1	18	0.00
	Nagaland	169	0	3.0	2.6	-0.1	21	0.00
	Tripura	319	0	6.1	5.4	0.5	65	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	31.9	18.5	-22.3	-29.3
Day Peak (MW)	1673.0	923.8	-989.0	-1535.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	308.1	-184.5	-46.9	-81.7	4.9	0.0
Actual(MU)	316.8	-182.4	-70.0	-74.6	5.3	-5.0
O/D/U/D(MU)	8.6	2.0	-23.1	7.1	0.4	-5.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2870	14113	3308	3286	280	23857	40
State Sector	5877	14551	11669	3569	155	35820	60
Total	8747	28664	14977	6855	435	59678	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	789	1217	571	673	15	3265	65
Lignite	26	9	50	0	0	86	2
Hydro	373	117	161	82	29	761	15
Nuclear	34	70	76	0	0	180	4
Gas, Naptha & Diesel	17	36	6	0	22	81	2
RES (Wind, Solar, Biomass & Others)	147	158	322	5	1	633	13
Total	1386	1608	1185	761	67	5006	100

Share of RES in total generation (%)	10.62	9.84	27.17	0.70	0.97	12.65
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.95	21.49	47.10	11.49	44.57	31.45

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.038
Based on State Max Demands	1.074

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	199907	10:58	0
Non-Solar hr	206996	19:43	367

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 01-Sep-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	700	0.0	16.3	-16.3
2	HVDC	PUSAULI B/B	-	0	112	0.0	2.8	-2.8
3	765 kV	GAYA-VARANASI	2	752	613	0.0	2.7	-2.7
4	765 kV	SASARAM-FATEHPUR	1	309	316	0.0	1.7	-1.7
5	765 kV	GAYA-BALIA	1	0	838	0.0	13.5	-13.5
6	400 kV	PUSAULI-VARANASI	1	0	184	0.0	2.9	-2.9
7	400 kV	PUSAULI -ALLAHABAD	1	73	43	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	32	654	0.0	8.0	-8.0
9	400 kV	PATNA-BALIA	2	81	771	0.0	11.4	-11.4
10	400 kV	NAUBATPUR-BALIA	2	77	225	0.0	2.9	-2.9
11	400 kV	BIHARSHARIFF-BALIA	2	303	113	1.3	0.0	1.3
12	400 kV	MOTIHARI-GORAKHPUR	2	65	399	0.0	5.1	-5.1
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	60	0.0	0.1	-0.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						2.0	67.3	-65.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	34	1613	0.0	15.7	-15.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2231	0	36.8	0.0	36.8
3	765 kV	JHARSUGUDA-DURG	2	90	395	0.0	4.7	-4.7
4	400 kV	JHARSUGUDA-RAIGARH	4	86	462	0.0	5.6	-5.6
5	400 kV	RANCHI-SIPAT	2	536	13	6.9	0.0	6.9
6	220 kV	BUDHIPADAR-RAIGARH	1	17	66	0.0	0.8	-0.8
7	220 kV	BUDHIPADAR-KORBA	2	41	144	0.0	1.8	-1.8
ER-WR						43.7	28.6	15.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	105	528	0.0	10.6	-10.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	793	0.0	19.3	-19.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	1843	0.0	20.8	-20.8
4	400 kV	TALCHER-I/C	2	1169	0	23.4	0.0	23.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	50.7	-50.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	409	0.0	6.4	-6.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	514	0.0	7.0	-7.0
3	220 kV	ALIPURDUAR-SALAKATI	2	0	109	0.0	1.7	-1.7
ER-NER						0.0	15.1	-15.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	503	0.0	12.1	-12.1
NER-NR						0.0	12.1	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3546	0.0	62.4	-62.4
2	HVDC	VINDHYACHAL B/B	-	0	103	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	0	0.0	0.0	0.0
4	765 kV	GWALIOR-AGRA	2	0	2548	0.0	38.6	-38.6
5	765 kV	GWALIOR-PHAGI	2	543	1697	1.1	22.8	-21.7
6	765 kV	JABALPUR-ORAI	2	0	1388	0.0	42.0	-42.0
7	765 kV	GWALIOR-ORAI	1	685	0	11.5	0.0	11.5
8	765 kV	SATNA-ORAI	1	0	1029	0.0	19.1	-19.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1103	337	7.9	0.5	7.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3521	0.0	64.1	-64.1
11	400 kV	ZERDA-KANKROLI	1	190	67	1.3	0.3	1.0
12	400 kV	ZERDA -BHINMAL	1	505	151	3.9	0.7	3.2
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	240	617	0.8	6.0	-5.2
15	400 kV	NEEMUCH-Chittorgarh	2	173	749	0.1	8.3	-8.2
16	220 kV	BHANPURA-RANPUR	1	0	0	0.0	1.3	-1.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	73	15	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	47	33	0.3	0.1	0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						27.6	270.7	-243.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	669	0	12.1	0.0	12.1
2	HVDC	RAIGARH-PUGALUR	2	0	502	0.0	11.6	-11.6
3	765 kV	SOLAPUR-RAICHUR	2	2528	0	37.7	0.0	37.7
4	765 kV	WARDHA-NIZAMABAD	2	1022	1524	3.1	8.2	-5.1
5	765 kV	WARORA-WARANGAL(NEW)	2	1135	1391	5.2	5.6	-0.4
6	400 kV	KOLHAPUR-KUDGI	2	2257	0	41.2	0.0	41.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.2	0.0	2.2
WR-SR						101.4	25.5	76.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	719	457	548	13.15	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	705	585	615	14.75	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	73	73	73	1.85	
	NER	132kV GELEPHU-SALAKATI	40	18	28	0.68	
	NER	132kV MOTANGA-RANGIA	75	48	60	1.43	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	56	1.34	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	856	486	715	17.16	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-916	-671	-863	-20.70	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1535	-707	-1219	-29.26	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-73	0	-66	-1.58	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 01-Sep-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	21.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.36

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	29.78	0.00	1.30	0.00	0.00	0.05	0.00	0.00	31.13
Nepal	5.48	0.00	12.83	0.00	0.00	0.00	0.00	0.00	18.31
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	35.26	0.00	14.13	0.00	0.00	0.05	0.00	0.00	49.44

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	29.78	0.00	1.30	0.00	0.00	0.05	0.00	0.00	31.13
Nepal	5.48	0.00	12.83	0.00	0.00	0.00	0.00	0.00	18.31
Bangladesh	-21.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	13.90	0.00	14.13	0.00	0.00	0.05	0.00	0.00	28.08