



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53718	64959	44896	22240	2615	188428
Peak Shortage (MW)	0	0	0	0	33	33
Energy Met (MU)	1213	1583	1253	465	46	4561
Hydro Gen (MU)	99	41	70	22	8	240
Wind Gen (MU)	17	90	51	-	-	158
Solar Gen (MU)*	166.13	126.29	154.76	3.79	0.92	452
Energy Shortage (MU)	0.23	0.00	0.00	0.00	0.19	0.42
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65094	76385	61914	23541	2606	225222
Time Of Maximum Demand Met	10:11	10:28	09:30	18:55	18:03	10:12

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.047	0.00	0.29	7.55	7.83	70.58	21.58

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8839	0	155.1	92.0	-2.3	505	0.00
	Haryana	7769	0	148.5	91.2	-2.4	260	0.00
	Rajasthan	17967	0	347.3	115.7	-0.5	678	0.00
	Delhi	4096	0	68.7	56.7	-0.3	302	0.00
	UP	18800	18	348.1	107.1	0.9	684	0.23
	Uttarakhand	2179	0	40.0	30.6	-0.1	163	0.00
	HP	2017	0	37.1	31.7	-0.6	114	0.00
	J&K(UT) & Ladakh(UT)	2900	0	60.5	58.7	-1.7	522	0.00
	Chandigarh	201	0	3.5	3.5	0.0	35	0.00
WR	Railways_NR ISTS	205	0	4.5	3.9	0.6	41	0.00
	Chhattisgarh	5991	0	132.2	64.6	0.2	264	0.00
	Gujarat	21987	0	421.1	176.8	-1.2	646	0.00
	MP	17768	0	345.9	210.8	-3.2	613	0.00
	Maharashtra	28161	0	605.2	220.3	-4.5	659	0.00
	Goa	684	0	14.1	13.4	0.5	55	0.00
	DNHDDPDCL	1264	0	29.3	29.3	0.0	0	0.00
	AMNSIL	824	0	18.5	9.3	0.1	241	0.00
	BALCO	534	0	12.7	12.7	0.0	240	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12453	0	234.3	63.2	-0.4	424	0.00
	Telangana	15092	0	287.4	161.8	-0.2	1025	0.00
	Karnataka	16956	0	305.7	109.7	-0.8	765	0.00
	Kerala	4249	0	82.9	64.1	1.4	301	0.00
	Tamil Nadu	15519	0	334.5	181.7	-1.2	468	0.00
	Puducherry	372	0	8.5	8.1	-0.1	38	0.00
	Bihar	5112	0	99.1	89.9	-3.2	181	0.00
	DVC	3272	0	69.7	-38.1	-0.2	293	0.00
ER	Jharkhand	2024	0	39.1	28.0	-0.6	246	0.00
	Odisha	5114	0	102.1	32.2	-2.0	409	0.00
	West Bengal	7236	0	152.9	27.8	-1.2	89	0.00
	Sikkim	104	0	1.7	1.9	-0.2	8	0.00
	Railways_ER ISTS	21	0	0.1	0.1	0.0	0	0.00
	Arunachal Pradesh	208	0	3.5	3.4	0.1	19	0.00
NER	Assam	1472	0	25.8	20.4	-1.0	173	0.00
	Manipur	221	0	3.2	3.1	0.1	60	0.19
	Meghalaya	335	0	5.6	5.1	-0.1	61	0.00
	Mizoram	119	0	2.0	1.8	-0.4	15	0.00
	Nagaland	149	0	2.4	2.5	-0.1	19	0.00
	Tripura	225	0	3.9	3.3	0.1	43	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.8	-10.2	-23.2	-16.2
Day Peak (MW)	-555.0	-691.3	-1022.0	-769.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	206.9	-234.9	207.3	-186.4	7.1	0.0
Actual(MU)	199.9	-225.9	214.5	-200.5	7.2	-4.8
O/D/U/D(MU)	-7.0	9.0	7.2	-14.1	0.2	-4.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6035	7689	5168	2076	873	21840	46
State Sector	7458	9148	5957	2509	197	25268	54
Total	13493	16836	11125	4585	1069	47109	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	722	1598	676	734	12	3744	76
Lignite	24	12	58	0	0	94	2
Hydro	99	41	70	22	8	240	5
Nuclear	26	54	56	0	0	136	3
Gas, Naptha & Diesel	13	9	9	0	25	56	1
RES (Wind, Solar, Biomass & Others)	210	220	240	7	1	678	14
Total	1094	1934	1110	764	46	4948	100

Share of RES in total generation (%)	19.16	11.40	21.66	0.91	2.01	13.71
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.62	16.29	33.00	3.84	18.89	21.31

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.032

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	225222	10:12	18
Non-Solar hr	196286	18:55	39

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 17-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	0	670	0.0	19.5	-19.5
4	765 kV	SASARAM-FATEHPUR	1	0	662	0.0	11.6	-11.6
5	765 kV	GAYA-BALIA	1	0	472	0.0	9.9	-9.9
6	400 kV	PUSAULI-VARANASI	1	24	247	0.0	0.9	-0.9
7	400 kV	PUSAULI -ALLAHABAD	1	51	34	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	298	506	0.0	4.7	-4.7
9	400 kV	PATNA-BALIA	2	0	968	0.0	17.6	-17.6
10	400 kV	NAUBATPUR-BALIA	2	0	334	0.0	5.5	-5.5
11	400 kV	BIHARSHARIFF-BALIA	2	242	242	0.0	2.6	-2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	463	0.0	7.3	-7.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	7.9	-7.9
14	220 kV	SAHUPURI-KARAMNASHA	1	0	55	0.0	1.2	-1.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASHA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASHA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.9	89.8	-88.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	719	816	2.1	0.0	2.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	594	1083	0.0	10.9	-10.9
3	765 kV	JHARSUGUDA-DURG	2	0	1183	0.0	23.1	-23.1
4	400 kV	JHARSUGUDA-RAIGARH	4	0	924	0.0	14.4	-14.4
5	400 kV	RANCHI-SIPAT	2	152	271	0.0	2.8	-2.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	139	0.0	1.8	-1.8
7	220 kV	BUDHIPADAR-KORBA	2	76	104	0.2	0.0	0.2
ER-WR						2.3	53.0	-50.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	368	0.0	8.7	-8.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1643	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	3073	0.0	55.5	-55.5
4	400 kV	TALCHER-I/C	2	0	554	0.0	7.0	-7.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	104.0	-104.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	223	29	2.4	0.0	2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	406	19	4.6	0.0	4.6
3	220 kV	ALIPURDUAR-SALAKATI	2	109	0	1.7	0.0	1.7
ER-NER						8.8	0.0	8.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3025	0.0	52.9	-52.9
2	HVDC	VINDHYACHAL B/B	-	767	0	7.9	0.0	7.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.2	-36.2
4	765 kV	GWALIOR-AGRA	2	0	1606	0.0	18.9	-18.9
5	765 kV	GWALIOR-PHAGI	2	523	1645	0.9	22.1	-21.2
6	765 kV	JABALPUR-ORAI	2	0	862	0.0	21.7	-21.7
7	765 kV	GWALIOR-ORAI	1	837	0	14.7	0.0	14.7
8	765 kV	SATNA-ORAI	1	0	942	0.0	17.5	-17.5
9	765 kV	BANASKANTHA-CHITORGARH	2	962	182	9.2	0.1	9.1
10	765 kV	VINDHYACHAL-VARANASI	2	188	1431	0.0	13.0	-13.0
11	400 kV	ZERDA-KANKROLI	1	172	46	2.1	0.0	2.1
12	400 kV	ZERDA -BHINMAL	1	119	32	1.4	0.0	1.4
13	400 kV	VINDHYACHAL -RIHAND	1	491	0	10.6	0.0	10.6
14	400 kV	RAPP-SHUJALPUR	2	562	225	3.4	0.9	2.5
15	400 kV	NEEMUCH-Chittorgarh	2	556	265	3.3	0.9	2.3
16	220 kV	BHANPURA-RANPUR	1	0	195	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	116	0	1.9	0.0	1.9
19	220 kV	MALANPUR-AURAIYA	1	80	0	1.1	0.0	1.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						56.6	189.9	-133.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	510	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	3506	0.0	58.8	-58.8
3	765 kV	SOLAPUR-RAICHUR	2	1220	1501	3.6	10.6	-7.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2883	0.0	45.7	-45.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2904	0.0	45.6	-45.6
6	400 kV	KOLHAPUR-KUDGI	2	1488	0	22.8	0.0	22.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.3	0.0	2.3
WR-SR						28.6	172.7	-144.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	370	84	167	4.01	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-284	68	-155	-3.72	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-384	-212	-320	-7.68	
	NER	132kV GELEPHU-SALAKATI	-12	19	-1	-0.03	
	NER	132kV MOTANGA-RANGIA	-44	-2	-17	-0.41	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-44	-1.05	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-42	-1.01	
	ER	NEPAL IMPORT (FROM BIHAR)	-197	-50	-59	-1.43	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-494	-182	-280	-6.72	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-948	-756	-906	-21.74	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-769	-405	-674	-16.17	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-74	0	-61	-1.46	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	8.98	0.00	0.00	0.14	0.00	0.00	9.47
Nepal	3.91	0.00	4.94	0.00	0.00	2.70	0.00	0.00	11.55
Bangladesh	22.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.58
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.49	0.35	13.92	0.00	0.00	2.84	0.00	0.00	43.60

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.20
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.20

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.20	-0.35	-8.98	0.00	0.00	-0.14	0.00	0.00	-8.27
Nepal	-3.91	0.00	-4.94	0.00	0.00	-2.70	0.00	0.00	-11.55
Bangladesh	-22.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.58
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.29	-0.35	-13.92	0.00	0.00	-2.84	0.00	0.00	-42.40

