



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 07.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 06.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 6-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 06.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 07-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	65361	70468	49670	24002	2915	212416
Peak Shortage (MW)	313	0	0	360	0	673
Energy Met (MU)	1374	1569	1220	495	54	4711
Hydro Gen (MU)	115	42	98	22	13	289
Wind Gen (MU)	20	121	93	-	-	234
Solar Gen (MU)*	150.96	162.79	124.25	3.34	0.63	442
Energy Shortage (MU)	1.37	0.00	0.00	0.85	0.00	2.22
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74246	79702	61163	24966	2984	239195
Time Of Maximum Demand Met	11:27	09:50	09:42	17:47	17:15	10:12

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.12	1.19	4.78	6.09	76.03	17.88

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9751	0	172.9	80.9	0.1	545	0.00
	Haryana	9574	0	178.6	133.7	0.4	650	1.24
	Rajasthan	18046	0	338.1	112.2	0.4	1048	0.00
	Delhi	5736	0	96.3	83.6	3.2	584	0.00
	UP	22561	0	422.7	91.5	0.0	398	0.00
	Uttarakhand	2693	0	49.4	38.9	1.0	217	0.13
	HP	2207	0	40.9	34.0	-0.6	107	0.00
	J&K(UT) & Ladakh(UT)	3265	0	66.8	63.4	-1.2	264	0.00
	Chandigarh	291	0	5.0	4.9	0.1	23	0.00
	Railways_NR ISTS	185	0	3.6	3.6	0.0	37	0.00
WR	Chhattisgarh	5386	0	107.7	50.9	-1.4	329	0.00
	Gujarat	24046	0	443.0	178.1	-1.8	867	0.00
	MP	18763	0	341.9	207.9	0.0	866	0.00
	Maharashtra	28991	0	592.6	173.9	-10.2	848	0.00
	Goa	734	0	14.0	11.8	2.0	54	0.00
	DNHDDPDCL	1370	0	31.2	31.0	0.2	51	0.00
	AMNSIL	855	0	18.6	11.7	-0.2	333	0.00
	BALCO	612	0	14.4	14.5	-0.1	32	0.00
	RIL JAMNAGAR	225	0	5.1	5.2	-0.1	0	0.00
	Andhra Pradesh	11498	0	216.1	53.0	0.2	536	0.00
SR	Telangana	15231	0	261.8	97.8	-2.1	573	0.00
	Karnataka	16113	0	294.4	105.1	-0.2	680	0.00
	Kerala	4480	0	85.9	63.1	1.7	487	0.00
	Tamil Nadu	17329	0	353.1	215.1	3.2	1330	0.00
	Puducherry	411	0	8.9	8.4	-0.1	41	0.00
	Bihar	6444	0	119.0	106.6	0.4	423	0.85
ER	DVC	3272	0	67.5	-41.2	0.2	337	0.00
	Jharkhand	2319	0	43.6	29.7	0.4	225	0.00
	Odisha	5196	0	98.9	9.5	-2.2	329	0.00
	West Bengal	8017	0	164.0	25.6	-1.3	257	0.00
	Sikkim	114	0	1.9	1.8	0.1	21	0.00
	Railways_ER ISTS	11	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	198	0	3.6	3.3	0.2	30	0.00
	Assam	1638	0	30.1	24.1	0.3	85	0.00
	Manipur	247	0	4.0	4.0	0.0	40	0.00
	Meghalaya	373	0	6.6	5.7	0.0	27	0.00
	Mizoram	175	0	2.4	2.2	-0.1	41	0.00
	Nagaland	166	0	2.8	2.7	0.0	12	0.00
	Tripura	239	0	4.2	5.0	0.1	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-13.5	-6.5	-12.0	-25.8
Day Peak (MW)	-948.9	-643.3	-545.3	-1462.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	266.4	-222.1	152.8	-206.6	9.5	0.0
Actual(MU)	263.5	-238.9	151.4	-202.4	8.6	-17.8
O/D/U/D(MU)	-2.9	-16.8	-1.4	4.2	-0.9	-17.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6530	11659	6828	4822	295	30134	50
State Sector	8674	11403	7780	2359	205	30420	50
Total	15204	23061	14608	7181	500	60554	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	815	1507	691	751	15	3779	74
Lignite	27	19	42	0	0	88	2
Hydro	115	42	98	22	13	289	6
Nuclear	53	52	47	0	0	152	3
Gas, Naptha & Diesel	11	20	10	0	23	65	1
RES (Wind, Solar, Biomass & Others)	196	287	269	7	1	759	15
Total	1217	1927	1156	780	52	5132	100

Share of RES in total generation (%)	16.12	14.87	23.23	0.85	1.26	14.78
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.91	19.75	35.69	3.68	27.19	23.38

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	239195	10:12	0
Non-Solar hr	215345	18:31	912

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 07-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1243	0.0	19.9	-19.9
4	765 kV	SASARAM-FATEHPUR	1	71	401	0.0	7.1	-7.1
5	765 kV	GAYA-BALIA	1	0	794	0.0	13.5	-13.5
6	400 kV	PUSAULI-VARANASI	1	41	62	0.0	0.3	-0.3
7	400 kV	PUSAULI-ALLAHABAD	1	42	108	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	142	639	0.0	6.2	-6.2
9	400 kV	PATNA-BALIA	2	0	892	0.0	11.8	-11.8
10	400 kV	NAUBATPUR-BALIA	2	0	429	0.0	3.4	-3.4
11	400 kV	BIHARSHARIFF-BALIA	2	371	235	0.5	0.0	0.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	522	0.0	8.0	-8.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	57	406	0.0	4.9	-4.9
14	220 kV	SAHUPURI-KARMANASA	1	0	26	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-SAHUPURI	1	0	31	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	33	0.0	0.8	-0.8
ER-NR						0.6	80.1	-79.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1927	0.0	24.2	-24.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	537	1311	0.0	10.4	-10.4
3	765 kV	JHARSUGUDA-DURG	2	0	1275	0.0	23.6	-23.6
4	400 kV	JHARSUGUDA-RAIGARH	4	0	739	0.0	10.5	-10.5
5	400 kV	RANCHI-SIPAT	2	19	396	0.0	3.2	-3.2
6	400 kV	JEYPORE-JACDALPUR	2	259	239	1.0	0.0	1.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	160	0.0	2.8	-2.8
8	220 kV	BUDHIPADAR-KORBA	2	94	107	0.3	0.0	0.3
ER-WR						1.3	74.7	-73.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	316	0.0	7.5	-7.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1618	0.0	42.2	-42.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2863	0.0	47.4	-47.4
4	400 kV	TALCHER/UC	2	798	498	2.3	0.0	2.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	2	2	0.0	0.0	0.0
ER-SR						0.0	97.0	-97.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	195	173	0.6	1.2	-0.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	693	301	2.5	0.0	2.5
3	220 kV	ALIPURDUAR-SALAKATI	2	0	162	0.0	2.3	-2.3
ER-NER						3.2	3.6	-0.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	464	0	9.7	0.0	9.7
NER-NR						9.7	0.0	9.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3518	0.0	75.5	-75.5
2	HVDC	VINDHYACHAL B/B	-	94	107	0.9	1.6	-0.7
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1177	0.0	26.6	-26.6
4	765 kV	GWALIOR-AGRA	2	10	2320	0.0	30.6	-30.6
5	765 kV	GWALIOR-PHAGI	2	178	2143	0.1	31.2	-31.1
6	765 kV	JABALPUR-ORAI	2	0	1184	0.0	30.9	-30.9
7	765 kV	GWALIOR-ORAI	1	946	0	16.3	0.0	16.3
8	765 kV	SATNA-ORAI	1	0	1257	0.0	25.0	-25.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1725	777	10.9	3.8	7.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2349	0.0	35.4	-35.4
11	400 kV	ZERDA-KANKROLI	1	292	42	2.8	0.0	2.8
12	400 kV	ZERDA -BHINMAL	1	201	29	1.9	0.0	1.9
13	400 kV	VINDHYACHAL -RIHAND	1	965	0	22.0	0.0	22.0
14	400 kV	RAPP-SHUJALPUR	2	658	343	4.3	0.9	3.4
15	400 kV	NEEMUCH-Chittorgarh	2	548	598	2.8	2.3	0.6
16	220 kV	BHANPURA-RANPUR	1	0	121	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	101	7	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	74	21	0.5	0.1	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						63.5	267.4	-204.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	19.1	-19.1
2	HVDC	RAIGARH-PUGALUR	2	0	4511	0.0	73.8	-73.8
3	765 kV	SOLAPUR-RAICHUR	2	1958	1236	9.4	9.4	0.0
4	765 kV	WARDHA-NIZAMABAD	2	943	1879	3.0	20.6	-17.6
5	765 kV	WARORA-WARANGAL(NEW)	2	460	2477	0.5	29.1	-28.5
6	400 kV	KOLHAPUR-KUDGI	2	1994	0	29.6	0.0	29.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	1.9	0.0	1.9
WR-SR						44.5	151.9	-107.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-304	14	-197	-4.73	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-268	203	-98	-2.36	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-279	-113	-219	-5.25	
	NER	132kV GELEPHU-SALAKATI	-53	0	-37	-0.88	
	NER	132kV MOTANGA-RANGIA	-25	0	-10	-0.23	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-28	-0.66	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-44	-1.05	
	ER	NEPAL IMPORT (FROM BIHAR)	-175	0	-82	-1.96	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-369	-20	-117	-2.82	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-449	-280	-400	-9.59	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1462	-814	-1074	-25.78	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-120	0	-100	-2.40	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 07-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	14.34	0.00	0.00	0.38	0.00	0.00	15.03
Nepal	1.99	0.00	1.25	0.00	0.00	1.94	0.00	0.00	5.18
Bangladesh	10.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.04
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	12.03	0.31	15.59	0.00	0.00	2.32	0.00	0.00	30.25

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.18
Nepal	0.00	0.00	0.00	0.00	0.00	0.27	0.00	0.00	0.27
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.18	0.00	0.00	0.00	0.00	0.27	0.00	0.00	0.45

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.18	-0.31	-14.34	0.00	0.00	-0.38	0.00	0.00	-14.85
Nepal	-1.99	0.00	-1.25	0.00	0.00	-1.66	0.00	0.00	-4.90
Bangladesh	-10.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-10.04
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.85	-0.31	-15.59	0.00	0.00	-2.04	0.00	0.00	-29.79

