



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 18.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 17-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 18-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52838	61046	47236	21005	2749	184874
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1124	1386	1077	426	50	4062
Hydro Gen (MU)	127	31	97	35	17	306
Wind Gen (MU)	3	101	68	-	-	171
Solar Gen (MU)*	195.79	153.93	119.28	3.19	1.18	473
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58244	65705	53249	22032	2987	197064
Time Of Maximum Demand Met	18:24	09:39	11:57	17:48	17:20	09:51

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.029	0.00	0.20	1.35	1.55	80.49	17.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7434	0	141.9	46.1	-0.9	807	0.00
	Haryana	7604	0	146.6	121.5	-1.3	170	0.00
	Rajasthan	15968	0	301.9	101.6	-0.6	1090	0.00
	Delhi	4004	0	73.9	68.4	-0.4	295	0.00
	UP	17339	0	316.4	85.9	-3.3	636	0.00
	Uttarakhand	2182	0	38.7	28.0	0.2	144	0.00
	HP	2057	0	36.2	23.8	-0.7	200	0.00
	J&K(UT) & Ladakh(UT)	2944	0	61.2	55.8	-0.4	166	0.00
	Chandigarh	205	0	3.5	3.6	-0.1	46	0.00
	Railways_NR ISTS	200	0	4.3	3.9	0.4	35	0.00
WR	Chhattisgarh	4496	0	86.5	31.2	0.7	333	0.00
	Gujarat	20248	0	405.9	160.6	-6.7	625	0.00
	MP	16340	0	293.1	179.6	-0.4	561	0.00
	Maharashtra	25678	0	519.6	169.6	2.3	986	0.00
	Goa	684	0	13.2	11.0	1.8	50	0.00
	DNHDDPDCL	1321	0	29.2	29.3	-0.1	43	0.00
	AMNSIL	913	0	19.4	12.1	0.3	287	0.00
	BALCO	538	0	12.8	12.8	0.0	52	0.00
	RIL JAMNAGAR	257	0	6.0	6.1	-0.1	0	0.00
	Andhra Pradesh	9673	0	197.9	53.0	0.1	364	0.00
SR	Telangana	9834	0	175.4	87.2	0.7	538	0.00
	Karnataka	15228	0	275.5	99.7	1.6	952	0.00
	Kerala	4326	0	86.9	67.6	-0.1	174	0.00
	Tamil Nadu	16342	0	332.6	207.4	-2.1	586	0.00
	Puducherry	384	0	8.3	8.0	-0.2	40	0.00
	Bihar	4946	0	88.8	71.4	-0.4	317	0.00
ER	DVC	3008	0	62.2	-16.7	1.2	436	0.00
	Jharkhand	2009	0	36.8	28.7	-1.0	311	0.00
	Odisha	4765	0	91.1	18.2	-3.6	467	0.00
	West Bengal	7549	0	145.6	35.0	-1.9	191	0.00
	Sikkim	95	0	1.4	1.4	-0.1	17	0.00
	Railways_ER ISTS	16	0	0.1	0.1	-0.1	4	0.00
NER	Arunachal Pradesh	167	0	2.7	2.7	-0.2	22	0.00
	Assam	1732	0	28.8	21.9	0.1	91	0.00
	Manipur	237	0	3.0	3.2	-0.1	43	0.00
	Meghalaya	375	0	6.2	5.5	-0.1	49	0.00
	Mizoram	144	0	2.1	1.0	-0.2	13	0.00
	Nagaland	161	0	2.5	2.3	-0.1	18	0.00
	Tripura	256	0	4.3	5.8	0.3	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.5	17.9	-23.3	-15.9
Day Peak (MW)	277.6	893.4	-996.4	-1146.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	178.4	-193.1	173.7	-166.1	7.1	0.0
Actual(MU)	169.4	-184.0	165.3	-170.1	5.6	-14.0
O/D/U/D(MU)	-9.0	9.1	-8.4	-4.1	-1.5	-14.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6917	13511	6838	4850	587	32703	45
State Sector	12289	13677	9738	3347	306	39357	55
Total	19206	27188	16576	8197	893	72059	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	623	1289	588	621	12	3134	71
Lignite	27	18	44	0	0	90	2
Hydro	127	31	97	35	17	306	7
Nuclear	32	53	41	0	0	126	3
Gas, Naptha & Diesel	10	20	4	0	20	55	1
RES (Wind, Solar, Biomass & Others)	218	258	211	5	1	694	16
Total	1037	1670	987	661	50	4404	100

Share of RES in total generation (%)	21.04	15.46	21.40	0.79	2.36	15.75
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.29	20.47	35.43	6.06	35.44	25.55

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.026
Based on State Max Demands	1.074

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	197064	9:51	0
Non-Solar hr	195194	18:22	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godha (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 18-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	100	1254	0.0	16.3	-16.3
4	765 kV	SASARAM-FATEHPUR	1	0	609	0.0	8.2	-8.2
5	765 kV	GAYA-BALIA	1	0	599	0.0	8.7	-8.7
6	400 kV	PUSAULI-VARANASI	1	0	105	0.0	1.1	-1.1
7	400 kV	PUSAULI-ALLAHABAD	1	10	96	0.0	1.3	-1.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	822	0.0	10.9	-10.9
9	400 kV	PATNA-BALIA	2	0	885	0.0	11.2	-11.2
10	400 kV	NAUBATPUR-BALIA	2	132	195	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	159	281	0.0	1.4	-1.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	519	0.0	7.0	-7.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	88	427	0.0	4.8	-4.8
14	220 kV	SAHUPURI-KARMANASA	1	24	12	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.3	77.8	-77.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	357	1021	0.0	12.0	-12.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	464	827	0.0	5.2	-5.2
3	765 kV	JHARSUGUDA-DURG	2	0	1409	0.0	23.2	-23.2
4	400 kV	JHARSUGUDA-RAIGARH	4	198	335	0.0	1.9	-1.9
5	400 kV	RANCHI-SIPAT	2	157	341	0.0	2.8	-2.8
6	400 kV	JEYPORE-JACDALPUR	2	229	243	0.0	0.0	0.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	139	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	91	111	0.0	0.0	0.0
ER-WR						0.9	46.7	-45.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	530	0.0	6.2	-6.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1623	0.0	40.7	-40.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	3253	0.0	52.2	-52.2
4	400 kV	TALCHER/UC	2	378	973	0.0	1.8	-1.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	21	0	0.4	0.0	0.4
ER-SR						0.4	99.0	-98.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	275	79	3.0	0.1	3.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	478	108	4.8	0.0	4.8
3	220 kV	ALIPURDUAR-SALAKATI	2	77	15	0.8	0.0	0.8
ER-NER						8.6	0.1	8.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1998	0.0	47.9	-47.9
2	HVDC	VINDHYACHAL B/B	-	198	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	982	0.0	14.8	-14.8
4	765 kV	GWALIOR-AGRA	2	0	1761	0.0	21.0	-21.0
5	765 kV	GWALIOR-PHAGI	2	604	2235	1.8	26.1	-24.4
6	765 kV	JABALPUR-ORAI	2	141	736	0.0	19.5	-19.5
7	765 kV	GWALIOR-ORAI	1	1095	0	15.0	0.0	15.0
8	765 kV	SATNA-ORAI	1	0	1041	0.0	17.2	-17.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2193	478	21.7	0.6	21.1
10	765 kV	VINDHYACHAL-VARANASI	2	92	1641	0.0	20.8	-20.8
11	400 kV	ZERDA-KANKROLI	1	373	0	4.5	0.0	4.5
12	400 kV	ZERDA -BHINMAL	1	257	0	3.1	0.0	3.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	638	299	4.1	1.2	2.9
15	400 kV	NEEMUCH-Chittorgarh	2	712	344	4.3	2.2	2.2
16	220 kV	BHANPURA-RANPUR	1	0	124	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	120	0	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	99	9	0.4	0.0	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						60.4	174.7	-114.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	992	0.0	16.2	-16.2
2	HVDC	RAIGARH-PUGALUR	2	0	3004	0.0	49.0	-49.0
3	765 kV	SOLAPUR-RAICHUR	2	472	2164	0.0	10.1	-10.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2689	0.0	28.6	-28.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3020	0.0	35.3	-35.3
6	400 kV	KOLHAPUR-KUDGI	2	1355	0	22.3	0.0	22.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	2	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	0.0	0.0	0.0
WR-SR						24.3	139.2	-114.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	209	95	182	4.36	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	361	151	246	5.91	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-210	-118	-158	-3.79	
	NER	132kV GELEPHU-SALAKATI	-73	-53	-63	-1.50	
	NER	132kV MOTANGA-RANGIA	-27	1	-18	-0.43	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	61	0	49	1.18	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	769	617	696	16.70	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-885	-878	-881	-21.14	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1147	-373	-663	-15.92	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-115	0	-91	-2.18	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 18-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.37	0.00	0.00	0.00	0.00	0.00	0.00	0.37
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	21.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.96
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.96	0.37	0.00	0.00	0.00	0.00	0.00	0.00	22.33

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	12.69	0.00	0.00	0.00	3.64	0.00	0.00	16.33
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	12.69	0.00	0.00	0.00	3.64	0.00	0.00	16.33

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	-0.37	0.00	0.00	0.00	0.00	0.00	0.00	-0.37	
Nepal	0.00	0.00	12.69	0.00	0.00	0.00	3.64	0.00	0.00	16.33
Bangladesh	-21.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.96
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.96	-0.37	12.69	0.00	0.00	0.00	3.64	0.00	0.00	-6.00

