



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 09.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 08.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 8-फ़रवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 08.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 09-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54650	64806	47815	23308	2683	193262
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1198	1565	1221	493	50	4527
Hydro Gen (MU)	111	31	75	24	11	252
Wind Gen (MU)	9	46	62	-	-	117
Solar Gen (MU)*	227.45	188.31	166.43	4.53	0.96	588
Energy Shortage (MU)	0.10	0.00	0.00	0.20	0.00	0.30
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64026	79788	61274	24039	2725	226841
Time Of Maximum Demand Met	10:39	10:11	09:29	18:16	18:03	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.060	0.00	0.00	4.83	4.83	79.70	15.47

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8432	0	150.8	58.9	-1.6	444	0.00
	Haryana	7473	0	143.7	98.5	-1.8	191	0.00
	Rajasthan	18048	0	335.9	105.5	-2.9	974	0.00
	Delhi	4458	0	76.4	67.4	-0.2	481	0.00
	UP	18835	0	345.4	58.8	0.8	447	0.00
	Uttarakhand	2347	0	41.7	33.8	0.3	161	0.00
	HP	2043	0	35.7	28.8	-0.7	46	0.00
	J&K(UT) & Ladakh(UT)	2942	0	60.2	55.2	-0.4	136	0.10
	Chandigarh	224	0	3.6	3.6	0.0	16	0.00
	Railways_NR ISTS	198	0	4.2	3.7	0.5	51	0.00
WR	Chhattisgarh	5865	0	121.7	56.5	-0.6	375	0.00
	Gujarat	23377	0	437.9	208.9	-1.3	903	0.00
	MP	18251	0	328.1	204.3	0.0	653	0.00
	Maharashtra	28498	0	595.0	188.9	-7.2	677	0.00
	Goa	667	0	13.7	11.1	2.3	44	0.00
	DNHDDPDCL	1301	0	30.0	30.0	0.0	38	0.00
	AMNSIL	790	0	17.7	13.7	0.8	254	0.00
	BALCO	601	0	14.4	14.5	-0.1	30	0.00
	RIL JAMNAGAR	267	0	6.4	6.4	0.0	0	0.00
	Andhra Pradesh	12653	0	232.6	79.3	-1.0	680	0.00
SR	Telangana	15515	0	275.5	135.0	-0.2	760	0.00
	Karnataka	16460	0	301.2	113.2	-0.6	555	0.00
	Kerala	4259	0	81.0	64.5	1.2	292	0.00
	Tamil Nadu	15153	0	322.2	176.6	-3.1	900	0.00
	Puducherry	373	0	8.3	7.9	-0.2	29	0.00
	Bihar	5685	0	108.7	85.3	2.2	247	0.20
ER	DVC	3230	0	69.5	-31.9	1.1	334	0.00
	Jharkhand	2076	0	38.8	27.7	0.9	200	0.00
	Odisha	5588	0	112.9	20.9	-2.6	371	0.00
	West Bengal	7609	0	161.5	58.3	-2.3	265	0.00
	Sikkim	101	0	1.7	1.7	0.0	13	0.00
	Railways_ER ISTS	15	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	177	0	3.5	3.2	0.2	12	0.00
	Assam	1649	0	28.5	22.4	0.3	140	0.00
	Manipur	238	0	4.1	3.9	0.2	23	0.00
	Meghalaya	348	0	6.3	5.6	0.0	33	0.00
	Mizoram	119	0	2.5	2.0	0.2	15	0.00
	Nagaland	155	0	2.8	2.5	0.2	16	0.00
	Tripura	224	0	2.5	4.8	-1.3	60	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-14.9	-10.4	-24.8	-16.1
Day Peak (MW)	-1070.0	-774.0	-1049.9	-736.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	124.0	-152.6	160.0	-147.5	16.2	0.0
Actual(MU)	110.5	-135.6	143.7	-144.7	15.0	-11.2
O/D/U/D(MU)	-13.4	17.0	-16.3	2.8	-1.3	-11.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5820	11708	2858	2494	969	23848	44
State Sector	8314	12158	6056	3730	205	30463	56
Total	14134	23866	8914	6224	1174	54311	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	724	1451	698	710	7	3591	73
Lignite	27	18	46	0	0	91	2
Hydro	111	31	75	24	11	252	5
Nuclear	43	65	71	0	0	178	4
Gas, Naptha & Diesel	10	16	9	0	22	56	1
RES (Wind, Solar, Biomass & Others)	262	237	263	7	1	770	16
Total	1178	1818	1161	741	41	4939	100

Share of RES in total generation (%)	22.26	13.06	22.76	0.95	2.33	15.62
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.35	18.33	35.38	4.18	29.58	24.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.022
Based on State Max Demands	1.041

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226841	9:43	98
Non-Solar hr	199409	18:51	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 09-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	533	1593	0.0	18.2	-18.2
4	765 kV	SASARAM-FATEHPUR	1	251	646	0.0	6.1	-6.1
5	765 kV	GAYA-BALIA	1	55	767	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	140	0.0	1.6	-1.6
7	400 kV	PUSAULI-ALLAHABAD	1	50	100	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	721	572	0.0	0.6	-0.6
9	400 kV	PATNA-BALIA	2	223	1026	0.0	12.0	-12.0
10	400 kV	NAUBATPUR-BALIA	2	222	230	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	599	216	2.7	0.0	2.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	354	0.0	5.4	-5.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	289	516	0.0	4.2	-4.2
14	220 kV	SAHUPURI-KARAMNANA	1	17	17	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.2	0.0	0.2
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						3.5	66.6	-63.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	906	1425	0.0	10.7	-10.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1037	970	3.5	0.0	3.5
3	765 kV	JHARSUGUDA-DURG	2	0	1486	0.0	25.2	-25.2
4	400 kV	JHARSUGUDA-RAIGARH	4	165	379	0.0	3.1	-3.1
5	400 kV	RANCHI-SIPAT	2	243	341	0.0	1.0	-1.0
6	400 kV	JEYPORE-JAGDALPUR	2	358	360	1.0	0.0	1.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	174	0.0	2.6	-2.6
8	220 kV	BUDHIPADAR-KORBA	2	78	156	0.0	0.7	-0.7
ER-WR						4.5	43.3	-38.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	524	0.0	10.1	-10.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1426	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2660	0.0	45.2	-45.2
4	400 kV	TALCHER-I/C	2	710	589	3.8	0.0	3.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	91.5	-91.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	167	247	1.2	1.2	0.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	460	177	4.3	0.0	4.3
3	220 kV	ALIPURDUAR-SALAKATI	2	52	61	0.1	0.0	0.1
ER-NER						5.6	1.2	4.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	965	0	21.5	0.0	21.5
NER-NR						21.5	0.0	21.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4549	0.0	55.2	-55.2
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1176	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	1389	1395	4.8	14.3	-9.5
5	765 kV	GWALIOR-PHAGI	2	1057	1994	4.6	25.5	-20.9
6	765 kV	JABALPUR-ORAI	2	598	1143	0.0	18.8	-18.8
7	765 kV	GWALIOR-ORAI	1	1110	0	16.1	0.0	16.1
8	765 kV	SATNA-ORAI	1	97	949	0.1	13.4	-13.3
9	765 kV	BANASKANTHA-CHITTOORGARH	2	2407	0	32.4	0.0	32.4
10	765 kV	VINDHYACHAL VARANASI	2	696	1172	0.0	8.8	-8.8
11	400 kV	ZERDA-KANKROLI	1	380	0	6.0	0.0	6.0
12	400 kV	ZERDA BHINMAL	1	262	0	4.2	0.0	4.2
13	400 kV	VINDHYACHAL -RIHAND	1	484	0	9.4	0.0	9.4
14	400 kV	RAPP-SHUJALPUR	2	1064	217	8.1	0.4	7.7
15	400 kV	NEEMUCH-Chittorgarh	2	942	407	5.8	1.7	4.1
16	220 kV	BHANPURA-RANPUR	1	0	134	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	112	0	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	84	10	0.7	0.0	0.7
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						93.2	168.4	-75.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	308	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	4018	0.0	57.0	-57.0
3	765 kV	SOLAPUR-RAICHUR	2	1818	1393	9.5	6.3	3.2
4	765 kV	WARDHA-NIZAMABAD	2	435	2642	0.4	31.8	-31.5
5	765 kV	WARORA-WARANGAL(NEW)	2	314	2950	0.2	35.2	-35.1
6	400 kV	KOLHAPUR-KUDGI	2	1905	0	26.5	0.0	26.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	2.1	0.0	2.1
WR-SR						38.6	137.6	-98.9

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-326	14	-210	-5.03	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-408	113	-157	-3.78	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-211	-84	-172	-4.13	
	NER	132kV GELEPHU-SALAKATI	-77	-50	-68	-1.64	
	NER	132kV MOTANGA-RANGIA	-24	-5	-14	-0.34	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-27	-0.64	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-47	-1.12	
	ER	NEPAL IMPORT (FROM BIHAR)	-150	-76	-122	-2.92	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-389	-70	-238	-5.71	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-915	-913	-914	-21.95	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-736	-422	-672	-16.12	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-134	0	-118	-2.82	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 09-Feb-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.36	19.34	0.00	0.00	0.24	0.00	0.00	19.94
Nepal	3.31	1.75	0.97	0.00	0.00	3.84	0.00	0.00	9.87
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.26	2.11	20.31	0.00	0.00	4.08	0.00	0.00	52.76

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-19.34	0.00	0.00	-0.24	0.00	0.00	-19.60
Nepal	-3.31	-1.75	-0.97	0.00	0.00	-3.84	0.00	0.00	-9.87
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.92	-2.11	-20.31	0.00	0.00	-4.08	0.00	0.00	-52.42

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+G+H)	(K)
0:00	50.07	165650	6762	7336	0	7232	1929	143403	3896	158314	170558	-2104
0:15	49.99	165745	6772	7561	0	6854	1930	143612	3857	158184	170586	-2127
0:30	49.95	165592	6781	7731	0	6911	1937	143195	3834	157861	170389	-2137
0:45	50.04	165840	6755	7809	0	6569	1932	143767	3841	158031	170673	-2146
1:00	50.08	164718	6763	7899	0	6438	1924	142747	3836	156819	169607	-2161
1:15	50.04	163920	6770	7787	0	6055	1934	142284	3802	156133	168632	-2141
1:30	50.05	162968	6755	7717	0	6041	1927	141684	3844	155251	167968	-2137
1:45	50.02	162540	6766	7661	0	5936	1932	141325	3873	154879	167493	-2125
2:00	50.01	161508	6765	7656	0	5588	1932	140736	3802	153852	166479	-2120
2:15	49.96	161136	6766	7599	0	5466	1933	140777	3858	153537	166399	-2093
2:30	50.02	160968	6756	7662	0	5549	1934	140595	3859	153306	166355	-2108
2:45	49.97	160798	6768	7530	0	5508	1949	140567	3867	153268	166189	-2078
3:00	49.99	160718	6753	7508	0	5354	1943	140601	3929	153210	166088	-2114
3:15	49.95	161556	6772	7421	0	5304	1936	141532	3879	154135	166844	-2095
3:30	50.01	161349	6756	7375	0	5568	1936	141163	3878	153974	166676	-2106
3:45	50.00	161554	6769	7325	0	5916	1935	141165	3877	154229	166987	-2116
4:00	50.04	161685	6770	7373	0	6176	1940	141030	3881	154312	167170	-2116
4:15	49.97	163693	6774	7254	0	6130	1946	142944	3878	156439	168926	-2148
4:30	50.00	165079	6768	7074	0	6218	1949	144704	3889	158005	170602	-2171
4:45	49.97	166272	6771	6974	0	5696	1942	146534	3875	159298	171792	-2192
5:00	50.02	167869	6753	6743	242	5849	1940	148057	3869	160884	173453	-2218
5:15	50.06	170548	6765	6642	250	6805	1940	150299	3866	163656	176567	-2215
5:30	50.05	173809	6772	6346	263	7415	1942	153290	3901	167200	179929	-2267
5:45	50.01	177140	6780	6263	257	8301	1940	155497	3928	170620	182966	-2315
6:00	50.06	178501	6781	6178	272	8330	1950	156884	3996	172051	184391	-2291
6:15	49.97	182542	6761	6134	811	8347	1946	160754	3921	175597	188674	-2290
6:30	49.98	188833	6754	5972	820	10735	1942	163926	3879	182041	194028	-1756
6:45	50.00	193506	6760	5913	847	13039	1936	165869	3903	186746	198267	-1289
7:00	50.05	197939	6755	5784	1128	16802	1939	166651	3959	191027	203018	-1324
7:15	49.94	201744	6766	5798	2038	19048	1947	167163	3917	193908	206677	-1313
7:30	50.03	205325	6774	5692	3893	20112	1993	167514	3969	195740	209947	-1349
7:45	50.01	208615	6780	5491	7354	20009	2054	167171	4108	195770	212967	-1344
8:00	50.03	209276	6776	4964	12572	18919	2154	163882	4088	191740	213355	-1359
8:15	49.96	213599	6786	4597	18705	18806	2215	162268	4086	190297	217463	-1382
8:30	50.07	216400	6774	4263	26140	17881	2169	158855	4067	185997	220149	-1410
8:45	50.04	218723	6777	3993	33555	14701	2089	156626	4009	181175	221750	-1441
9:00	50.06	219798	6760	3694	40794	12683	1957	153342	3975	175310	223205	-1952
9:15	49.97	224169	6777	3558	48045	11957	1989	152222	3995	172566	228543	-2494
9:30	50.00	225285	6772	3323	54173	10448	2144	148891	3988	167789	229739	-2448
9:45	49.90	226822	6763	3176	59650	9563	2200	146327	3912	163996	231591	-2528
10:00	50.04	226603	6766	3073	64561	8825	2116	142641	3891	158969	231873	-2565
10:15	49.96	226107	6777	3018	68132	7104	1999	140448	3904	154957	231382	-2564
10:30	50.00	226235	6757	3088	71414	7056	1896	137229	3863	151733	231303	-2584
10:45	49.99	225469	6766	3164	73790	6787	1903	134490	3816	148515	230716	-2635
11:00	50.01	223071	6755	3247	75748	6891	2101	129834	3893	144076	228469	-2632
11:15	49.97	220760	6760	3315	76906	6335	2095	126927	3800	140539	226138	-2611
11:30	49.99	219095	6767	3355	77505	5996	2075	125058	3803	138235	224559	-2658
11:45	49.88	218285	6763	3308	78457	6280	2067	123130	3790	136520	223795	-2631
12:00	50.01	215437	6761	3190	79134	6250	2079	119873	3720	133113	221007	-2632
12:15	49.97	213111	6757	2994	78759	6041	2071	118276	3716	131358	218614	-2613
12:30	50.08	211871	6767	2272	79597	6243	2032	116336	3737	130002	216984	-2630
12:45	50.10	210156	6762	2235	79255	6102	2028	115426	3690	128666	215498	-2639
13:00	50.19	209086	6758	2670	78968	5824	2036	114051	3819	127448	214126	-2363
13:15	50.16	206488	6767	2607	78003	5802	2047	112581	3741	125878	211548	-2475
13:30	50.28	204912	6774	2544	77141	5766	2028	112028	3735	125227	210016	-2552
13:45	50.22	204055	6765	2588	76879	5582	2026	111652	3730	124588	209222	-2517
14:00	50.30	202391	6768	2529	74974	5421	2032	111927	3692	124888	207343	-2614
14:15	50.18	200018	6764	2611	73815	4870	2030	111332	3737	123592	205159	-2611
14:30	49.97	199744	6754	2652	71436	5141	2030	113015	3732	125656	204760	-2648
14:45	49.89	200432	6754	2652	69516	5334	2048	115677	3704	128264	205685	-2656
15:00	49.99	200889	6753	2747	68642	5914	2006	116629	3688	129500	206379	-2724
15:15	49.98	199212	6765	2837	68032	5828	1895	115417	3730	128343	204504	-2748
15:30	50.02	199303	6755	2775	64733	6328	1923	118559	3704	131795	204777	-2742
15:45	49.98	197762	6752	2881	61085	6717	1936	120066	3672	133796	203109	-2712
16:00	49.98	196159	6754	2922	55830	6559	2108	123240	3706	137407	201119	-2717
16:15	49.93	193068	6775	2993	50458	7031	2158	124773	3792	139617	197980	-2777
16:30	49.99	194216	6764	3138	44768	8172	2147	130263	3697	146310	198949	-2732
16:45	49.93	193625	6765	3062	38109	9503	2141	134489	3726	152454	197795	-2720
17:00	50.05	193444	6740	3117	31288	10491	2053	140097	3725	159039	197511	-2664
17:15	50.07	189923	6759	2943	23775	11292	1994	143431	3769	163205	193963	-2749
17:30	50.01	190056	6764	2963	16065	12802	1904	149796	3762	171028	194056	-2670
17:45	50.09	192253	6752	2911	9539	16145	1894	154919	3826	179803	195986	-2074
18:00	50.09	192770	6762	2984	4680	18060	1890	157445	3795	185106	195616	-1292
18:15	49.98	193081	6765	3233	1968	18843	1905	159628	3784	187880	196126	-1337
18:30	50.00	196675	6738	3301	867	20114	1908	163048	3737	192507	199713	-1302
18:45	49.98	199032	6753	3566	538	20976	1901	164315	3743	194928	201792	-1320
19:00	50.02	198777	6756	3722	463	21608	1891	163514	3818	194592	201772	-1405
19:15	50.04	196774	6771	3869	482	20370	1894	162379	3746	192423	199511	-1392
19:30	50.00	194855	6767	4055	0	17018	1906	163423	3799	190800	196968	-1357
19:45	50.02	192719	6763	4172	0	15713	1920	162760	3803	188547	195131	-1406
20:00	49.99	189272	6770	4286	0	14169	1915	160936	3806	184986	191882	-1417
20:15	49.99	187096	6765	4295	0	13391	1912	159610	3870	182801	189843	-1431
20:30	50.01	184578	6764	4301	0	12571	1911	158825	3809	180277	188181	-2018
20:45	50.00	182416	6774	4446	0	11964	1912	157122	3853	177970	186071	-2293
21:00	50.01	179128	6776	4523	0	10776	1908	155264	3818	174605	183065	-2282
21:15	49.98	177128	6779	4452	0	11066	1908	153043	3859	172676	181107	-2309
21:30	49.97	174419	6786	4499	0	11141	1920	150973	3870	169920	179189	-2289
21:45	49.98	172378	6770	4499	0	9603	1921	149957	3879	167879	176629	-2301
22:00	50.00	169743	6778	4460	0	9294	1914	147780	3830	165283	174056	-2216
22:15	49.96	169775	6777	4445	0	9032	1924	148333	3831	165330	174342	-2218
22:30	49.97	168516	6778	4510	0	8917	1927	147005	3888	164006	1	