



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 01.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 31.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 31-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 31.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 01-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	62340	64850	50389	23614	2798	203991
Peak Shortage (MW)	0	0	0	53	0	53
Energy Met (MU)	1328	1565	1245	488	55	4681
Hydro Gen (MU)	121	43	104	22	15	305
Wind Gen (MU)	16	42	19	-	-	78
Solar Gen (MU)*	108.46	138.15	130.86	3.10	0.56	381
Energy Shortage (MU)	0.29	0.00	0.00	0.63	0.00	0.92
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72499	80699	64329	24015	2954	241201
Time Of Maximum Demand Met	10:40	09:52	11:59	17:34	18:02	10:39

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.045	0.37	1.71	4.72	6.80	79.35	13.84

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9163	0	166.6	72.2	-0.1	551	0.00
	Haryana	8535	0	164.9	108.7	-1.5	336	0.00
	Rajasthan	18731	0	340.5	132.6	4.2	865	0.00
	Delhi	5465	0	91.8	85.6	1.7	558	0.00
	UP	21535	0	402.2	75.6	-1.7	590	0.00
	Uttarakhand	2631	0	48.6	38.1	0.5	90	0.00
	HP	2149	0	39.4	33.3	-0.8	174	0.00
	J&K(UT) & Ladakh(UT)	3301	80	65.8	62.0	-2.0	349	0.29
	Chandigarh	284	0	4.8	4.7	0.1	24	0.00
	Railways_NR ISTS	190	0	3.9	3.5	0.4	56	0.00
WR	Chhattisgarh	5456	0	108.7	51.1	-1.2	366	0.00
	Gujarat	23877	0	440.0	196.1	-1.3	866	0.00
	MP	19851	0	356.1	222.2	0.0	873	0.00
	Maharashtra	28354	0	577.9	164.7	-9.9	795	0.00
	Goa	732	0	13.9	11.5	1.9	78	0.00
	DNHDDPDCL	1272	0	29.6	30.1	-0.5	42	0.00
	AMNSIL	905	0	18.7	11.6	0.1	331	0.00
	BALCO	595	0	14.2	14.3	-0.1	14	0.00
	RIL JAMNAGAR	259	0	5.8	5.9	-0.1	0	0.00
	Andhra Pradesh	11586	0	219.9	62.2	-0.4	479	0.00
SR	Telangana	14579	0	254.7	97.2	-0.7	689	0.00
	Karnataka	17220	0	306.1	106.1	-1.2	974	0.00
	Kerala	4535	0	86.3	60.4	0.1	418	0.00
	Tamil Nadu	17842	0	368.9	242.9	0.5	1860	0.00
	Puducherry	410	0	8.9	8.4	-0.2	36	0.00
	Bihar	6285	53	119.3	105.9	1.5	475	0.63
ER	DVC	3098	0	68.0	-43.0	1.1	308	0.00
	Jharkhand	2205	0	41.6	30.5	-1.3	140	0.00
	Odisha	4941	0	97.6	5.7	-0.4	435	0.00
	West Bengal	7832	0	159.7	22.5	-1.3	260	0.00
	Sikkim	109	0	1.8	1.9	-0.1	16	0.00
	Railways_ER ISTS	37	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	173	0	3.4	3.3	0.0	23	0.00
	Assam	1705	0	29.6	23.7	0.3	117	0.00
	Manipur	257	0	3.9	3.9	0.0	39	0.00
	Meghalaya	357	0	6.5	5.4	0.0	65	0.00
	Mizoram	157	0	2.4	2.3	-0.1	36	0.00
	Nagaland	160	0	2.9	2.8	0.0	15	0.00
	Tripura	238	0	6.0	4.7	-0.1	62	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-13.2	-3.8	-20.0	-20.8
Day Peak (MW)	-947.3	-576.9	-1006.7	-988.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	236.1	-207.2	173.9	-211.1	8.3	0.0
Actual(MU)	265.2	-231.0	166.4	-218.4	6.3	-11.5
O/D/U/D(MU)	29.1	-23.8	-7.5	-7.3	-2.1	-11.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5264	11167	5968	4900	85	27384	50
State Sector	7289	10223	7020	2359	205	27095	50
Total	12553	21389	12988	7259	290	54479	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	811	1589	775	767	15	3957	78
Lignite	19	17	52	0	0	87	2
Hydro	121	43	104	22	15	305	6
Nuclear	48	53	47	0	0	148	3
Gas, Naptha & Diesel	14	26	11	0	22	74	1
RES (Wind, Solar, Biomass & Others)	150	184	180	7	1	521	10
Total	1164	1912	1168	796	53	5092	100

Share of RES in total generation (%)	12.90	9.61	15.43	0.82	1.08	10.24
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.49	14.60	28.31	3.63	29.50	19.13

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.024

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	241201	10:39	0
Non-Solar hr	215173	18:20	482

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 01-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1304	0.0	24.8	-24.8
4	765 kV	SASARAM-FATEHPUR	1	0	627	0.0	10.3	-10.3
5	765 kV	GAYA-BALIA	1	0	785	0.0	15.4	-15.4
6	400 kV	PUSAULI-VARANASI	1	18	54	0.0	0.5	-0.5
7	400 kV	PUSAULI-ALLAHABAD	1	0	117	0.0	0.4	-0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	38	746	0.0	8.9	-8.9
9	400 kV	PATNA-BALIA	2	0	1105	0.0	19.1	-19.1
10	400 kV	NAUBATPUR-BALIA	2	0	492	0.0	5.7	-5.7
11	400 kV	BIHARSHARIFF-BALIA	2	154	381	0.0	3.5	-3.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	592	0.0	8.9	-8.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	491	0.0	7.8	-7.8
14	220 kV	SAHUPURI-KARMANASA	1	19	19	0.0	0.0	0.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	30	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	20	0.0	0.8	-0.8
ER-NR						0.7	108.5	-107.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	54	1120	0.0	14.6	-14.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	370	1401	0.0	13.0	-13.0
3	765 kV	JHARSUGUDA-DURG	2	0	1224	0.0	23.8	-23.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	724	0.0	10.3	-10.3
5	400 kV	RANCHI-SIPAT	2	89	382	0.0	3.7	-3.7
6	400 kV	JEYPORE-JACDALPUR	2	425	120	0.0	3.9	-3.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	160	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	20	147	0.0	1.1	-1.1
ER-WR						3.9	68.0	-64.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	647	0.0	14.8	-14.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1622	0.0	39.1	-39.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2737	0.0	49.4	-49.4
4	400 kV	TALCHER UC	2	878	223	0.0	5.5	0.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	103.4	-103.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	401	197	2.0	0.7	1.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	708	118	5.3	0.0	5.3
3	220 kV	ALIPURDUAR-SALAKATI	2	132	16	1.1	0.0	1.1
ER-NER						8.5	0.7	7.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	16.0	0.0	16.0
NER-NR						16.0	0.0	16.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2512	0.0	51.0	-51.0
2	HVDC	VINDHYACHAL B/B	-	0	304	0.0	4.4	-4.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1365	0.0	29.7	-29.7
4	765 kV	GWALIOR-AGRA	2	82	2500	0.0	33.7	-33.7
5	765 kV	GWALIOR-PHAGI	2	0	1362	0.0	25.3	-25.3
6	765 kV	JABALPUR-ORAI	2	0	1061	0.0	32.5	-32.5
7	765 kV	GWALIOR-ORAI	1	820	0	15.5	0.0	15.5
8	765 kV	SATNA-ORAI	1	0	1244	0.0	24.5	-24.5
9	765 kV	BANASKANTHA-CHITORGARH	2	2379	1202	22.6	4.6	18.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2436	0.0	33.2	-33.2
11	400 kV	ZERDA-KANKROLI	1	343	159	3.9	0.5	3.4
12	400 kV	ZERDA -BHINMAL	1	237	110	1.5	0.0	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	0.0	21.3	-21.3
14	400 kV	RAPP-SHUJALPUR	2	252	303	1.3	1.3	-0.1
15	400 kV	NEEMUCH-Chittorgarh	2	158	471	0.3	3.1	-2.9
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	158	5	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	126	19	0.9	0.0	0.9
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						47.3	268.7	-221.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	2510	0.0	54.9	-54.9
3	765 kV	SOLAPUR-RAICHUR	2	994	1552	4.6	12.3	-7.7
4	765 kV	WARDHA-NIZAMABAD	2	331	2041	0.5	23.2	-22.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2370	0.0	29.1	-29.1
6	400 kV	KOLHAPUR-KUDGI	2	1502	0	20.9	0.0	20.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	116	0.9	0.0	1.9
WR-SR						28.0	143.4	-115.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-244	-18	-129	-3.11	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	298	-264	-32	-0.77	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-358	-182	-308	-7.40	
	NER	132kV GELEPHU-SALAKATI	-68	0	-58	-1.38	
	NER	132kV MOTANGA-RANGIA	-36	0	-23	-0.56	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-69	0	-23	-0.56	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-69	0	-35	-0.83	
	ER	NEPAL IMPORT (FROM BIHAR)	-49	0	-23	-0.56	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-382	156	-78	-1.87	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-912	-264	-754	-18.09	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-988	-821	-865	-20.77	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-94	0	-78	-1.86	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 01-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	14.35	0.00	0.00	0.00	0.00	0.00	14.35	
Nepal	0.87	0.00	0.32	0.00	0.00	0.00	1.94	0.00	0.00	3.13
Bangladesh	19.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.09	0.00	14.67	0.00	0.00	0.00	1.94	0.00	0.00	36.70

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.99	0.00	0.00	0.99
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	0.99	0.00	0.00	0.99

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	-14.35	0.00	0.00	0.00	0.00	0.00	-14.35
Nepal	-0.87	0.00	-0.32	0.00	0.00	-0.95	0.00	0.00	-2.14
Bangladesh	-19.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.09	0.00	-14.67	0.00	0.00	-0.95	0.00	0.00	-35.71

