



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.06.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	74523	57694	43701	27511	3594	207023
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1705	1327	1114	603	70	4819
Hydro Gen (MU)	405	40	125	98	35	703
Wind Gen (MU)	23	201	275	-	-	500
Solar Gen (MU)*	169.46	77.52	120.04	2.87	0.95	371
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79652	58613	51131	28908	3640	217699
Time Of Maximum Demand Met	00:00	00:00	09:37	00:00	20:07	00:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.059	0.00	0.01	6.78	6.79	71.38	21.83

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15464	0	335.8	214.3	-2.6	494	0.00
	Haryana	11967	0	261.8	199.2	-2.5	220	0.00
	Rajasthan	12986	0	286.1	124.4	-9.8	340	0.00
	Delhi	6791	0	139.4	123.4	-0.4	365	0.00
	UP	27178	0	532.1	262.2	-0.2	492	0.00
	Uttarakhand	2413	0	49.6	27.4	1.4	269	0.00
	HP	1705	0	37.0	-1.6	-1.1	19	0.00
	J&K(UT) & Ladakh(UT)	2652	0	52.3	28.1	-0.2	254	0.00
	Chandigarh	337	0	6.8	6.7	0.1	38	0.00
	Railways_NR ISTS	213	0	4.2	3.9	0.3	44	0.00
WR	Chhattisgarh	5376	0	120.3	65.8	-1.7	324	0.00
	Gujarat	17396	0	387.8	170.9	2.8	1330	0.00
	MP	9957	0	214.3	110.3	-2.9	497	0.00
	Maharashtra	23435	0	522.0	155.1	-0.7	899	0.00
	Goa	551	0	14.1	11.3	2.3	68	0.00
	DNHDDPDCL	1332	0	30.8	30.4	0.4	97	0.00
	AMNSIL	851	0	19.0	9.5	0.2	230	0.00
	BALCO	532	0	12.7	12.7	0.0	11	0.00
	RIL JAMNAGAR	247	0	5.9	5.9	0.0	0	0.00
	Andhra Pradesh	10508	0	221.8	41.5	0.5	697	0.00
SR	Telangana	10813	0	224.9	116.0	1.7	679	0.00
	Karnataka	11751	0	213.7	43.9	-2.3	469	0.00
	Kerala	3588	0	74.3	30.7	-2.7	296	0.00
	Tamil Nadu	17128	0	368.7	115.3	-2.8	618	0.00
	Puducherry	493	0	10.2	10.1	-0.6	33	0.00
	Bihar	7341	0	145.4	140.5	-5.2	268	0.00
ER	DVC	3135	0	66.4	-32.8	-1.3	349	0.00
	Jharkhand	1989	0	42.6	34.4	-0.7	169	0.00
	Odisha	6180	0	129.4	59.2	-1.0	678	0.00
	West Bengal	11174	0	218.7	94.6	-2.4	343	0.00
	Sikkim	62	0	0.9	1.0	-0.1	10	0.00
	Railways_ER ISTS	20	0	0.1	0.2	-0.1	5	0.00
NER	Arunachal Pradesh	194	0	3.3	3.0	0.0	43	0.00
	Assam	2466	0	46.7	39.2	0.9	229	0.00
	Manipur	211	0	3.1	3.3	-0.2	35	0.00
	Meghalaya	307	0	5.4	-0.6	-0.1	37	0.00
	Mizoram	108	0	2.8	0.7	0.7	49	0.00
	Nagaland	184	0	2.8	3.0	-0.4	48	0.00
	Tripura	3281	0	6.2	5.1	0.1	42	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	58.2	12.8	-23.3	-32.5
Day Peak (MW)	2642.2	685.8	-981.0	-1467.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	403.6	-327.3	-23.7	-58.3	5.7	0.0
Actual(MU)	397.9	-312.1	-34.9	-62.4	4.2	-7.2
O/D/U/D(MU)	-5.7	15.2	-11.2	-4.0	-1.5	-7.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4059	10271	6898	4640	445	26312	42
State Sector	8599	13927	10959	2399	199	36083	58
Total	12658	24197	17857	7039	644	62394	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	713	1371	522	634	12	3253	63
Lignite	25	9	46	0	0	80	2
Hydro	405	40	125	98	35	703	14
Nuclear	37	44	63	0	0	144	3
Gas, Naptha & Diesel	17	17	5	0	21	59	1
RES (Wind, Solar, Biomass & Others)	202	281	427	4	1	915	18
Total	1399	1762	1186	737	69	5153	100

Share of RES in total generation (%)	14.46	15.94	35.99	0.53	1.37	17.76
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	46.03	20.68	51.82	13.89	52.25	34.18

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.067

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	199897	14:23	0
Non-Solar hr	217699	0:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 23-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	310	0.0	7.7	-7.7
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	592	721	0.0	3.1	-3.1
4	765 kV	SASARAM-FATEHPUR	1	183	486	0.0	3.5	-3.5
5	765 kV	GAYA-BALIA	1	0	863	0.0	12.0	-12.0
6	400 kV	PUSAULI-VARANASI	1	0	105	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	10	70	0.0	0.8	-0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	861	0.0	11.9	-11.9
9	400 kV	PATNA-BALIA	2	84	785	0.0	10.0	-10.0
10	400 kV	NAUBATPUR-BALIA	2	97	521	0.0	2.7	-2.7
11	400 kV	BIHARSHARIFF-BALIA	2	184	361	0.0	2.4	-2.4
12	400 kV	MOTIHARI-GORAKHPUR	2	50	477	0.0	6.3	-6.3
13	400 kV	BIHARSHARIFE-SAHUPURI	2	114	373	0.0	3.3	-3.3
14	220 kV	SAHUPURI-KARAMNASHA	1	0	108	0.0	2.4	-2.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASHA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASHA-CHANDLAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.8	69.9	-69.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	772	818	0.2	0.0	0.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2105	0	34.9	0.0	34.9
3	765 kV	JHARSUGUDA-DURG	2	243	451	0.0	3.3	-3.3
4	400 kV	JHARSUGUDA-RAIGARH	4	323	218	0.9	0.0	0.9
5	400 kV	RANCHI-SIPAT	2	538	0	7.5	0.0	7.5
6	400 kV	JEYPORE-JAGDALPUR	2	168	331	0.5	2.5	-2.0
7	220 kV	BUDHIPADAR-RAIGARH	1	74	50	0.2	0.0	0.2
8	220 kV	BUDHIPADAR-KORBA	2	146	23	1.4	0.0	1.4
ER-WR						45.6	5.8	39.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	512	0	9.5	0.0	9.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1329	0.0	27.7	-27.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2467	0.0	32.4	-32.4
4	400 kV	TALCHER-J/C	2	586	392	0.3	0.0	0.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						9.5	60.2	-50.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	249	246	0.7	1.6	-0.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	84	660	0.0	8.1	-8.1
3	220 kV	ALIPURDUAR-SALAKATI	2	23	127	0.0	1.6	-1.6
ER-NER						0.7	11.3	-10.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
NER-NR						0.0	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3080	0.0	67.3	-67.3
2	HVDC	VINDHYACHAL B/B	-	46	0	1.2	0.0	1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	3020	0.0	50.2	-50.2
5	765 kV	GWALIOR-PHAGI	2	496	1948	1.0	23.8	-22.8
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	41.2	-41.2
7	765 kV	GWALIOR-ORAI	1	604	108	7.6	0.3	7.3
8	765 kV	SATNA-ORAI	1	0	1316	0.0	22.9	-22.9
9	765 kV	BANASKANTHA-CHITORGARH	2	843	1548	2.3	14.6	-12.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	3685	0.0	64.5	-64.5
11	400 kV	ZERDA-KANKROLI	1	251	216	0.8	1.2	-0.4
12	400 kV	ZERDA -BHINMAL	1	171	149	0.6	0.9	-0.3
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	332	664	0.9	6.7	-5.8
15	400 kV	NEEMUCH-Chittorgarh	2	215	665	0.5	6.5	-6.0
16	220 kV	BHANPURA-RANPUR	1	0	110	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURATIYA	1	53	31	0.1	0.1	0.0
19	220 kV	MALANPUR-AURATIYA	1	31	62	0.1	0.6	-0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						15.1	341.9	-326.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1003	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	0	903	0.0	18.6	-18.6
3	765 kV	SOLAPUR-RAICHUR	2	2733	189	36.2	0.1	36.1
4	765 kV	WARDHA-NIZAMABAD	2	548	1918	1.8	13.7	-11.9
5	765 kV	WARORA-WARANGAL(NEW)	2	760	1900	2.6	13.0	-10.4
6	400 kV	KOLHAPUR-KUDGI	2	2050	0	34.1	0.0	34.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	105	2.0	0.0	2.0
WR-SR						100.7	45.4	55.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1367	695	1344	32.25		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	899	806	848	20.34		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	207	108	138	3.30		
	NER	132kV GELEPHU-SALAKATI	87	30	49	1.18		
	NER	132kV MOTANGA-RANGIA	61	35	49	1.17		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-61	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-61	0	-29	-0.69		
	ER	NEPAL IMPORT (FROM BIHAR)	142	9	101	2.43		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	544	254	461	11.07		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-937	-937	-22.50		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1467	-1206	-1354	-32.49		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-40	0	-33	-0.80		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 23-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.19	0.00	0.00	0.00	0.00	0.16	0.00	0.00	0.35
Bangladesh	22.89	0.30	0.00	0.00	0.00	0.00	0.00	0.00	23.19
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.08	0.30	0.00	0.00	0.00	0.16	0.00	0.00	23.54

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	56.64	0.00	0.73	0.00	0.00	0.25	0.00	0.00	57.62
Nepal	8.26	0.29	0.00	0.00	0.00	5.26	0.00	0.00	13.81
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	64.90	0.29	0.73	0.00	0.00	5.51	0.00	0.00	71.43

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	56.64	0.00	0.73	0.00	0.00	0.25	0.00	0.00	57.62
Nepal	8.07	0.29	0.00	0.00	0.00	5.10	0.00	0.00	13.46
Bangladesh	-22.89	-0.30	0.00	0.00	0.00	0.00	0.00	0.00	-23.19
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	41.82	-0.01	0.73	0.00	0.00	5.35	0.00	0.00	47.89

