



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 26.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 25.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 25-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 25.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 26-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59315	67039	46911	23051	2774	199090
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1248	1593	1205	481	52	4578
Hydro Gen (MU)	92	43	86	23	11	255
Wind Gen (MU)	5	99	65	-	-	168
Solar Gen (MU)*	188.28	113.48	141.05	3.42	0.76	447
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65469	79214	60963	24446	2903	229686
Time Of Maximum Demand Met	10:25	10:25	09:58	19:20	17:47	10:25

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.042	0.38	1.31	4.61	6.30	77.54	16.17

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8703	0	159.5	74.2	0.8	710	0.00
	Haryana	8289	0	158.2	106.5	-1.5	538	0.00
	Rajasthan	17679	0	337.0	114.8	-1.6	516	0.00
	Delhi	4511	0	76.2	75.4	-1.1	369	0.00
	UP	19792	0	360.5	121.2	-0.8	321	0.00
	Uttarakhand	2438	0	44.4	35.1	-0.2	94	0.00
	HP	2099	0	38.4	32.9	-0.9	122	0.00
	J&K(UT) & Ladakh(UT)	3093	0	65.9	64.5	-2.2	970	0.00
	Chandigarh	238	0	4.0	4.4	-0.4	12	0.00
WR	Railways_NR ISTS	205	0	3.8	3.8	-0.1	38	0.00
	Chhattisgarh	5804	0	120.7	68.7	0.3	504	0.00
	Gujarat	23456	0	434.2	191.5	-2.2	714	0.00
	MP	18473	0	348.4	217.0	-3.0	902	0.00
	Maharashtra	29213	0	609.9	215.1	2.2	695	0.00
	Goa	691	0	14.4	13.7	0.2	111	0.00
	DNHDDPDCL	1330	0	30.8	30.8	0.0	40	0.00
	AMNSIL	806	0	17.0	7.3	0.6	320	0.00
	BALCO	532	0	12.7	12.7	0.0	14	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	11559	0	212.1	45.6	-0.8	768	0.00
	Telangana	14436	0	274.9	138.0	-1.5	686	0.00
	Karnataka	16804	0	295.3	95.2	0.3	589	0.00
	Kerala	4296	0	85.4	69.1	1.2	615	0.00
	Tamil Nadu	16033	0	328.7	171.5	-1.5	1191	0.00
	Puducherry	416	0	9.1	8.6	0.0	39	0.00
ER	Bihar	5431	0	101.0	90.1	0.2	148	0.00
	DVC	3254	0	69.8	-38.2	-1.0	287	0.00
	Jharkhand	2075	0	39.9	30.4	-0.4	182	0.00
	Odisha	5399	0	108.2	37.4	-1.1	470	0.00
	West Bengal	7694	0	159.6	32.8	-1.6	208	0.00
	Sikkim	134	0	2.2	2.0	0.2	43	0.00
	Railways_ER ISTS	14	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	188	0	3.3	3.2	0.0	0	0.00
	Assam	1574	0	28.3	23.9	-0.1	47	0.00
	Manipur	237	0	3.7	3.8	-0.1	0	0.00
	Meghalaya	381	0	7.1	5.5	0.0	37	0.00
	Mizoram	156	0	2.6	2.0	-0.1	0	0.00
	Nagaland	157	0	2.5	2.4	0.0	0	0.00
	Tripura	228	0	4.2	3.3	0.2	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.2	-9.9	-22.0	-14.1
Day Peak (MW)	-492.0	-560.4	-1002.0	-818.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	232.7	-229.6	142.9	-155.8	9.9	0.0
Actual(MU)	214.2	-220.8	140.8	-153.8	10.1	-9.6
O/D/U/D(MU)	-18.5	8.7	-2.0	2.0	0.2	-9.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4934	7999	5948	2696	923	22499	45
State Sector	7758	11331	5036	3584	222	27930	55
Total	12692	19329	10984	6280	1144	50429	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	743	1594	654	696	13	3700	75
Lignite	27	16	58	0	0	101	2
Hydro	92	43	86	23	11	255	5
Nuclear	32	50	71	0	0	153	3
Gas, Naptha & Diesel	3	12	5	0	22	42	1
RES (Wind, Solar, Biomass & Others)	219	215	255	7	1	697	14
Total	1117	1930	1129	726	46	4948	100

Share of RES in total generation (%)	19.63	11.13	22.62	0.94	1.64	14.09
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.80	15.93	36.57	4.05	25.02	22.34

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.036

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	229686	10:25	0
Non-Solar hr	205398	18:39	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 26-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	190	1060	0.0	12.6	-12.6
4	765 kV	SASARAM-FATEHPUR	1	27	582	0.0	8.3	-8.3
5	765 kV	GAYA-BALIA	1	0	795	0.0	10.4	-10.4
6	400 kV	PUSAULI-VARANASI	1	0	92	0.0	1.1	-1.1
7	400 kV	PUSAULI -ALLAHABAD	1	45	44	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	336	593	0.0	3.9	-3.9
9	400 kV	PATNA-BALIA	2	9	774	0.0	10.2	-10.2
10	400 kV	NAUBATPUR-BALIA	2	29	252	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	266	277	0.0	0.4	-0.4
12	400 kV	MOTIHARI-GORAKHPUR	2	37	476	0.0	5.9	-5.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	476	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	128	0.0	0.5	-0.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	57.4	-56.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	490	606	0.0	2.2	-2.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	419	912	0.0	2.9	-2.9
3	765 kV	JHARSUGUDA-DURG	2	0	1072	0.0	19.4	-19.4
4	400 kV	JHARSUGUDA-RAIGARH	4	0	663	0.0	10.2	-10.2
5	400 kV	RANCHI-SIPAT	2	83	343	0.0	2.1	-2.1
6	220 kV	BUDHIPADAR-RAIGARH	1	0	95	0.0	1.3	-1.3
7	220 kV	BUDHIPADAR-KORBA	2	85	71	0.5	0.0	0.5
ER-WR						0.5	38.1	-37.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	361	0.0	8.6	-8.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1248	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2742	0.0	50.1	-50.1
4	400 kV	TALCHER-I/C	2	182	20	3.0	0.0	3.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	88.9	-88.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	89	179	0.0	1.1	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	177	217	0.0	0.4	-0.4
3	220 kV	ALIPURDUAR-SALAKATI	2	52	31	0.2	0.0	0.2
ER-NER						0.2	1.4	-1.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	366	0	9.2	0.0	9.2
NER-NR						9.2	0.0	9.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4034	0.0	81.0	-81.0
2	HVDC	VINDHYACHAL B/B	-	17	143	1.5	0.9	0.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	31.3	-31.3
4	765 kV	GWALIOR-AGRA	2	615	2089	0.9	21.7	-20.8
5	765 kV	GWALIOR-PHAGI	2	316	1880	0.8	20.1	-19.4
6	765 kV	JABALPUR-ORAI	2	233	1079	0.0	21.2	-21.2
7	765 kV	GWALIOR-ORAI	1	829	0	14.0	0.0	14.0
8	765 kV	SATNA-ORAI	1	0	1162	0.0	19.8	-19.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1698	464	12.4	1.1	11.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	2420	0.0	34.5	-34.5
11	400 kV	ZERDA-KANKROLI	1	323	74	2.9	0.1	2.8
12	400 kV	ZERDA -BHINMAL	1	223	52	2.0	0.1	1.9
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	755	283	5.8	0.9	4.9
15	400 kV	NEEMUCH-Chittorgarh	2	699	413	5.1	1.3	3.8
16	220 kV	BHANPURA-RANPUR	1	0	209	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	128	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	88	9	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						69.5	239.5	-170.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	208	0.0	3.6	-3.6
2	HVDC	RAIGARH-PUGALUR	2	0	3008	0.0	57.2	-57.2
3	765 kV	SOLAPUR-RAICHUR	2	1393	1016	8.9	4.1	4.9
4	765 kV	WARDHA-NIZAMABAD	2	232	2216	0.1	29.1	-29.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2205	0.0	32.2	-32.2
6	400 kV	KOLHAPUR-KUDGI	2	1543	0	27.2	0.0	27.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
WR-SR						38.4	126.2	-87.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	265	-28	61	1.47	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-335	114	-119	-2.85	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-263	-104	-186	-4.48	
	NER	132kV GELEPHU-SALAKATI	-32	0	-19	-0.45	
	NER	132kV MOTANGA-RANGIA	20	0	5	0.12	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-76	0	-34	-0.81	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-76	0	-46	-1.10	
	ER	NEPAL IMPORT (FROM BIHAR)	-217	-17	-142	-3.41	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-343	-5	-191	-4.58	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-938	-646	-868	-20.83	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-818	-404	-586	-14.06	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-50	-1.20	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.32	6.47	0.00	0.00	0.52	0.00	0.00	7.31
Nepal	3.66	0.00	2.21	0.00	0.00	2.42	0.00	0.00	8.29
Bangladesh	21.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.35	0.32	8.68	0.00	0.00	2.94	0.00	0.00	37.29

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	-0.32	-6.47	0.00	0.00	-0.52	0.00	0.00	-6.56
Nepal	-3.66	0.00	-2.21	0.00	0.00	-2.42	0.00	0.00	-8.29
Bangladesh	-21.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.69
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.60	-0.32	-8.68	0.00	0.00	-2.94	0.00	0.00	-36.54

Date of Reporting: 26-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	158106	6141	12552	9	5796	1667	131831	3264	145545	161260	-1784
0:15	49.97	158431	6121	12263	8	6081	1663	132033	3259	146160	161428	-1700
0:30	49.97	158009	6090	11987	9	6145	1678	131801	3269	146013	160979	-1690
0:45	49.92	157121	6076	11717	8	5793	1690	131559	3264	145396	160107	-1615
1:00	49.92	156267	6073	11510	9	5623	1689	130828	3253	144748	158985	-1451
1:15	49.97	155433	6090	11245	13	5206	1668	130746	3220	144175	158188	-1476
1:30	49.97	154890	6076	11008	13	5213	1674	130356	3242	143869	157582	-1497
1:45	50.02	153986	6071	10858	10	4994	1647	129911	3262	143118	156753	-1475
2:00	50.02	152832	6075	10662	10	4818	1676	129176	3290	142160	155707	-1475
2:15	49.97	152731	6068	10421	11	4744	1660	129253	3294	142299	155451	-1505
2:30	50.02	152410	6086	10130	11	4818	1657	129288	3255	142269	155245	-1486
2:45	50.02	152204	6089	9950	10	4928	1671	129107	3263	142244	155018	-1492
3:00	50.02	151774	6065	9665	11	4868	1663	129115	3246	142098	154633	-1508
3:15	49.97	152016	6070	9427	9	4867	1685	129421	3252	142580	154731	-1400
3:30	50.02	152006	6082	9181	11	5096	1669	129343	3267	142814	154649	-1383
3:45	49.97	152214	6084	9005	11	4964	1660	129938	3277	143198	154939	-1394
4:00	50.02	152481	6056	8849	10	5113	1664	130259	3271	143622	155222	-1401
4:15	49.97	154664	6056	8844	11	5319	1676	132051	3296	145809	157253	-1444
4:30	49.97	156311	6080	8700	9	5430	1670	133835	3261	147602	158985	-1460
4:45	49.97	158773	6075	8573	11	5680	1672	135881	3278	150189	161170	-1434
5:00	50.02	160771	6059	8520	10	6104	1673	137773	3267	152241	163406	-1517
5:15	49.91	164750	6093	8506	31	6585	1684	140850	3280	156213	167029	-1508
5:30	50.02	168581	6100	8423	32	6927	1656	144220	3283	160126	170641	-1508
5:45	50.02	172854	6119	8355	31	7291	1661	148049	3318	164468	174824	-1567
6:00	50.07	176327	6097	8293	38	8067	1674	150393	3374	167996	177936	-1548
6:15	50.02	181265	6103	8338	74	8532	1660	154494	3316	172853	182517	-1447
6:30	50.07	187668	6111	8426	172	10969	1671	158462	3318	179070	189129	-1267
6:45	50.07	194713	6119	8534	175	13819	1663	162293	3323	186004	195926	-1086
7:00	50.07	200064	6117	8468	310	17148	1678	164305	3334	191286	201360	-1076
7:15	49.96	205882	6136	8509	901	20127	1668	166031	3364	196472	206736	-1020
7:30	50.06	210087	6131	8484	2161	22323	1648	166921	3386	199442	211054	-982
7:45	50.01	212671	6133	8499	4618	22427	1672	166431	3411	199554	213191	-951
8:00	50.11	214021	6127	8445	8282	21678	1639	164770	3458	197294	214399	-902
8:15	50.06	217202	6135	8348	13614	20706	1693	163773	3383	195240	217652	-919
8:30	50.11	220006	6143	8071	19110	19320	1653	162666	3477	192825	220440	-926
8:45	50.11	222535	6159	7749	25236	16429	1671	162115	3521	189550	222880	-1072
9:00	50.06	224022	6173	7487	30901	14531	1664	160264	3486	185634	224506	-1141
9:15	50.01	227447	6152	6878	36074	13439	1661	160339	3520	184495	228063	-1174
9:30	49.96	227756	6150	6080	40441	13019	1660	157976	3540	181235	228866	-1256
9:45	49.91	228808	6132	5420	44349	12031	1670	156959	3641	179039	230202	-1306
10:00	49.96	228883	6106	5035	47877	11127	1652	155497	3589	175971	230883	-1398
10:15	49.91	228622	6100	4913	50798	10218	1683	153128	3607	172911	230447	-1476
10:30	50.01	228958	6103	4824	53251	9513	1643	152207	3584	170883	231125	-1416
10:45	50.01	228454	6096	4747	55692	9382	1660	149644	3650	168015	230871	-1429
11:00	50.01	226611	6089	4732	57141	8388	1652	147480	3579	164738	229061	-1437
11:15	50.01	224601	6074	4599	58562	7725	1661	145324	3609	161440	227554	-1721
11:30	49.96	223225	6083	4376	59215	7718	1638	143704	3602	159634	226336	-1954
11:45	49.96	222353	6103	4129	59682	7995	1669	142452	3605	158542	225635	-1965
12:00	50.01	220173	6086	3912	59903	7821	1642	140226	3597	156358	223187	-1945
12:15	49.96	218340	6104	3724	60263	7616	1644	138549	3595	154353	221495	-1942
12:30	49.96	216960	6066	3645	59533	7481	1638	138074	3628	153782	220065	-1965
12:45	49.96	215562	6061	3644	59408	7557	1632	136737	3607	152510	218646	-1926
13:00	50.01	212817	6070	3727	59262	7226	1630	134287	3613	149828	215815	-1953
13:15	50.01	209575	6082	3838	59168	6590	1638	131825	3625	146569	212766	-1958
13:30	50.01	208432	6099	3920	59109	6288	1642	131035	3573	145403	211666	-1960
13:45	50.01	208158	6105	3981	58756	5854	1650	131385	3545	145421	211276	-2037
14:00	50.06	207470	6089	4050	58071	5914	1639	131256	3571	145349	210590	-2059
14:15	50.01	206622	6069	4086	57174	5698	1624	131863	3515	145362	210029	-2093
14:30	49.96	207311	6095	3901	56328	5719	1639	133423	3499	147082	210604	-2067
14:45	49.96	207579	6093	3911	54772	5877	1619	135236	3525	148896	211033	-2094
15:00	49.96	208045	6098	3919	52952	6239	1659	136812	3497	151174	211176	-2097
15:15	49.91	206093	6086	3865	50525	6247	1637	137671	3455	151703	209486	-2068
15:30	50.01	206363	6077	3776	47960	6884	1636	139944	3459	154627	209736	-2058
15:45	49.96	204865	6079	3805	44712	7666	1636	140913	3432	156348	208243	-2058
16:00	50.01	202606	5921	3793	41276	8007	1640	141341	3426	157537	205404	-1807
16:15	50.01	201149	6099	3844	37437	8021	1653	143479	3379	159868	203912	-1727
16:30	49.96	201678	6094	3885	32655	9061	1622	147247	3387	165138	203951	-1447
16:45	49.91	201833	6083	3943	27534	10047	1635	150750	3366	170356	203358	-1322
17:00	49.96	201201	6093	3995	21936	12588	1644	152955	3393	175270	202604	-1281
17:15	49.96	198135	6136	3992	16134	14423	1642	153911	3322	178009	199560	-1014
17:30	50.06	198495	6171	3966	10518	17439	1669	157076	3349	184011	200188	-1043
17:45	49.96	199396	6201	4017	6097	20348	1702	159127	3325	189282	200817	-1053
18:00	49.96	200483	6200	4173	2939	21961	1722	161596	3332	193371	201923	-1016
18:15	49.66	201357	6219	4288	1375	23131	1729	162994	3275	195694	203011	-992
18:30	49.91	203663	6211	4556	952	24159	1679	164655	3294	198155	205506	-1019
18:45	50.01	205147	6219	4895	914	24268	1753	165353	3340	199338	206742	-986
19:00	49.96	204108	6208	5217	829	22525	1729	165557	3276	198062	205341	-1011
19:15	49.96	202811	6212	5460	401	22136	1731	164616	3310	196950	203866	-987
19:30	50.06	201344	6188	5687	405	20597	1726	164341	3325	195252	202269	-973
19:45	50.06	198175	6179	5952	226	18104	1746	163547	3310	191997	199064	-966
20:00	50.06	194062	6154	6273	225	15771	1669	161457	3314	187564	194863	-982
20:15	50.00	191063	6151	6488	193	13715	1631	160244	3276	184382	191698	-1003
20:30	50.00	188682	6164	6733	190	13288	1635	157965	3264	181759	189239	-1044
20:45	50.00	186209	6147	7013	203	12448	1622	156279	3301	178993	187013	-1047
21:00	50.06	183313	6154	7241	161	11393	1633	154487	3286	175911	184355	-1067
21:15	50.06	180957	6139	7492	160	10753	1637	152838	3265	173305	182284	-1402
21:30	50.01	178455	6129	7665	162	9657	1638	151588	3315	170628	180154	-1531
21:45	50.01	176519	6126	7853	161	9123	1635	150256	3280	168505	178434	-1678
22:00	50.11	172745	6124	7954	164	8564	1642	147691	3299	164627	175438	-1651
22:15	50.00	172758	6143	8068	165	8588	1642	147120	3351	164525	175077	-1680
22:30	50.00	171415	6147	8263	163	8277	1651					