



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 21.08.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.08.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 20-अगस्त-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.08.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Aug-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	70441	59322	48265	27403	2984	208415
Peak Shortage (MW)	0	481	0	16	0	497
Energy Met (MU)	1537	1376	1120	588	55	4677
Hydro Gen (MU)	375	96	146	91	33	742
Wind Gen (MU)	25	53	38	-	-	116
Solar Gen (MU)*	169.78	84.22	118.71	2.85	0.38	376
Energy Shortage (MU)	0.00	3.60	0.00	0.28	0.00	3.88
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71150	61116	50447	27753	3066	208948
Time Of Maximum Demand Met	19:56	11:00	14:49	21:24	18:56	19:49

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.28	2.44	2.72	74.25	23.03

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13388	0	284.5	187.0	-1.5	455	0.00
	Haryana	10247	0	220.0	159.5	-2.5	416	0.00
	Rajasthan	12568	0	267.4	86.6	2.2	616	0.00
	Delhi	5895	0	126.3	109.7	0.8	389	0.00
	UP	25595	0	502.2	234.7	1.7	722	0.00
	Uttarakhand	2106	0	45.5	17.6	-0.5	65	0.00
	HP	1585	0	33.5	-0.1	1.2	165	0.00
	J&K(UT) & Ladakh(UT)	2385	0	46.7	21.9	0.4	318	0.00
	Chandigarh	355	0	7.0	7.2	-0.3	28	0.00
WR	Railways_NR ISTS	201	0	4.0	3.8	0.2	61	0.00
	Chhattisgarh	5127	0	116.5	71.9	-2.0	277	0.00
	Gujarat	20966	0	430.9	195.5	-1.2	781	0.00
	MP	10903	0	243.5	130.2	0.2	633	1.73
	Maharashtra	24749	1451	513.2	190.2	-3.2	1142	1.87
	Goa	690	0	14.8	12.0	2.6	97	0.00
	DNHDDPDCL	1256	0	27.8	27.9	-0.1	83	0.00
	AMNSIL	832	0	16.8	3.8	0.4	326	0.00
	BALCO	524	0	12.5	12.6	-0.1	14	0.00
SR	Andhra Pradesh	10808	0	225.6	96.8	-0.6	585	0.00
	Telangana	11455	0	231.2	118.3	-2.9	716	0.00
	Karnataka	10375	0	215.7	61.7	-0.5	412	0.00
	Kerala	4105	0	83.8	52.5	0.7	417	0.00
	Tamil Nadu	17112	0	353.5	187.9	0.4	812	0.00
	Puducherry	482	0	10.5	10.0	-0.1	59	0.00
	Bihar	7319	0	146.2	135.8	-0.3	229	0.28
ER	DVC	3444	0	71.9	-37.1	-0.3	369	0.00
	Jharkhand	2052	0	43.7	29.8	-0.5	220	0.00
	Odisha	5670	0	118.2	43.6	-1.7	502	0.00
	West Bengal	9703	0	206.7	74.6	-2.2	293	0.00
	Sikkim	85	0	1.4	1.5	-0.2	12	0.00
	Railways_ER ISTS	21	0	0.2	0.1	0.1	6	0.00
NER	Arunachal Pradesh	167	0	3.0	2.7	-0.4	28	0.00
	Assam	1991	0	36.5	29.1	0.3	284	0.00
	Manipur	175	0	2.5	2.6	-0.1	15	0.00
	Meghalaya	277	0	5.2	-0.5	-0.3	40	0.00
	Mizoram	114	0	1.7	0.6	-0.2	6	0.00
	Nagaland	169	0	2.8	2.4	-0.1	17	0.00
	Tripura	237	0	3.4	3.4	-0.5	57	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	42.7	17.4	-22.6	-18.1
Day Peak (MW)	1946.0	829.5	-977.0	-771.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	255.3	-247.4	120.8	-121.2	-7.5	0.0
Actual(MU)	242.2	-242.9	120.6	-118.3	-8.3	-6.7
O/D/U/D(MU)	-13.1	4.5	-0.3	2.9	-0.8	-6.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2535	9296	3328	3931	255	19345	41
State Sector	6457	10734	8445	1939	155	27729	59
Total	8992	20030	11773	5870	409	47074	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	721	1372	597	673	13	3375	67
Lignite	27	9	49	0	0	84	2
Hydro	375	96	146	91	33	742	15
Nuclear	34	55	76	0	0	165	3
Gas, Naptha & Diesel	23	55	5	0	22	106	2
RES (Wind, Solar, Biomass & Others)	201	140	189	4	0	535	11
Total	1379	1728	1062	768	69	5006	100

Share of RES in total generation (%)	14.56	8.11	17.80	0.56	0.52	10.68
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.19	16.89	38.68	12.47	48.55	28.79

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.077

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	203710	14:57	0
Non-Solar hr	208948	19:49	1618

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 21-Aug-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	700	0.0	17.1	-17.1
2	HVDC	PUSAULI B/B	-	0	107	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	644	675	0.0	4.8	-4.8
4	765 kV	SASARAM-FATEHPUR	1	190	411	0.0	3.9	-3.9
5	765 kV	GAYA-BALIA	1	0	649	0.0	8.2	-8.2
6	400 kV	PUSAULI-VARANASI	1	0	163	0.0	2.5	-2.5
7	400 kV	PUSAULI -ALLAHABAD	1	59	28	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	25	650	0.0	9.0	-9.0
9	400 kV	PATNA-BALIA	2	179	611	0.0	8.2	-8.2
10	400 kV	NAUBATPUR-BALIA	2	108	227	0.0	1.9	-1.9
11	400 kV	BIHARSHARIFF-BALIA	2	277	127	0.3	0.0	0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	54	351	0.0	4.9	-4.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	57	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.2	0.0	0.2
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	63.7	-63.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	464	681	0.0	4.4	-4.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1355	237	13.2	0.0	13.2
3	765 kV	JHARSUGUDA-DURG	2	3	487	0.0	5.5	-5.5
4	400 kV	JHARSUGUDA-RAIGARH	4	0	582	0.0	8.7	-8.7
5	400 kV	RANCHI-SIPAT	2	272	264	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	12	69	0.0	0.7	-0.7
7	220 kV	BUDHIPADAR-KORBA	2	35	134	0.0	1.4	-1.4
ER-WR						13.2	20.7	-7.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	522	0.0	12.4	-12.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1991	0.0	32.9	-32.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2502	0.0	43.1	-43.1
4	400 kV	TALCHER-I/C	2	1073	932	7.2	0.0	7.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	88.4	-88.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	163	98	0.7	0.4	0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	275	127	0.7	0.0	0.7
3	220 kV	ALIPURDUAR-SALAKATI	2	50	33	0.0	0.0	0.0
ER-NER						1.4	0.4	1.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.4	-8.4
NER-NR						0.0	8.4	-8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2511	0.0	59.4	-59.4
2	HVDC	VINDHYACHAL B/B	-	98	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	978	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	153	1715	0.1	20.2	-20.1
5	765 kV	GWALIOR-PHAGI	2	1073	1406	5.9	15.1	-9.1
6	765 kV	JABALPUR-ORAI	2	61	936	0.0	22.1	-22.1
7	765 kV	GWALIOR-ORAI	1	614	0	8.8	0.0	8.8
8	765 kV	SATNA-ORAI	1	0	888	0.0	16.6	-16.6
9	765 kV	BANASKANTHA-CHITORGARH	2	907	716	6.4	5.0	1.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2444	0.0	42.1	-42.1
11	400 kV	ZERDA-KANKROLI	1	285	90	2.7	0.3	2.3
12	400 kV	ZERDA -BHINMAL	1	205	53	1.9	0.2	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	559	368	4.1	2.8	1.3
15	400 kV	NEEMUCH-Chittorgarh	2	600	378	4.1	2.8	1.4
16	220 kV	BHANPURA-RANPUR	1	0	173	0.0	1.2	-1.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	92	0	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	64	11	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						38.5	213.5	-175.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1001	0.0	20.2	-20.2
2	HVDC	RAIGARH-PUGALUR	2	0	1004	0.0	24.0	-24.0
3	765 kV	SOLAPUR-RAICHUR	2	1207	871	6.6	4.1	2.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2213	0.0	30.7	-30.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2154	0.0	30.1	-30.1
6	400 kV	KOLHAPUR-KUDGI	2	1483	0	25.3	0.0	25.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	121	2.0	0.0	2.0
WR-SR						33.9	109.1	-75.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	754	677	732	17.56	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	951	0	893	21.44	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	110	60	77	1.85	
	NER	132kV GELEPHU-SALAKATI	36	0	31	0.75	
	NER	132kV MOTANGA-RANGIA	65	0	46	1.10	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-26	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	61	1.46	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	761	604	664	15.94	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-913	0	-886	-21.26	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-771	-690	-753	-18.07	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-55	-1.32	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.00

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.89	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.22
Nepal	2.54	0.00	13.60	0.00	0.00	0.00	0.00	0.00	16.14
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	41.43	0.00	15.93	0.00	0.00	0.00	0.00	0.00	57.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.89	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.22
Nepal	2.54	0.00	13.60	0.00	0.00	0.00	0.00	0.00	16.14
Bangladesh	-22.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	19.43	0.00	15.93	0.00	0.00	0.00	0.00	0.00	35.36