



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 15.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 14.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 14-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 14.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 15-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs: from RLDCs)	52198	60493	48597	21547	2786	185621
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1139	1392	1124	450	54	4158
Hydro Gen (MU)	133	42	108	36	16	335
Wind Gen (MU)	3	68	62	-	-	133
Solar Gen (MU)*	192.12	160.54	126.50	3.55	1.04	484
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	57820	64132	54672	22657	3056	199057
Time Of Maximum Demand Met	10:26	16:59	09:45	17:56	17:05	09:42

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.032	0.00	0.00	4.34	4.34	80.41	15.25

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7577	0	145.9	56.5	0.6	813	0.00
	Haryana	7558	0	150.0	124.5	-0.9	265	0.00
	Rajasthan	15637	0	297.5	95.1	-1.4	1161	0.00
	Delhi	4171	0	76.6	70.3	0.2	340	0.00
	UP	17135	0	322.3	70.7	-4.7	672	0.00
	Uttarakhand	2167	0	40.4	29.8	0.3	179	0.00
	HP	2126	0	36.9	23.9	-0.6	259	0.00
	J&K(UT) & Ladakh(UT)	2996	0	61.7	53.2	0.5	180	0.00
	Chandigarh	209	0	3.6	3.6	0.1	18	0.00
	Railways NR ISTS	189	0	4.1	3.9	0.2	42	0.00
WR	Chhattisgarh	4549	0	89.9	28.7	-0.3	222	0.00
	Gujarat	20285	0	415.9	160.7	-2.7	691	0.00
	MP	15838	0	283.6	180.5	0.0	460	0.00
	Maharashtra	25267	0	521.4	178.0	3.3	592	0.00
	Goa	717	0	14.5	12.2	1.8	62	0.00
	DNHDDPDCL	1313	0	30.1	29.9	0.2	55	0.00
	AMNSIL	799	0	17.6	9.7	1.0	281	0.00
	BALCO	536	0	12.8	12.9	-0.1	17	0.00
	RIL JAMNAGAR	254	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	9713	0	203.4	66.8	-0.1	536	0.00
SR	Telangana	10120	0	183.3	102.6	-1.8	300	0.00
	Karnataka	15310	0	282.0	107.8	-0.4	847	0.00
	Kerala	4279	0	86.7	66.8	-0.3	229	0.00
	Tamil Nadu	17312	0	358.8	232.4	-1.7	584	0.00
	Puducherry	423	0	9.3	9.0	-0.3	19	0.00
	Bihar	4891	0	90.0	74.0	-2.2	285	0.00
ER	DVC	2977	0	63.8	-22.5	0.9	408	0.00
	Jharkhand	1993	0	36.5	26.2	-2.7	263	0.00
	Odisha	5650	0	109.4	33.6	-3.9	635	0.00
	West Bengal	7575	0	148.3	31.9	-2.3	257	0.00
	Sikkim	93	0	1.4	1.5	-0.1	13	0.00
	Railways ER ISTS	17	0	0.1	0.2	-0.1	0	0.00
NER	Arunachal Pradesh	166	0	2.8	2.7	-0.1	34	0.00
	Assam	1804	0	31.9	24.7	0.4	105	0.00
	Manipur	225	0	3.2	3.3	0.0	15	0.00
	Meghalaya	341	0	5.9	4.9	-0.1	43	0.00
	Mizoram	140	0	2.1	1.2	-0.1	35	0.00
	Nagaland	162	0	2.6	2.4	-0.1	12	0.00
	Tripura	244	0	5.4	5.3	-0.1	41	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	3.5	20.1	-24.4	-13.8
Day Peak (MW)	228.0	906.5	-1035.1	-766.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	158.4	-211.3	215.5	-172.3	9.8	0.0
Actual(MU)	151.9	-195.5	206.5	-180.3	7.9	-9.5
O/D/U/D(MU)	-6.5	15.8	-9.0	-8.0	-1.9	-9.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7593	13405	6038	4305	473	31814	47
State Sector	9414	11865	10258	3597	306	35439	53
Total	17007	25269	16296	7902	779	67253	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	656	1334	595	657	11	3254	72
Lignite	26	19	43	0	0	87	2
Hydro	133	42	108	36	16	335	7
Nuclear	32	53	41	0	0	126	3
Gas, Naptha & Diesel	9	15	4	0	21	49	1
RES (Wind, Solar, Biomass & Others)	216	230	213	6	1	665	15
Total	1071	1692	1005	699	50	4517	100

Share of RES in total generation (%)	20.12	13.58	21.24	0.81	2.12	14.73
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.48	19.19	36.14	5.95	34.48	24.95

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.068

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	199057	9:42	0
Non-Solar hr	196817	17:56	0

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 15-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYAN ARANASI	2	264	1246	0.0	14.9	-14.9
4	765 kV	SASARAM-FATEHPUR	1	34	636	0.0	8.7	-8.7
5	765 kV	GAYA-BALIA	1	0	856	0.0	7.4	-7.4
6	400 kV	PUSAULI-VARANASI	1	0	120	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	24	83	0.0	0.8	-0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	5	877	0.0	12.3	-12.3
9	400 kV	PATNA-BALIA	2	0	1028	0.0	13.3	-13.3
10	400 kV	NAUBATPUR-BALIA	2	117	301	0.0	2.2	-2.2
11	400 kV	BIHARSHARIFF-BALIA	2	186	317	0.0	2.2	-2.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	588	0.0	7.7	-7.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	153	475	0.0	4.3	-4.3
14	220 kV	SAHUPURI-KARMANASA	1	26	7	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	79.0	-78.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	317	1132	0.0	10.5	-10.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	428	963	0.0	8.2	-8.2
3	765 kV	JHARSUGUDA-DURG	2	0	1343	0.0	24.5	-24.5
4	400 kV	JHARSUGUDA-RAIGARH	4	159	354	0.0	1.4	-1.4
5	400 kV	RANCHI-SIPAT	2	147	427	0.0	4.4	-4.4
6	400 kV	JEYPORE-JACDALPUR	2	619	15	0.0	0.0	8.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	154	0.0	2.1	-2.1
8	220 kV	BUDHIPADAR-KORBA	2	112	68	0.5	0.0	0.5
ER-WR						8.9	51.0	-42.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	783	0.0	18.6	-18.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1621	0.0	45.1	-45.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2827	0.0	46.1	-46.1
4	400 kV	TALCHER-UC	2	0	987	0.0	5.1	-5.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	21	0	0.4	0.0	0.4
ER-SR						0.4	109.8	-109.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	292	112	2.2	0.3	1.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	488	135	3.0	0.0	3.0
3	220 kV	ALIPURDUAR-SALAKATI	2	73	19	0.4	0.0	0.4
ER-NER						5.6	0.3	5.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIAL-AGRA	2	657	0	15.5	0.0	15.5
NER-NR						15.5	0.0	15.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2001	0.0	47.6	-47.6
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	982	0.0	22.7	-22.7
4	765 kV	GWALIOR-AGRA	2	329	1386	0.3	12.0	-11.7
5	765 kV	GWALIOR-PHAGI	2	767	1972	3.1	23.9	-20.8
6	765 kV	JABALPUR-ORAI	2	211	743	0.0	15.6	-15.6
7	765 kV	GWALIOR-ORAI	1	923	0	13.5	0.0	13.5
8	765 kV	SATNA-ORAI	1	0	969	0.0	16.2	-16.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2025	53	25.0	0.0	24.9
10	765 kV	VINDHYACHAL-VARANASI	2	168	1391	0.0	14.8	-14.8
11	400 kV	ZERDA-KANKROLI	1	341	0	5.1	0.0	5.1
12	400 kV	ZERDA -BHINMAL	1	236	0	3.5	0.0	3.5
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	718	220	5.0	0.7	4.3
15	400 kV	NEEMUCH-Chittorgarh	2	570	262	4.0	1.5	2.6
16	220 kV	BHANPURA-RANPUR	1	0	119	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	116	0	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	94	1	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						65.8	158.2	-92.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	993	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4007	0.0	80.2	-80.2
3	765 kV	SOLAPUR-RAICHUR	2	269	1568	0.3	8.0	-7.8
4	765 kV	WARDHA-NIZAMABAD	2	0	2115	0.0	25.5	-25.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2490	0.0	33.3	-33.3
6	400 kV	KOLHAPUR-KUDGI	2	1348	0	24.4	0.0	24.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.1	0.0	2.1
WR-SR						26.7	171.1	-144.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	126	71	126	4.87
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	296	228	258	6.20
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-149	-100	-120	-2.89
	NER	132kV GELEPHU-SALAKATI	-75	-57	-63	-1.50
	NER	132kV MOTANGA-RANGIA	-30	-13	-21	-0.50
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	58	1.39
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	815	655	779	18.70
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-957	-852	-953	-22.87
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-766	-412	-574	-13.78
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-78	0	-65	-1.56

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 15-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.33
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.87	0.33	0.00	0.00	0.00	0.00	0.00	0.00	24.20

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.92	0.00	12.69	0.00	0.00	0.00	3.80	0.00	0.00	17.41
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.92	0.00	12.69	0.00	0.00	0.00	3.80	0.00	0.00	17.41

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	-0.33	0.00	0.00	0.00	0.00	0.00	0.00	-0.33	
Nepal	0.92	0.00	12.69	0.00	0.00	0.00	3.80	0.00	0.00	17.41
Bangladesh	-23.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.95	-0.33	12.69	0.00	0.00	0.00	3.80	0.00	0.00	-6.79

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.01	147511	4080	7659	0	9317	2219	122459	2551	139852	148285	61
0:15	50.01	147135	4067	7661	0	8660	2178	122772	2551	139474	147889	27
0:30	50.01	146063	4071	7567	0	8643	2183	121803	2561	138496	146828	45
0:45	50.06	144907	4083	7561	0	8920	2181	120207	2602	137346	145554	65
1:00	49.95	144246	4079	7723	0	8706	2186	119520	2588	136523	144802	80
1:15	50.01	142906	4076	7672	0	8672	2125	118241	2559	135234	143345	93
1:30	50.06	142182	4082	7831	0	8629	2130	117529	2597	134351	142798	50
1:45	50.01	141414	4074	7861	0	8200	2126	117234	2564	133553	142059	77
2:00	50.06	140133	4091	7751	0	8271	2128	116266	2562	132382	141069	47
2:15	50.01	139101	4088	7995	0	8305	2129	115756	2586	131106	140859	86
2:30	50.05	139144	4088	8117	0	8372	1699	115341	2585	131027	140202	68
2:45	50.00	138997	4085	8120	0	8361	1699	115085	2551	130877	139901	60
3:00	50.00	138940	4081	8220	0	8453	1701	114925	2573	130720	139953	62
3:15	50.05	139449	4087	8308	0	8405	1703	115399	2557	131141	140459	42
3:30	50.05	139417	4082	8246	0	8513	1701	115183	2580	131171	140305	42
3:45	50.00	139675	4090	8279	0	8568	1711	115240	2598	131396	140486	60
4:00	50.00	139777	4077	8130	0	8484	1707	115693	2551	131647	140642	42
4:15	49.95	142019	4084	8044	0	8807	1706	117419	2561	133975	142621	40
4:30	50.00	144275	4085	7851	0	8444	1706	119714	2605	136424	144805	8
4:45	50.05	146032	4078	7570	0	9237	1704	121475	2587	138462	146651	24
5:00	50.05	148748	4082	7332	109	10297	1701	123692	2560	141307	149773	14
5:15	50.00	153713	4085	7128	115	11128	1706	127864	2661	146470	154687	-6
5:30	50.00	158022	4081	7040	129	11421	1710	132347	2561	150853	159289	-18
5:45	50.06	162334	4077	6843	179	12869	1704	135777	2581	155312	164030	-19
6:00	50.11	166627	4081	6816	176	14485	1708	138580	2590	159635	168436	-52
6:15	50.00	171449	4084	6868	190	16575	1711	141853	2590	164391	173871	-34
6:30	50.01	176728	4089	6904	288	17919	1711	145649	2604	169536	179164	-17
6:45	49.96	181522	4089	6948	717	18818	1712	149627	2629	173857	184540	-49
7:00	50.01	183838	4092	6898	1617	19283	1724	150761	2654	175232	187029	-90
7:15	50.01	187112	4094	6831	3351	19497	1730	151601	2722	176930	189826	-39
7:30	50.06	189157	4086	6740	5922	19709	1707	149907	2739	176495	190810	-45
7:45	50.06	188257	4094	6596	9331	17980	1706	146092	2762	172330	188561	-6
8:00	50.06	188237	4096	6260	13231	16193	1711	141992	2772	168746	186255	20
8:15	50.01	190642	4092	5813	17954	15622	1734	138256	2824	166875	186295	29
8:30	50.01	191555	4091	5472	22413	14410	1722	133973	2854	163670	184935	37
8:45	50.01	193076	4086	5262	35117	13421	1729	130470	2810	152697	192895	166
9:00	50.01	193523	4087	4948	42410	12598	1743	127068	2807	146165	195661	181
9:15	50.01	197020	4090	4542	47003	12308	1728	127132	2836	145475	199639	-9
9:30	50.06	197528	4068	4074	50779	12017	1726	124465	2809	142675	199938	-21
9:45	50.01	199019	4050	3837	54294	10997	1707	123298	2903	140888	201086	-8
10:00	50.01	198197	4047	3748	56594	10111	1708	121303	2981	137855	200492	-46
10:15	49.91	197725	4054	3530	58491	9288	1716	119516	2919	135704	199514	-39
10:30	49.95	197231	4064	3269	60155	9551	1709	117282	2964	133807	198994	-33
10:45	49.95	195893	4065	3082	61047	9252	1738	115247	2896	131764	197327	-54
11:00	49.95	194770	4060	2802	62330	9020	1712	113082	2883	129638	195889	14
11:15	49.90	192532	4053	2655	63271	8187	1741	110936	2894	126606	193737	29
11:30	49.95	191332	4044	2544	64117	8257	1741	109194	2888	124671	192785	14
11:45	49.85	190469	4234	2493	64739	8282	1768	107871	2929	123237	192316	17
12:00	50.01	189572	4245	2374	65377	8610	1766	106045	2886	121821	191303	-43
12:15	49.91	189062	4236	2276	64650	8585	1757	105718	2920	122136	190142	-4
12:30	49.96	188384	4238	2194	64946	8039	1767	105395	2807	121244	189386	-58
12:45	49.96	187354	4240	2077	64746	7696	1773	104726	2879	120531	188137	-50
13:00	50.06	184899	4655	2008	64355	7772	1769	102830	2793	118536	186182	-49
13:15	49.96	181461	4667	1944	62624	7122	1766	101935	2830	116893	182888	-71
13:30	50.01	180796	4673	1911	61650	7496	1751	101650	2822	117235	181953	-75
13:45	49.96	181632	4675	1833	61388	7430	1651	102619	2869	118411	182465	-116
14:00	49.96	181914	4674	1753	60536	7619	1691	104011	2809	119625	183093	-138
14:15	50.01	182614	4680	1751	58647	7479	1655	106756	2720	122216	183688	-86
14:30	50.01	183946	4674	1743	56730	7516	1706	110209	2766	125473	185344	-56
14:45	50.06	185615	4680	1767	55022	7568	1727	113550	2741	128826	187055	-69
15:00	50.06	185795	4675	1763	52283	7952	1719	116454	2663	131749	187509	-67
15:15	50.01	185032	4671	1828	49464	8150	1725	118556	2647	133740	187041	-54
15:30	50.06	185497	4677	1859	45861	9048	1716	121937	2687	137777	187785	-21
15:45	50.01	185274	4673	1897	41648	9687	1955	125690	2607	141729	188157	-111
16:00	49.96	185024	4669	1972	36149	10560	2370	129479	2574	146903	187773	-82
16:15	50.11	182721	4665	2075	30503	11137	2838	132498	2546	150143	186262	-46
16:30	49.91	184433	4669	2125	24146	12803	3044	138569	2575	158162	187931	-65
16:45	49.91	185671	4678	2229	17907	15122	3114	144182	2561	165535	189793	-59
17:00	50.06	187267	4674	2367	12028	17566	3269	149227	2516	172872	191647	-166
17:15	49.91	187833	4675	2512	7316	18957	3863	152790	2501	178005	192614	-169
17:30	50.01	189822	4675	2835	3978	21368	4127	155752	2497	183009	195232	-280
17:45	49.96	194547	4682	3220	1921	24563	4232	158648	2475	189406	199741	-240
18:00	50.17	196344	4668	3589	1170	27159	4089	158636	2501	191585	201812	-132
18:15	50.01	195415	4696	4143	926	26815	3572	158077	2375	190346	200604	-96
18:30	50.01	194582	4689	4670	331	26593	2385	157672	2432	189581	198772	-55
18:45	50.01	193142	4697	5169	265	26761	2087	155496	2549	187708	197024	-36
19:00	50.06	189580	4694	5542	253	25920	1961	152822	2534	183785	193726	-45
19:15	49.96	186784	4696	5721	242	24612	1953	150742	2487	180821	190453	-38
19:30	50.01	184401	4694	5790	0	23924	1901	148468	2485	178611	187262	-40
19:45	49.96	181595	4700	5860	0	23410	1921	145557	2501	175735	183949	7
20:00	50.07	178068	4697	6045	0	21215	1937	143742	2436	172023	180072	-69
20:15	50.02	174584	4695	6282	0	19347	1844	142093	2531	168302	176792	-19
20:30	50.04	172480	4687	6484	0	18483	1811	140783	2481	165996	174729	-23
20:45	49.99	169939	4701	6615	0	17929	1821	138383	2480	163324	171929	23
21:00	50.04	167412	4686	6607	0	17428	1839	136227	2501	160805	169288	-23
21:15	49.99	164747	4698	6610	0	16073	1866	134759	2524	158137	166530	3
21:30	50.04	162363	4687	6554	0	15275	1846	133181	2478	155809	164021	28
21:45	50.04	160099	4702	6566	0	14256	1842	131856	2510	153533	161732	19
22:00	50.04	157111	4703	6596	0	13326	1846	129648	2546	150515	158665	-38
22:15	49.99	157526	4704	6493	0	13331	1875	130136	2504	151033	159043	3
22:30	49.94	155476	4702	6396	0	13200	1854	128332	2595	149080	157079	40
22:45	49.94	154017	4701	6341	0	13104	1873	126830	2513	147676	155362	4
23:00	49.94	152213	4702									