



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.09.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.09.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-सितंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.09.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Sep-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79096	56943	43246	29179	3654	212118
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1764	1379	993	642	72	4850
Hydro Gen (MU)	346	108	154	107	36	751
Wind Gen (MU)	19	215	278	-	-	512
Solar Gen (MU)*	178.55	90.82	113.09	3.20	1.04	387
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	80132	60656	44610	30225	3724	214305
Time Of Maximum Demand Met	22:22	09:31	09:07	21:21	18:01	18:54

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.045	0.00	0.00	6.86	6.86	76.21	16.93

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13352	0	292.7	192.2	-0.6	838	0.00
	Haryana	11346	0	253.2	199.4	-0.6	489	0.00
	Rajasthan	15008	0	338.6	123.4	-1.2	697	0.00
	Delhi	6850	0	138.2	132.1	0.1	310	0.00
	UP	28968	0	586.3	265.2	-0.2	525	0.00
	Uttarakhand	2422	0	50.3	25.5	0.4	160	0.00
	HP	1746	0	36.6	6.6	-0.4	137	0.00
	J&K(UT) & Ladakh(UT)	2796	0	57.0	31.5	2.9	347	0.00
	Chandigarh	320	0	6.2	6.0	0.3	29	0.00
	Railways_NR ISTS	217	0	4.6	4.0	0.6	48	0.00
WR	Chhattisgarh	5113	0	108.7	55.2	-1.8	230	0.00
	Gujarat	22758	0	473.3	213.1	0.0	1643	0.00
	MP	11892	0	251.4	111.0	-0.4	489	0.00
	Maharashtra	21903	0	463.3	158.4	-6.7	682	0.00
	Goa	624	0	17.8	10.9	6.5	77	0.00
	DNHDDPDCL	1293	0	28.2	28.9	-0.7	101	0.00
	AMNSIL	770	0	17.2	10.1	0.1	250	0.00
	BALCO	536	0	12.8	12.7	0.1	11	0.00
	RIL JAMNAGAR	254	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	9513	0	208.2	28.4	-1.7	638	0.00
SR	Telangana	8577	0	170.3	43.0	0.3	669	0.00
	Karnataka	9636	0	188.8	11.6	-3.8	782	0.00
	Kerala	3872	0	75.4	43.8	-0.7	386	0.00
	Tamil Nadu	15286	0	340.4	100.7	-0.8	948	0.00
	Puducherry	449	0	9.6	9.1	-0.1	38	0.00
ER	Bihar	8136	0	171.1	159.3	-0.4	377	0.00
	DVC	3139	0	66.4	-33.7	-1.1	294	0.00
	Jharkhand	2242	0	45.5	33.4	0.0	466	0.00
	Odisha	6229	0	130.0	56.8	-1.6	596	0.00
	West Bengal	10845	0	228.1	88.7	-1.8	388	0.00
	Sikkim	65	0	1.0	1.2	-0.1	8	0.00
NER	Railways_ER ISTS	16	0	0.1	0.2	0.0	0	0.00
	Arunachal Pradesh	207	0	3.5	3.2	-0.2	27	0.00
	Assam	2527	0	48.4	41.2	-0.3	105	0.00
	Manipur	228	0	3.1	3.2	-0.1	33	0.00
	Meghalaya	292	0	5.3	2.5	-0.2	10	0.00
	Mizoram	105	0	2.3	0.7	0.0	19	0.00
	Nagaland	170	0	3.0	2.6	-0.1	23	0.00
	Tripura	325	0	6.4	5.7	0.1	15	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	55.5	19.4	-24.6	-17.5
Day Peak (MW)	2380.6	990.2	-1035.8	-1171.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	471.0	-265.8	-184.4	-28.3	7.5	0.0
Actual(MU)	494.1	-269.9	-177.6	-67.3	7.4	-13.3
O/D/U/D(MU)	23.1	-4.1	6.7	-38.9	-0.1	-13.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5282	11444	5138	3280	55	25198	46
State Sector	6544	13449	7583	1809	199	29584	54
Total	11826	24893	12721	5089	254	54782	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	748	1239	574	665	11	3237	62
Lignite	26	17	51	0	0	94	2
Hydro	346	108	154	107	36	751	14
Nuclear	31	59	41	0	0	132	3
Gas, Naptha & Diesel	7	13	4	0	22	46	1
RES (Wind, Solar, Biomass & Others)	204	309	415	6	1	936	18
Total	1361	1746	1240	778	70	5195	100

Share of RES in total generation (%)	15.00	17.72	33.49	0.78	1.50	18.01
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.72	27.30	49.21	14.52	53.34	35.01

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.023
Based on State Max Demands	1.073

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	205004	14:59	0
Non-Solar hr	214305	18:54	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 29-Sep-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	353	0.0	7.2	-7.2
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	339	757	0.0	5.8	-3.8
4	765 kV	SASARAM-FATEHPUR	1	151	426	0.0	3.4	-3.4
5	765 kV	GAYA-BALIA	1	0	995	0.0	16.7	-16.7
6	400 kV	PUSAULI-VARANASI	1	0	76	0.0	1.2	-1.2
7	400 kV	PUSAULI-ALLAHABAD	1	0	97	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	1004	0.0	16.0	-16.0
9	400 kV	PATNA-BALIA	2	0	929	0.0	13.9	-13.9
10	400 kV	NAUBATPUR-BALIA	2	0	373	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	147	298	0.0	1.2	-1.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	632	0.0	9.8	-9.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	465	377	0.0	4.3	-4.3
14	220 kV	SAHUPURI-KARMANASA	1	0	67	0.0	2.1	-2.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	89.1	-88.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	534	910	0.0	7.2	-7.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2327	0	41.1	0.0	41.1
3	765 kV	JHARSUGUDA-DURG	2	260	339	0.0	1.2	-1.2
4	400 kV	JHARSUGUDA-RAIGARH	4	380	233	2.0	0.0	2.0
5	400 kV	RANCHI-SIPAT	2	547	0	10.2	0.0	10.2
6	400 kV	JEYPORE-JACDALPUR	2	0	687	0.0	8.7	-8.7
7	220 kV	BUDHIPADAR-RAIGARH	1	67	89	0.0	0.5	-0.5
8	220 kV	BUDHIPADAR-KORBA	2	149	44	1.2	0.0	1.2
ER-WR						54.5	17.6	36.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	805	0	17.1	0.0	17.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1226	0.0	16.8	-16.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2048	0.0	24.7	-24.7
4	400 kV	TALCHER I/C	2	972	0	9.7	0.0	9.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						17.1	41.5	-24.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	44	358	0.0	4.0	-3.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	778	0.0	12.9	-12.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	149	0.0	2.2	-2.2
ER-NER						0.0	19.0	-19.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	503	0.0	12.1	-12.1
NER-NR						0.0	12.1	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5546	0.0	97.1	-97.1
2	HVDC	VINDHYACHAL B/B	-	0	510	0.0	9.1	-9.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	21.2	-21.2
4	765 kV	GWALIOR-AGRA	2	0	3292	0.0	60.9	-60.9
5	765 kV	GWALIOR-PHAGI	2	285	2088	0.2	28.9	-28.8
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	60.2	-60.2
7	765 kV	GWALIOR-ORAI	1	752	0	12.1	0.0	12.1
8	765 kV	SATNA-ORAI	1	0	1257	0.0	22.8	-22.8
9	765 kV	BANASKANTHA-CHITORGARH	2	286	1014	0.2	8.9	-8.7
10	765 kV	VINDHYACHAL-VARANASI	2	0	3903	0.0	76.3	-76.3
11	400 kV	ZERDA-KANKROLI	1	190	157	1.1	1.0	0.0
12	400 kV	ZERDA -BHINMAL	1	131	109	0.7	0.7	0.0
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	136	824	0.1	10.7	-10.6
15	400 kV	NEEMUCH-Chittorgarh	2	59	901	0.0	13.5	-13.5
16	220 kV	BHANPURA-RANPUR	1	0	121	0.0	2.3	-2.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	46	44	0.1	0.3	-0.2
19	220 kV	MALANPUR-AURAIYA	1	24	58	0.0	0.7	-0.7
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						14.6	417.1	-402.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	909	0	19.3	0.0	19.3
2	HVDC	RAIGARH-PUGALUR	2	2876	0	56.2	0.0	56.2
3	765 kV	SOLAPUR-RAICHUR	2	2413	0	36.7	0.0	36.7
4	765 kV	WARDHA-NIZAMABAD	2	1080	971	8.6	1.8	6.8
5	765 kV	WARORA-WARANGAL(NEW)	2	726	717	5.0	1.5	3.5
6	400 kV	KOLHAPUR-KUDGI	2	2316	0	45.5	0.0	45.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	98	1.9	1.9	0.0
WR-SR						173.2	3.3	170.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1347	1108	1323	31.76
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	873	713	833	20.00
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	125	57	96	2.29
	NER	132kV GELEPHU-SALAKATI	18	0	10	0.23
	NER	132kV MOTANGA-RANGIA	66	38	52	1.25
NEPAL	NR	NEPAL IMPORT (FROM UP)	-36	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	60	0	18	0.42
	ER	NEPAL IMPORT (FROM BIHAR)	184	145	161	3.87
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	818	300	630	15.13
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-989	-963	-982	-23.56
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1171	-541	-727	-17.45
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-49	0	-42	-1.00

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Sep-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.20
Bangladesh	24.14	0.21	0.00	0.00	0.00	0.00	0.00	0.00	24.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.34	0.21	0.00	0.00	0.00	0.00	0.00	0.00	24.55

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	33.47	0.00	1.09	0.00	0.00	0.14	0.00	0.00	34.70
Nepal	9.09	4.84	0.00	0.00	0.00	5.89	0.00	0.00	19.82
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	42.56	4.84	1.09	0.00	0.00	6.03	0.00	0.00	54.52

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	33.47	0.00	1.09	0.00	0.00	0.14	0.00	0.00	34.70
Nepal	8.89	4.84	0.00	0.00	0.00	5.89	0.00	0.00	19.62
Bangladesh	-24.14	-0.21	0.00	0.00	0.00	0.00	0.00	0.00	-24.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	18.22	4.63	1.09	0.00	0.00	6.03	0.00	0.00	29.97

