



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 04.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.08.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 3-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 04-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71539	61231	46662	26208	3194	208834
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1560	1428	1228	581	66	4864
Hydro Gen (MU)	412	101	192	107	37	850
Wind Gen (MU)	39	124	105	-	-	268
Solar Gen (MU)*	217.32	124.08	114.91	2.91	0.53	460
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72646	61991	58459	28367	3224	209454
Time Of Maximum Demand Met	21:31	19:38	09:27	00:01	20:55	22:25

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.046	0.19	1.30	6.48	7.96	77.16	14.88

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13264	0	292.3	171.6	-0.6	357	0.00
	Haryana	10418	0	214.0	159.4	-3.3	214	0.00
	Rajasthan	13555	0	316.2	107.0	-9.3	265	0.00
	Delhi	6489	0	124.0	113.0	-1.0	229	0.00
	UP	25475	0	470.3	205.2	-2.6	309	0.00
	Uttarakhand	2132	0	46.0	20.3	-0.3	115	0.00
	HP	1644	0	34.7	-6.6	-0.8	83	0.00
	J&K(UT) & Ladakh(UT)	2598	0	52.6	27.5	0.0	244	0.00
	Chandigarh	330	0	6.3	6.3	0.0	24	0.00
	Railways NR ISTS	205	0	4.1	3.8	0.3	39	0.00
WR	Chhattisgarh	5682	0	126.2	81.6	0.4	278	0.00
	Gujarat	20084	0	439.4	166.6	1.6	970	0.00
	MP	11066	0	238.3	108.1	0.0	480	0.00
	Maharashtra	24696	0	545.5	192.5	8.1	1308	0.00
	Goa	506	0	13.1	10.4	2.2	77	0.00
	DNHDDPDCL	1292	0	30.2	29.7	0.5	103	0.00
	AMNSIL	872	0	16.9	8.1	0.1	305	0.00
	BALCO	531	0	12.7	12.7	0.0	10	0.00
	RIL JAMNAGAR	248	0	5.7	5.7	0.0	0	0.00
	Andhra Pradesh	12879	0	261.8	89.8	0.7	821	0.00
SR	Telangana	15474	0	291.6	138.4	-0.6	675	0.00
	Karnataka	13430	0	249.4	81.9	2.9	814	0.00
	Kerala	3471	0	70.3	30.8	-3.0	306	0.00
	Tamil Nadu	15700	0	345.9	161.2	-3.6	973	0.00
	Puducherry	437	0	9.5	9.0	-0.1	38	0.00
ER	Bihar	7216	0	131.6	129.6	-6.9	249	0.00
	DVC	3072	0	66.4	-40.2	-1.0	241	0.00
	Jharkhand	2015	0	40.0	33.0	-2.1	91	0.00
	Odisha	6488	0	135.3	50.7	-1.2	585	0.00
	West Bengal	10260	0	206.9	78.6	-2.8	445	0.00
	Sikkim	66	0	0.9	0.9	0.0	25	0.00
	Railways ER ISTS	13	0	0.2	0.1	0.1	0	0.00
NER	Arunachal Pradesh	188	0	3.4	3.3	-0.4	35	0.00
	Assam	2163	0	43.1	35.8	0.8	124	0.00
	Manipur	199	0	3.0	3.2	-0.2	29	0.00
	Meghalaya	314	0	5.6	1.2	-0.2	25	0.00
	Mizoram	110	0	2.2	0.7	-0.1	22	0.00
	Nagaland	163	0	3.0	2.6	-0.1	19	0.00
	Tripura	301	0	5.8	4.0	0.1	38	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	52.9	15.4	-23.5	-26.1
Day Peak (MW)	2269.2	854.7	-1000.5	-1456.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	202.4	-238.5	134.9	-95.7	-3.2	0.0
Actual(MU)	167.5	-238.8	155.6	-100.0	-4.0	-19.7
O/D/UD(MU)	-34.9	-0.3	20.7	-4.4	-0.8	-19.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5231	15478	8068	5180	452	34409	49
State Sector	9079	14880	8727	2469	199	35354	51
Total	14310	30358	16795	7649	651	69763	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	753	1334	626	638	14	3365	64
Lignite	23	10	39	0	0	72	1
Hydro	412	101	192	107	37	850	16
Nuclear	37	35	46	0	0	119	2
Gas, Naptha & Diesel	13	24	5	0	21	63	1
RES (Wind, Solar, Biomass & Others)	264	249	245	5	1	763	15
Total	1502	1753	1153	750	73	5232	100

Share of RES in total generation (%)	17.54	14.23	21.22	0.68	0.74	14.59
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	47.45	21.99	41.93	14.97	51.68	33.10

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.072
Based on State Max Demands	1.122

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	207826	10:59	0
Non-Solar hr	209454	22:25	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 04-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	753	0.0	16.9	-16.9
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	942	834	0.0	3.0	-3.0
4	765 kV	SASARAM-FATEHPUR	1	352	434	0.0	2.3	-2.3
5	765 kV	GAYA-BALIA	1	141	685	0.0	7.1	-7.1
6	400 kV	PUSAULI-VARANASI	1	0	168	0.0	2.5	-2.5
7	400 kV	PUSAULI-ALLAHABAD	1	78	53	0.3	0.0	0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	152	708	0.0	9.0	-9.0
9	400 kV	PATNA-BALIA	2	268	754	0.0	7.3	-7.3
10	400 kV	NAUBATPUR-BALIA	2	137	232	0.0	1.7	-1.7
11	400 kV	BIHARSHARIFF-BALIA	2	345	260	0.6	0.0	0.6
12	400 kV	MOTIHARI-GORAKHPUR	2	102	460	0.0	5.4	-5.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	322	331	0.0	1.4	-1.4
14	220 kV	SAHUPURI-KARAMNESA	1	0	91	0.0	0.3	-0.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	1.4	-57.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1331	231	13.6	0.0	13.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1060	1004	7.4	0.0	7.4
3	765 kV	JHARSUGUDA-DURG	2	0	683	0.0	7.7	-7.7
4	400 kV	JHARSUGUDA-RAIGARH	4	365	506	0.0	2.2	-2.2
5	400 kV	RANCHI-SIPAT	2	162	393	0.0	0.4	-0.4
6	400 kV	JEYPORE-JAGDALPUR	2	569	117	4.0	0.2	3.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	126	0.0	1.8	-1.8
8	220 kV	BUDHIPADAR-KORBA	2	44	157	0.0	1.6	-1.6
						ER-WR	25.0	11.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	629	0.0	15.0	-15.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1755	0.0	34.6	-34.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3051	0.0	41.1	-41.1
4	400 kV	TALCHER-I/C	2	686	963	5.2	0.0	5.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	0.0	-90.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	151	153	0.5	0.8	-0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	129	336	0.0	3.1	-3.1
3	220 kV	ALIPURDUAR-SALAKATI	2	20	63	0.0	0.9	-0.9
						ER-NER	0.5	-4.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
						NER-NR	0.0	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1970	0.0	41.4	-41.4
2	HVDC	VINDHYACHAL-B/B	-	0	156	0.0	3.6	-3.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2363	0.0	38.3	-38.3
4	765 kV	GWALIOR-AGRA	2	1096	1912	6.9	14.5	-7.6
5	765 kV	GWALIOR-PHAGI	2	1980	1930	12.6	19.1	-6.5
6	765 kV	JABALPUR-ORAI	2	598	1072	0.0	21.6	-21.6
7	765 kV	GWALIOR-ORAI	1	761	259	9.3	1.0	8.4
8	765 kV	SATNA-ORAI	1	0	1045	0.0	14.2	-14.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1899	0	20.7	0.0	20.7
10	765 kV	VINDHYACHAL-VARANASI	2	184	2500	0.0	30.1	-30.1
11	400 kV	ZERDA-KANKROLI	1	380	0	5.1	0.0	5.1
12	400 kV	ZERDA-BHINMAL	1	262	0	3.5	0.0	3.5
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	927	424	8.0	2.5	5.5
15	400 kV	NEEMUCH-Chittorgarh	2	822	536	6.4	3.8	2.6
16	220 kV	BHANPURA-RANPUR	1	0	138	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	132	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	102	4	0.9	0.0	0.9
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	74.8	-120.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	14.4	-14.4
2	HVDC	RAIGARH-PUGAUR	2	0	5016	0.0	64.2	-64.2
3	765 kV	SOLAPUR-RAICHUR	2	2048	1585	12.2	5.7	6.4
4	765 kV	WARDHAN-NIZAMABAD	2	597	3049	1.6	30.7	-29.1
5	765 kV	WARORA-WARANGAL(NEW)	2	502	3007	1.2	29.7	-28.5
6	400 kV	KOLHAPUR-KUDGI	2	1449	0	20.4	0.0	20.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.1	0.0	2.1
						WR-SR	37.5	-107.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1263	1189	1263	30.37
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	975	812	866	20.79
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	88	-56	45	1.08
	NER	132kV GELEPHU-SALAKATI	24	0	5	0.13
	NER	132kV MOTANGA-RANGIA	46	0	23	0.56
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.34
	ER	NEPAL IMPORT (FROM BIHAR)	151	84	125	2.99
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	662	310	501	12.02
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-952	-938	-942	-22.60
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1456	-818	-1085	-26.05
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-48	0	-38	-0.90

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 04-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06
Bangladesh	23.25	0.14	0.00	0.00	0.00	0.00	0.00	0.00	23.39
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.31	0.14	0.00	0.00	0.00	0.00	0.00	0.00	23.45

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.97	0.00	1.40	0.00	0.00	0.28	0.00	0.00	51.65
Nepal	8.40	0.14	4.97	0.00	0.00	2.46	0.00	0.00	15.97
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	58.37	0.14	6.37	0.00	0.00	2.74	0.00	0.00	67.62

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.97	0.00	1.40	0.00	0.00	0.28	0.00	0.00	51.65
Nepal	8.34	0.14	4.97	0.00	0.00	2.46	0.00	0.00	15.91
Bangladesh	-23.25	-0.14	0.00	0.00	0.00	0.00	0.00	0.00	-23.39
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	35.06	0.00	6.37	0.00	0.00	2.74	0.00	0.00	44.17

