



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 13.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 12.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 12-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 12.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 13-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	78200	65885	46877	31014	3514	224873
Peak Shortage (MW)	125	0	0	0	0	125
Energy Met (MU)	1694	1549	1070	673	70	5056
Hydro Gen (MU)	428	110	174	102	41	855
Wind Gen (MU)	54	177	206	-	-	437
Solar Gen (MU)*	164.93	133.91	104.36	3.45	0.34	407
Energy Shortage (MU)	0.40	0.00	0.00	0.00	0.00	0.40
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79034	69027	49895	31064	3560	224923
Time Of Maximum Demand Met	22:26	16:55	07:43	23:23	18:35	19:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.00	8.54	8.54	83.81	7.65

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13765	0	291.0	195.2	-2.0	634	0.00
	Haryana	11471	0	242.3	181.5	-2.5	323	0.00
	Rajasthan	16596	0	370.1	147.4	-1.2	616	0.00
	Delhi	6314	0	131.9	117.7	-1.1	283	0.00
	UP	27807	0	519.4	230.7	1.2	628	0.00
	Uttarakhand	2272	0	46.5	27.3	0.8	185	0.07
	HP	1666	0	34.3	-11.2	-0.2	78	0.00
	J&K(UT) & Ladakh(UT)	2471	125	48.2	23.7	0.2	210	0.33
	Chandigarh	305	0	6.2	6.4	-0.1	12	0.00
	Railways NR ISTS	204	0	4.0	3.7	0.3	48	0.00
WR	Chhattisgarh	6480	0	140.2	93.0	-0.4	406	0.00
	Gujarat	23695	0	491.7	186.7	-0.6	1092	0.00
	MP	12603	0	275.2	136.9	-0.8	365	0.00
	Maharashtra	25836	0	559.8	216.3	-0.9	724	0.00
	Goa	616	0	14.6	12.0	2.2	124	0.00
	DNHDDPDCL	1351	0	31.2	31.3	-0.1	53	0.00
	AMNSIL	816	0	18.4	11.8	0.0	273	0.00
	BALCO	532	0	12.7	12.7	0.0	21	0.00
	RIL JAMNAGAR	249	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	9741	0	211.0	30.2	-1.6	557	0.00
SR	Telangana	11178	0	216.9	75.2	-1.8	652	0.00
	Karnataka	10568	0	206.2	29.0	-2.1	637	0.00
	Kerala	4126	0	81.1	41.5	-3.1	91	0.00
	Tamil Nadu	16411	0	345.4	119.9	-3.3	945	0.00
	Puducherry	415	0	9.2	8.8	-0.2	64	0.00
	Bihar	8026	0	168.3	158.4	-1.1	403	0.00
ER	DVC	3218	0	68.8	-35.5	-0.2	566	0.00
	Jharkhand	2330	0	45.5	36.9	-0.8	232	0.00
	Odisha	7302	0	146.4	59.1	-0.8	487	0.00
	West Bengal	11451	0	242.1	119.4	-2.4	222	0.00
	Sikkim	84	0	1.3	1.3	0.0	21	0.00
	Railways ER ISTS	28	0	0.2	0.1	0.0	5	0.00
NER	Arunachal Pradesh	200	0	3.6	3.6	-0.4	19	0.00
	Assam	2272	0	45.4	39.4	0.2	221	0.00
	Manipur	209	0	3.2	3.1	0.1	75	0.00
	Meghalaya	352	0	6.2	1.4	-0.1	34	0.00
	Mizoram	133	0	1.9	0.8	-0.5	0	0.00
	Nagaland	162	0	2.7	2.8	-0.5	15	0.00
	Tripura	348	0	6.7	5.1	0.2	70	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	51.8	18.6	-24.2	-31.4
Day Peak (MW)	2404.4	905.5	-1017.4	-1466.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	333.0	-242.2	-59.1	-33.4	1.6	0.0
Actual(MU)	322.2	-228.4	-75.6	-27.2	1.4	-7.7
O/D/U/D(MU)	-10.9	13.8	-16.5	6.1	-0.1	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4962	11383	7252	4370	452	28419	50
State Sector	8584	11034	6033	3049	199	28899	50
Total	13546	22416	13285	7419	651	57317	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	725	1396	618	654	12	3404	63
Lignite	22	12	33	0	0	67	1
Hydro	428	110	174	102	41	855	16
Nuclear	39	48	47	0	0	134	2
Gas, Naptha & Diesel	16	28	4	0	20	67	1
RES (Wind, Solar, Biomass & Others)	227	312	336	6	0	882	16
Total	1457	1905	1211	762	73	5409	100

Share of RES in total generation (%)	15.58	16.39	27.77	0.79	0.46	16.31
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	47.62	24.68	45.95	14.22	56.74	34.58

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.034
Based on State Max Demands	1.083

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	219315	15:01	0
Non-Solar hr	224923	19:42	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 13-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	751	0.0	18.0	-18.0
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.2	-2.2
3	765 kV	GAYA-VARANASI	2	940	578	0.0	0.1	-0.1
4	765 kV	SASARAM-FATEHPUR	1	412	327	0.0	0.6	-0.6
5	765 kV	GAYA-BALIA	1	0	804	0.0	9.2	-9.2
6	400 kV	PUSAULI-VARANASI	1	14	111	0.0	1.8	-1.8
7	400 kV	PUSAULI-ALLAHABAD	1	20	57	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	303	728	0.0	6.7	-6.7
9	400 kV	PATNA-BALIA	2	330	712	0.0	6.3	-6.3
10	400 kV	NAUBATPUR-BALIA	2	134	302	0.0	0.9	-0.9
11	400 kV	BIHARSHARIFF-BALIA	2	502	123	3.1	0.0	3.1
12	400 kV	MOTIHARI-GORAKHPUR	2	156	462	0.0	4.4	-4.4
13	400 kV	BIHARSHARIFF-SAHUPURI	2	349	333	0.0	0.8	-0.8
14	220 kV	SAHUPURI-KARAMNESA	1	2	72	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	3.8	-48.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	969	319	6.9	0.0	6.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2144	0	34.0	0.0	34.0
3	765 kV	JHARSUGUDA-DURG	2	195	474	0.0	2.7	-2.7
4	400 kV	JHARSUGUDA-RAIGARH	4	367	417	0.0	0.9	-0.9
5	400 kV	RANCHI-SIPAT	2	466	129	6.3	0.0	6.3
6	400 kV	JEYPORE-JAGDALPUR	2	193	523	0.0	4.2	-4.2
7	220 kV	BUDHIPADAR-RAIGARH	1	155	142	0.0	0.9	-0.9
8	220 kV	BUDHIPADAR-KORBA	2	136	148	0.0	0.7	-0.7
						ER-WR	48.0	39.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	506	116	4.9	0.0	4.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1759	0.0	35.9	-35.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	1998	0.0	19.3	-19.3
4	400 kV	TALCHER-I/C	2	764	532	3.9	0.0	3.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	4.9	-50.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	167	324	0.4	2.6	-2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	119	533	0.0	6.3	-6.3
3	220 kV	ALIPURDUAR-SALAKATI	2	24	110	0.0	1.3	-1.3
						ER-NER	0.4	-9.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.4	-8.4
						NER-NR	0.0	-8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4035	0.0	84.3	-84.3
2	HVDC	VINDHYACHAL-B/B	-	0	156	0.0	3.6	-3.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	157	2479	0.1	29.3	-29.2
5	765 kV	GWALIOR-PHAGI	2	1132	1827	4.5	20.6	-16.1
6	765 kV	JABALPUR-ORAI	2	0	1447	0.0	33.8	-33.8
7	765 kV	GWALIOR-ORAI	1	725	0	11.5	0.0	11.5
8	765 kV	SATNA-ORAI	1	0	1107	0.0	16.8	-16.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1502	1133	6.0	5.9	0.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3410	0.0	54.4	-54.4
11	400 kV	ZERDA-KANKROLI	1	311	143	1.9	0.5	1.4
12	400 kV	ZERDA-BHINMAL	1	214	99	1.3	0.3	1.0
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	423	529	2.8	4.0	-1.2
15	400 kV	NEEMUCH-Chittorgarh	2	289	756	1.1	6.4	-5.3
16	220 kV	BHANPURA-RANPUR	1	0	140	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.7	-2.7
18	220 kV	MEHGAON-AURAIYA	1	95	25	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	70	42	0.3	0.1	0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	30.0	-271.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	999	308	13.0	3.3	9.7
2	HVDC	RAIGARH-PUGAULUR	2	0	604	0.0	14.3	-14.3
3	765 kV	SOLAPUR-RAICHUR	2	2913	0	41.8	0.0	41.8
4	765 kV	WARDHAN-NIZAMABAD	2	1443	1482	9.6	6.7	2.9
5	765 kV	WARORA-WARANGAL(NEW)	2	1174	1472	7.7	6.8	0.9
6	400 kV	KOLHAPUR-KUDGI	2	2066	0	40.1	0.0	40.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	117	2.0	0.0	2.0
						WR-SR	114.2	83.0

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1424	931	1229	29.50
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	867	791	829	19.90
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	118	55	91	2.18
	NER	132kV GELEPHU-SALAKATI	22	2	11	0.26
	NER	132kV MOTANGA-RANGIA	-13	0	0	-0.01
NEPAL	NR	NEPAL IMPORT (FROM UP)	-50	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	30	0.71
	ER	NEPAL IMPORT (FROM BIHAR)	147	117	130	3.12
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	724	420	614	14.73
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-970	-949	-962	-23.10
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1466	-1107	-1307	-31.37
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-51	0	-45	-1.08

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 13-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06
Bangladesh	23.81	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.87	0.13	0.00	0.00	0.00	0.00	0.00	0.00	24.00

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.53	0.00	1.81	0.00	0.00	0.08	0.00	0.00	55.42
Nepal	8.40	0.39	7.50	0.00	0.00	2.11	0.00	0.00	18.40
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	61.93	0.39	9.31	0.00	0.00	2.19	0.00	0.00	73.82

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.53	0.00	1.81	0.00	0.00	0.08	0.00	0.00	55.42
Nepal	8.34	0.39	7.50	0.00	0.00	2.11	0.00	0.00	18.34
Bangladesh	-23.81	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-23.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	38.06	0.26	9.31	0.00	0.00	2.19	0.00	0.00	49.82

