



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 27.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 26-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55952	60595	45954	22484	2677	187662
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1198	1473	1150	475	49	4345
Hydro Gen (MU)	104	36	79	24	14	257
Wind Gen (MU)	24	98	88	-	-	211
Solar Gen (MU)*	174.67	150.43	106.29	3.48	1.02	436
Energy Shortage (MU)	0.10	0.00	0.00	0.00	0.00	0.10
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64453	74284	58798	23147	2810	220642
Time Of Maximum Demand Met	09:23	10:23	12:14	10:44	18:10	09:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.037	0.00	0.45	6.05	6.50	79.35	14.14

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7435	0	140.8	62.7	-1.8	435	0.00
	Haryana	6830	0	133.0	92.2	-2.6	430	0.00
	Rajasthan	18252	0	326.2	114.5	-3.8	995	0.00
	Delhi	4447	0	76.1	67.5	0.2	438	0.00
	UP	19584	0	375.2	96.2	-1.6	631	0.00
	Uttarakhand	2382	0	38.7	30.6	0.1	177	0.00
	HP	1880	0	34.2	28.0	-0.9	73	0.00
	J&K(UT) & Ladakh(UT)	3216	0	65.5	61.9	-1.6	147	0.10
	Chandigarh	252	0	4.2	4.2	0.0	28	0.00
	Railways_NR ISTS	199	0	4.2	3.8	0.4	32	0.00
WR	Chhattisgarh	5619	0	112.1	64.5	0.2	315	0.00
	Gujarat	22177	0	409.6	198.7	-0.6	1068	0.00
	MP	19073	0	338.9	214.3	0.0	640	0.00
	Maharashtra	24456	0	539.4	145.4	-10.7	777	0.00
	Goa	656	0	7.9	10.6	-2.8	48	0.00
	DNHDDPDCL	1222	0	24.4	24.2	0.2	61	0.00
	AMNSIL	931	0	20.9	13.1	0.7	329	0.00
	BALCO	602	0	14.3	14.5	-0.2	5	0.00
	RIL JAMNAGAR	232	0	5.5	5.6	-0.1	0	0.00
	Andhra Pradesh	12002	0	222.8	68.6	-1.1	600	0.00
SR	Telangana	15002	0	266.1	126.3	-0.6	696	0.00
	Karnataka	15826	0	284.2	93.4	-0.4	687	0.00
	Kerala	4419	0	82.5	62.0	2.4	388	0.00
	Tamil Nadu	14234	0	286.7	156.4	-2.5	826	0.00
	Puducherry	364	0	7.7	7.2	-0.1	32	0.00
	Bihar	6031	0	107.3	91.7	1.8	419	0.00
ER	DVC	3149	0	68.0	-11.6	0.2	327	0.00
	Jharkhand	2033	0	38.1	28.8	-1.9	97	0.00
	Odisha	5167	0	105.3	28.5	-2.6	314	0.00
	West Bengal	7286	0	154.5	45.1	-2.4	383	0.00
	Sikkim	89	0	1.5	1.5	-0.1	8	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.1	3	0.00
NER	Arunachal Pradesh	186	0	3.3	3.1	0.1	20	0.00
	Assam	1528	0	26.8	22.7	0.1	95	0.00
	Manipur	258	0	3.9	4.0	-0.1	27	0.00
	Meghalaya	352	0	6.1	5.9	-0.2	47	0.00
	Mizoram	157	0	2.3	2.1	-0.2	17	0.00
	Nagaland	164	0	2.6	2.6	0.0	9	0.00
	Tripura	221	0	4.0	6.1	0.2	53	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-16.6	-9.2	-15.4	-17.5
Day Peak (MW)	-1057.8	-708.6	-1025.9	-1156.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	185.7	-199.8	133.6	-128.4	8.9	0.0
Actual(MU)	176.7	-201.3	129.9	-127.0	6.9	-14.7
O/D/U/D(MU)	-9.0	-1.4	-3.7	1.5	-2.0	-14.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5816	12705	4868	2994	469	26851	44
State Sector	10724	12380	5645	4993	205	33947	56
Total	16540	25085	10513	7986	674	60797	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	697	1443	663	664	12	3479	73
Lignite	28	23	49	0	0	100	2
Hydro	104	36	79	24	14	257	5
Nuclear	53	48	70	0	0	170	4
Gas, Naptha & Diesel	10	13	9	0	20	52	1
RES (Wind, Solar, Biomass & Others)	224	252	234	8	1	719	15
Total	1114	1815	1104	695	48	4776	100

Share of RES in total generation (%)	20.12	13.90	21.15	1.08	2.12	15.04
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.14	18.51	34.67	4.49	31.89	23.99

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.033

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220642	9:48	0
Non-Solar hr	196059	6:59	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 27-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	401	1370	0.0	12.9	-12.9
4	765 kV	SASARAM-FATEHPUR	1	199	648	0.0	5.0	-5.0
5	765 kV	GAYA-BALIA	1	0	846	0.0	12.9	-12.9
6	400 kV	PUSAULI-VARANASI	1	7	121	0.0	1.2	-1.2
7	400 kV	PUSAULI-ALLAHABAD	1	27	105	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	420	702	0.0	3.2	-3.2
9	400 kV	PATNA-BALIA	2	0	1096	0.0	14.5	-14.5
10	400 kV	NAUBATPUR-BALIA	2	0	411	0.0	4.5	-4.5
11	400 kV	BIHARSHARIFF-BALIA	2	286	338	0.0	0.7	-0.7
12	400 kV	MOTIHARI-GORAKHPUR	2	62	567	0.0	6.4	-6.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	204	476	0.0	3.5	-3.5
14	220 kV	SAHUPURI-KARAMNANA	1	13	57	0.0	2.1	-2.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.1	70.4	-70.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	263	1069	0.0	10.2	-10.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1183	104	13.8	0.0	13.8
3	765 kV	JHARSUGUDA-DURG	2	0	1178	0.0	20.2	-20.2
4	400 kV	JHARSUGUDA-RAIGARH	4	210	258	0.0	0.6	-0.6
5	400 kV	RANCHI-SIPAT	2	269	156	1.5	0.0	1.5
6	400 kV	JEYPORE-JAGDALPUR	2	430	328	3.8	0.0	3.8
7	220 kV	BUDHIPADAR-RAIGARH	1	8	106	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	21	200	0.0	1.8	-1.8
ER-WR						19.1	34.0	-15.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	630	0.0	12.2	-12.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1623	0.0	45.0	-45.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	1561	0.0	26.5	-26.5
4	400 kV	TALCHER-I/C	2	0	1173	0.0	12.4	-12.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	3	2	0.0	0.0	0.0
ER-SR						0.0	83.8	-83.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	204	120	0.8	0.7	0.2
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	366	0	4.2	0.0	4.2
3	220 kV	ALIPURDUAR-SALAKATI	2	53	23	0.5	0.0	0.5
ER-NER						5.5	0.7	4.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	571	0	14.0	0.0	14.0
NER-NR						14.0	0.0	14.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2947	0.0	53.4	-53.4
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1924	0.0	37.3	-37.3
4	765 kV	GWALIOR-AGRA	2	872	1789	2.1	17.2	-15.1
5	765 kV	GWALIOR-PHAGI	2	791	2014	2.3	20.9	-18.6
6	765 kV	JABALPUR-ORAI	2	355	1003	0.0	22.0	-22.0
7	765 kV	GWALIOR-ORAI	1	826	0	13.4	0.0	13.4
8	765 kV	SATNA-ORAI	1	0	1026	0.0	15.1	-15.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2465	0	23.7	0.0	23.7
10	765 kV	VINDHYACHAL VARANASI	2	0	1938	0.0	30.4	-30.4
11	400 kV	ZERDA-KANKROLI	1	405	0	5.3	0.0	5.3
12	400 kV	ZERDA BHINMAL	1	279	0	3.6	0.0	3.6
13	400 kV	VINDHYACHAL -RIHAND	1	492	0	0.0	9.6	-9.6
14	400 kV	RAPP-SHUJALPUR	2	981	188	7.9	0.3	7.6
15	400 kV	NEEMUCH-Chittorgarh	2	840	412	4.7	1.7	3.0
16	220 kV	BHANPURA-RANPUR	1	0	105	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	104	0	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	72	16	0.7	0.1	0.7
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						65.1	213.6	-148.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	974	0.0	12.9	-12.9
2	HVDC	RAIGARH-PUGALUR	2	0	4009	0.0	41.0	-41.0
3	765 kV	SOLAPUR-RAICHUR	2	1463	1076	7.2	4.0	3.2
4	765 kV	WARDHA-NIZAMABAD	2	119	2498	0.0	28.6	-28.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2714	0.0	33.5	-33.5
6	400 kV	KOLHAPUR-KUDGI	2	1396	0	24.4	0.0	24.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	123	2.1	0.0	2.1
WR-SR						33.7	120.1	-86.4

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-291	47	-176	-4.23	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-310	169	-151	-3.61	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-334	-193	-275	-6.60	
	NER	132kV GELEPHU-SALAKATI	-75	-55	-65	-1.55	
	NER	132kV MOTANGA-RANGIA	-48	-9	-25	-0.60	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-62	0	-30	-0.71	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-62	0	-38	-0.91	
	ER	NEPAL IMPORT (FROM BIHAR)	-120	-12	-119	-2.86	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-196	-90	-196	-4.76	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-720	-483	-526	-12.63	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1156	-280	-730	-17.53	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-146	0	-116	-2.79	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 27-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	18.12	0.00	0.00	0.44	0.00	0.00	18.89
Nepal	2.95	1.75	1.22	0.00	0.00	2.54	0.00	0.00	8.46
Bangladesh	13.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	13.28
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	16.23	2.08	19.34	0.00	0.00	2.98	0.00	0.00	40.63

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.05	-0.33	-18.12	0.00	0.00	-0.44	0.00	0.00	-18.84
Nepal	-2.95	-1.75	-1.22	0.00	0.00	-2.54	0.00	0.00	-8.46
Bangladesh	-13.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-13.28
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-16.18	-2.08	-19.34	0.00	0.00	-2.98	0.00	0.00	-40.58

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	152173	6251	14988	0	5778	2166	122206	3757	137185	155146	-1615
0:15	49.96	151883	6262	14603	0	5851	2184	122290	3764	137280	154954	-1690
0:30	49.94	151763	6262	14560	0	6173	2182	122077	3727	137203	154981	-1708
0:45	50.00	151034	6259	14232	0	6055	2183	121831	3740	136802	154300	-1728
1:00	49.98	150543	6279	14167	0	5937	2174	121536	3758	136376	153851	-1719
1:15	49.99	149612	6276	13752	0	5656	2180	121166	3799	135860	152829	-1726
1:30	50.00	149299	6283	13627	0	5487	2193	121129	3722	135672	152441	-1705
1:45	49.97	148819	6279	13569	0	5489	2187	120570	3756	135250	151850	-1710
2:00	50.01	147544	6295	13690	0	5346	2184	119607	3773	133854	150895	-1734
2:15	49.97	147674	6271	13534	0	5135	2213	119846	3771	134140	150770	-1713
2:30	50.05	147798	6275	13333	0	5365	2176	120162	3755	134465	151066	-1760
2:45	49.97	147993	6268	13087	0	5168	2173	120587	3778	134906	151061	-1743
3:00	50.02	148145	6266	12892	0	5218	2200	120813	3852	135253	151241	-1737
3:15	49.99	147790	6276	12647	0	4886	2203	121080	3817	135143	150909	-1755
3:30	49.99	148207	6264	12478	0	4888	2192	121890	3736	135729	151448	-1751
3:45	49.99	148878	6275	12505	0	4936	2192	122726	3698	136373	152332	-1766
4:00	50.00	149083	6302	12271	0	5149	2176	122612	3708	136812	152218	-1751
4:15	49.99	151364	6291	12246	0	5652	2184	124629	3707	139118	154709	-1726
4:30	49.99	153363	6269	11979	0	5809	2185	126360	3660	141384	156262	-1765
4:45	50.00	153627	6270	11597	0	5816	2170	127712	3649	142030	157214	-1784
5:00	50.06	155987	6284	11268	79	5852	2172	130195	3741	144640	159591	-1787
5:15	50.01	160626	6266	11323	84	6424	2179	134401	3657	149219	164334	-1795
5:30	50.03	165033	6263	11131	78	6740	2171	138563	3642	153824	168588	-1799
5:45	50.00	169350	6260	10824	83	7824	2214	142331	3718	158443	173254	-1780
6:00	50.04	172438	6258	10443	105	8963	2172	144892	3646	161890	176479	-1808
6:15	49.93	177896	6243	10332	120	10046	2186	149545	3675	167444	182147	-1834
6:30	49.97	184711	6215	10235	128	12370	2175	154185	3729	174348	189037	-1874
6:45	49.81	190315	6193	10255	189	14041	2190	157685	3687	179871	194240	-1374
7:00	49.98	196631	6171	10248	248	17856	2195	159380	3682	186135	199780	-912
7:15	49.89	200884	6140	9828	607	20426	2197	161218	3666	190449	204082	-848
7:30	49.97	204709	6145	9603	1455	21732	2206	162731	3735	193651	207607	-795
7:45	50.06	207428	6141	9547	3404	22195	2247	162965	3768	194477	210267	-819
8:00	50.08	208339	6145	9514	6365	21153	2209	162085	3684	192460	211155	-819
8:15	50.06	211396	6137	9273	10348	21169	2242	161102	3772	191775	214043	-860
8:30	50.07	213048	6150	8982	15205	19854	2185	159131	3787	188861	215294	-865
8:45	50.10	214475	6154	8517	20280	18698	2180	156917	3810	185678	216556	-850
9:00	50.03	216546	6152	7994	25721	16191	2183	156608	3758	182831	218607	-862
9:15	50.03	219545	6182	7534	32679	14342	2199	155117	3808	179332	221861	-1381
9:30	50.04	220281	6187	6936	36907	13670	2187	153492	3799	176438	223178	-1948
9:45	50.01	220395	6196	6480	41503	12292	2195	150960	3759	172412	223385	-1980
10:00	50.02	219605	6216	6078	45864	11110	2174	147182	3754	167663	222378	-1956
10:15	49.95	219096	6210	5680	48827	9950	2180	145474	3670	164589	221991	-2059
10:30	49.98	218436	6240	5274	53369	9373	2121	141148	3677	159793	221202	-2051
10:45	50.13	217804	6283	4836	58782	7804	2129	137046	3693	154186	220573	-2068
11:00	50.05	215430	6291	4603	59704	7593	2176	134362	3636	151123	218365	-2097
11:15	49.93	213563	6297	4629	60040	7391	2123	132371	3676	148894	216527	-2156
11:30	49.99	212489	6265	4551	60386	7289	2171	131040	3725	147552	215427	-2164
11:45	49.91	210292	6259	4275	61066	7177	2116	128470	3691	144951	213054	-2174
12:00	49.96	208117	6315	4151	61843	7180	2110	125879	3641	142123	211119	-2178
12:15	49.97	207197	6312	4080	63069	6792	2172	124220	3681	140048	210326	-2135
12:30	49.97	206504	6303	4012	62565	7072	2145	123810	3656	139927	209563	-2149
12:45	49.86	205062	6307	3775	61931	7267	2100	123199	3731	139356	208310	-2141
13:00	49.90	202539	6322	3702	62241	6999	2146	121262	3614	136596	206286	-2150
13:15	49.89	199089	6325	3518	61688	6706	2164	118831	3622	133883	202854	-2147
13:30	49.92	198245	6325	3472	59571	6634	2158	119861	3594	135202	201615	-2148
13:45	49.96	197249	6339	3543	56688	6584	2177	121526	3578	137018	200435	-2181
14:00	50.00	196355	6323	3417	55274	6644	2172	121895	3624	137664	199349	-2184
14:15	50.07	196023	6318	3426	54276	6048	2164	123085	3635	138321	198952	-2170
14:30	50.06	196547	6309	3504	53850	6052	2151	124146	3620	139193	199632	-2159
14:45	50.05	196849	6329	3505	53019	5977	2167	125493	3609	140325	200099	-2158
15:00	50.08	196878	6287	3556	50596	5875	2160	127155	3636	142726	199265	-2194
15:15	50.05	194961	6312	3568	48785	5662	2158	127848	3657	142608	197990	-2208
15:30	50.01	194711	6308	3621	44322	6434	2147	131255	3608	146768	197695	-2182
15:45	50.03	195235	6289	3872	42018	6735	2150	133386	3587	149345	198037	-2198
16:00	50.07	193687	6277	4027	38718	7077	2149	134834	3662	150942	196744	-2229
16:15	49.91	189241	6261	4357	34630	6046	2142	135248	3568	150254	192252	-2210
16:30	50.07	190171	6236	4505	29917	7922	2156	138533	3554	155749	192823	-2209
16:45	50.04	189221	6227	4861	25449	9790	2142	139836	3630	158911	191935	-2101
17:00	50.06	188640	6195	4737	20807	11242	2119	142244	3611	163096	190955	-2077
17:15	50.00	185581	6134	4823	15249	12978	2076	143216	3650	165509	188126	-2078
17:30	50.06	186223	6106	4791	10367	15768	2057	146068	3650	171065	188807	-1908
17:45	49.98	188160	6095	4909	6071	18160	1990	149348	3574	177180	190147	-1224
18:00	50.07	189271	6078	5040	2992	19057	1969	152284	3604	181239	191024	-914
18:15	50.02	188791	6074	5257	1218	18919	1962	153526	3591	182316	190547	-907
18:30	50.01	190779	6077	5360	622	19367	1965	155421	3602	184797	192414	-987
18:45	49.98	191715	6072	5773	259	19528	1966	156253	3625	185683	193476	-1049
19:00	50.07	190321	6075	5952	265	19009	1974	155068	3649	184104	191992	-877
19:15	50.02	187887	6088	6365	112	16542	1978	154337	3675	181410	189097	-806
19:30	50.04	185764	6079	6889	0	15446	1988	152848	3649	178875	186899	-825
19:45	49.99	183452	6090	7324	0	14876	1963	150840	3691	176128	184784	-859
20:00	50.00	180656	6110	7714	0	13789	1967	148854	3692	172942	182126	-953
20:15	49.93	177727	6109	7979	0	13320	1978	146531	3743	169748	179660	-1175
20:30	50.02	175943	6127	8447	0	12519	1983	145079	3789	167496	177944	-1112
20:45	49.97	173569	6127	8696	0	12007	1996	143248	3820	164873	175894	-1107
21:00	50.04	171013	6150	9130	0	11040	1979	141246	3750	161883	173295	-1285
21:15	50.02	168624	6165	9544	0	10638	1964	139240	3758	159080	171309	-1574
21:30	50.02	166983	6185	9816	0	10144	1981	137596	3700	157167	169422	-1622
21:45	50.04	164045	6192	10175	0	8667	1978	136157	3687	153870	166856	-1752
22:00	50.06	161216	6203	10359	0	8305	1980	133555	3708	150857	164110	-1811
22:15	50.01	160841	6191	10582	0	8403	1993	132858	3700	150259	163727	-1877
22:30	49.97	159166										