



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 17.08.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.08.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 16-अगस्त-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.08.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Aug-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	72189	59105	47444	27411	3554	209703
Peak Shortage (MW)	145	500	0	667	0	1312
Energy Met (MU)	1584	1363	1192	600	67	4806
Hydro Gen (MU)	384	115	173	88	33	794
Wind Gen (MU)	23	90	38	-	-	151
Solar Gen (MU)*	67.16	67.37	104.46	2.63	1.10	243
Energy Shortage (MU)	0.76	1.38	0.00	2.46	0.00	4.60
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72516	61248	56912	28152	3576	216685
Time Of Maximum Demand Met	21:49	19:26	11:38	22:46	19:37	11:38

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.024	0.00	0.00	3.33	3.33	76.26	20.40

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14928	0	307.7	194.2	-1.6	356	0.00
	Haryana	10676	0	222.7	160.0	-3.1	197	0.00
	Rajasthan	10481	0	223.5	54.3	-2.5	407	0.00
	Delhi	6517	0	129.7	116.2	-0.7	262	0.00
	UP	28158	0	556.0	251.4	0.4	549	0.00
	Uttarakhand	2324	0	49.1	22.8	0.0	234	0.59
	HP	1658	0	34.1	1.4	-0.1	113	0.00
	J&K(UT) & Ladakh(UT)	2562	0	50.7	25.7	0.7	356	0.17
	Chandigarh	346	0	6.7	6.5	0.3	71	0.00
WR	Railways_NR ISTS	210	0	4.2	3.6	0.6	68	0.00
	Chhattisgarh	4984	0	111.7	67.1	-1.1	285	0.00
	Gujarat	18731	0	409.8	167.4	-2.5	681	0.00
	MP	11284	0	238.5	113.8	-1.1	502	1.32
	Maharashtra	24313	0	532.3	188.4	-3.7	876	0.00
	Goa	664	15	14.4	11.0	3.0	101	0.06
	DNHDDPDCL	1196	0	25.3	25.8	-0.5	40	0.00
	AMNSIL	839	0	18.1	8.5	0.3	278	0.00
	BALCO	521	0	12.5	12.5	0.0	3	0.00
SR	Andhra Pradesh	11825	0	235.4	90.4	-1.3	721	0.00
	Telangana	14698	0	288.5	164.9	-1.8	878	0.00
	Karnataka	12203	0	229.8	57.8	0.0	503	0.00
	Kerala	4106	0	83.2	43.4	1.5	596	0.00
	Tamil Nadu	16358	0	345.8	181.5	-1.6	654	0.00
	Puducherry	437	0	9.3	8.8	-0.2	71	0.00
ER	Bihar	7540	203	153.8	145.1	-3.1	388	0.99
	DVC	3336	0	72.6	-45.0	0.1	409	0.00
	Jharkhand	2182	0	42.1	28.7	1.7	439	1.47
	Odisha	5560	0	112.9	39.8	-3.1	429	0.00
	West Bengal	10297	0	217.8	86.1	-1.0	337	0.00
	Sikkim	80	0	1.1	1.1	0.1	37	0.00
NER	Railways_ER ISTS	14	0	0.1	0.2	0.0	0	0.00
	Arunachal Pradesh	175	0	3.2	2.7	0.0	28	0.00
	Assam	2435	0	44.6	37.0	0.3	173	0.00
	Manipur	197	0	2.9	2.9	0.0	27	0.00
	Meghalaya	311	0	5.5	0.0	-0.2	89	0.00
	Mizoram	130	0	1.8	0.6	-0.1	37	0.00
	Nagaland	175	0	3.2	2.7	-0.1	12	0.00
	Tripura	307	0	6.0	4.9	0.3	77	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	41.7	16.1	-22.4	-18.1
Day Peak (MW)	1997.0	736.9	-993.0	-768.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	326.8	-340.5	117.7	-105.1	1.3	0.0
Actual(MU)	318.4	-337.9	122.4	-109.8	-0.6	-7.4
O/D/U/D(MU)	-8.4	2.6	4.8	-4.7	-1.8	-7.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3745	9752	4538	4706	622	23363	47
State Sector	4402	10970	8095	2522	141	26129	53
Total	8147	20722	12633	7228	763	49492	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	800	1433	652	682	17	3584	69
Lignite	24	9	54	0	0	87	2
Hydro	384	115	173	88	33	794	15
Nuclear	34	68	76	0	0	178	3
Gas, Naptha & Diesel	17	41	5	0	22	86	2
RES (Wind, Solar, Biomass & Others)	97	159	168	5	1	430	8
Total	1357	1826	1128	775	73	5159	100

Share of RES in total generation (%)	7.14	8.70	14.91	0.63	1.53	8.33
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.98	18.75	36.95	12.01	46.64	27.17

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.026
Based on State Max Demands	1.074

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	216685	11:38	0
Non-Solar hr	211705	19:34	165

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 17-Aug-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	702	0.0	16.6	-16.6
2	HVDC	PUSAULI B/B	-	0	107	0.0	5.3	-5.3
3	765 kV	GAYA-VARANASI	2	0	749	0.0	6.9	-6.9
4	765 kV	SASARAM-FATEHPUR	1	0	331	0.0	4.5	-4.5
5	765 kV	GAYA-BALIA	1	0	657	0.0	7.7	-7.7
6	400 kV	PUSAULI-VARANASI	1	0	126	0.0	2.4	-2.4
7	400 kV	PUSAULI -ALLAHABAD	1	19	34	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	545	0.0	9.6	-9.6
9	400 kV	PATNA-BALIA	2	0	478	0.0	7.8	-7.8
10	400 kV	NAUBATPUR-BALIA	2	0	149	0.0	1.7	-1.7
11	400 kV	BIHARSHARIFF-BALIA	2	90	107	0.0	0.1	-0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	269	0.0	4.5	-4.5
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	59	0.0	0.2	-0.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	67.2	-66.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	436	529	0.0	1.5	-1.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1513	0	20.7	0.0	20.7
3	765 kV	JHARSUGUDA-DURG	2	0	364	0.0	6.5	-6.5
4	400 kV	JHARSUGUDA-RAIGARH	4	0	455	0.0	5.7	-5.7
5	400 kV	RANCHI-SIPAT	2	288	91	3.1	0.0	3.1
6	220 kV	BUDHIPADAR-RAIGARH	1	37	64	0.0	0.5	-0.5
7	220 kV	BUDHIPADAR-KORBA	2	0	102	0.0	1.3	-1.3
ER-WR						23.8	15.5	8.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	523	0.0	12.4	-12.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1656	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2233	0.0	38.3	-38.3
4	400 kV	TALCHER-I/C	2	251	0	4.7	0.0	4.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	90.4	-90.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	51	250	0.1	2.5	-2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	104	324	0.0	2.2	-2.2
3	220 kV	ALIPURDUAR-SALAKATI	2	9	81	0.0	0.7	-0.7
ER-NER						0.1	5.5	-5.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.4	-8.4
NER-NR						0.0	8.4	-8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2511	0.0	59.6	-59.6
2	HVDC	VINDHYACHAL B/B	-	104	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1449	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	2046	0.0	33.2	-33.2
5	765 kV	GWALIOR-PHAGI	2	0	930	0.0	13.7	-13.7
6	765 kV	JABALPUR-ORAI	2	0	960	0.0	29.4	-29.4
7	765 kV	GWALIOR-ORAI	1	493	0	9.3	0.0	9.3
8	765 kV	SATNA-ORAI	1	0	903	0.0	18.7	-18.7
9	765 kV	BANASKANTHA-CHITORGARH	2	273	931	0.5	10.4	-9.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3210	0.0	53.7	-53.7
11	400 kV	ZERDA-KANKROLI	1	124	150	0.7	0.8	-0.1
12	400 kV	ZERDA -BHINMAL	1	87	104	0.5	0.6	-0.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	153	275	0.5	2.1	-1.6
15	400 kV	NEEMUCH-Chittorgarh	2	33	362	0.0	4.0	-4.0
16	220 kV	BHANPURA-RANPUR	1	0	104	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	0.9	-0.9
18	220 kV	MEHGAON-AURAIYA	1	86	25	0.7	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	56	35	0.3	0.2	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						14.8	265.2	-250.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	532	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1003	0.0	24.2	-24.2
3	765 kV	SOLAPUR-RAICHUR	2	835	912	5.9	3.0	2.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2646	0.0	38.6	-38.6
5	765 kV	WARORA-WARAMANGAL(NEW)	2	0	2378	0.0	33.3	-33.3
6	400 kV	KOLHAPUR-KUDGI	2	1441	0	23.9	0.0	23.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.3	0.0	2.3
WR-SR						32.1	111.0	-78.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	764	687	710	17.03	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	963	858	884	21.23	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	90	13	54	1.30	
	NER	132kV GELEPHU-SALAKATI	49	28	35	0.83	
	NER	132kV MOTANGA-RANGIA	71	27	53	1.28	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	55	1.33	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	669	571	617	14.80	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-890	-717	-855	-20.51	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-734	-755	-18.13	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-103	0	-78	-1.88	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.16
Bangladesh	21.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.27
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.43

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.22	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.55
Nepal	2.53	0.00	13.68	0.00	0.00	0.00	0.00	0.00	16.21
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	41.75	0.00	16.01	0.00	0.00	0.00	0.00	0.00	57.76

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.22	0.00	2.33	0.00	0.00	0.00	0.00	0.00	41.55
Nepal	2.37	0.00	13.68	0.00	0.00	0.00	0.00	0.00	16.05
Bangladesh	-21.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.27
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	20.32	0.00	16.01	0.00	0.00	0.00	0.00	0.00	36.33