



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 1-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53388	57507	46755	23899	2784	184333
Peak Shortage (MW)	0	0	0	286	0	286
Energy Met (MU)	1140	1254	1058	511	55	4017
Hydro Gen (MU)	157	72	187	80	29	525
Wind Gen (MU)	4	94	52	-	-	150
Solar Gen (MU)*	165.53	108.22	148.31	2.12	0.30	424
Energy Shortage (MU)	0.07	0.00	0.00	1.07	0.00	1.14
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	55332	59727	48787	24513	2985	189169
Time Of Maximum Demand Met	18:09	18:30	15:53	18:01	17:29	18:08

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.067	0.73	1.84	8.33	10.90	70.41	18.69

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7611	0	153.8	87.4	0.1	530	0.00
	Haryana	7690	0	160.4	133.1	0.3	387	0.00
	Rajasthan	13344	0	268.3	75.2	0.5	493	0.00
	Delhi	4093	0	82.9	79.9	0.8	274	0.00
	UP	17603	0	339.0	108.5	-1.4	515	0.00
	Uttarakhand	2119	0	40.3	27.9	0.3	158	0.07
	HP	1895	0	33.0	18.9	-2.8	0	0.00
	J&K(UT) & Ladakh(UT)	2804	0	54.5	47.8	-0.7	195	0.00
	Chandigarh	209	0	3.8	3.8	0.0	15	0.00
	Railways_NR ISTS	209	0	4.5	3.7	0.8	90	0.00
WR	Chhattisgarh	4505	0	95.1	51.2	-3.0	323	0.00
	Gujarat	17351	0	359.2	197.8	-0.4	1954	0.00
	MP	11199	0	215.4	137.3	0.0	317	0.00
	Maharashtra	24588	0	503.2	171.4	2.1	580	0.00
	Goa	704	0	14.6	11.9	2.3	64	0.00
	DNHDDPDCL	1294	0	29.8	29.6	0.2	81	0.00
	AMNSIL	820	0	18.2	11.1	0.5	280	0.00
	BALCO	535	0	12.7	12.8	-0.1	17	0.00
	RIL JAMNAGAR	251	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	9270	0	198.2	76.2	0.8	687	0.00
SR	Telangana	8764	0	178.8	71.2	-0.7	463	0.00
	Karnataka	11104	0	223.0	57.6	-0.9	474	0.00
	Kerala	4314	0	83.9	48.5	-1.2	411	0.00
	Tamil Nadu	17141	0	363.8	198.0	-2.4	941	0.00
	Puducherry	447	0	9.8	9.2	0.0	56	0.00
	Bihar	5049	0	95.5	82.7	1.3	742	0.00
ER	DVC	3038	0	64.9	-27.2	-0.5	313	0.00
	Jharkhand	1900	208	37.5	25.1	0.3	346	1.07
	Odisha	5704	0	117.4	33.8	0.3	667	0.00
	West Bengal	9111	0	194.6	58.5	-2.0	333	0.00
	Sikkim	72	0	1.1	1.3	-0.2	15	0.00
	Railways_ER ISTS	20	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	161	0	2.9	2.9	-0.5	32	0.00
	Assam	1714	0	32.2	25.2	0.3	207	0.00
	Manipur	237	0	3.2	3.3	0.0	35	0.00
	Meghalaya	319	0	5.4	3.8	-0.2	53	0.00
	Mizoram	140	0	2.4	1.2	-0.1	10	0.00
	Nagaland	163	0	2.3	2.3	-0.3	21	0.00
	Tripura	315	0	6.2	6.0	0.2	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	32.4	20.9	-24.2	-16.3
Day Peak (MW)	2069.1	1158.7	-1043.2	-766.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	219.0	-238.9	183.5	-162.2	-1.4	0.0
Actual(MU)	222.2	-237.9	176.6	-167.8	-4.6	-11.5
O/D/U/D(MU)	3.2	0.9	-6.9	-5.6	-3.2	-11.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	8002	12490	12348	4460	231	37531	44
State Sector	12734	20431	13308	1537	205	48215	56
Total	20736	32921	25656	5997	436	85745	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	596	1221	455	659	13	2944	67
Lignite	30	8	46	0	0	85	2
Hydro	157	72	187	80	29	525	12
Nuclear	36	65	41	0	0	142	3
Gas, Naptha & Diesel	7	27	5	0	22	61	1
RES (Wind, Solar, Biomass & Others)	179	203	224	4	0	611	14
Total	1005	1597	959	743	64	4368	100

Share of RES in total generation (%)	17.83	12.72	23.38	0.59	0.47	13.99
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.08	21.26	47.22	11.30	45.58	29.26

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.045

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	179599	9:51	0
Non-Solar hr	189169	18:08	208

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 02-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.2	-7.2
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	814	1131	0.0	6.9	-6.9
4	765 kV	SASARAM-FATEHPUR	1	236	694	0.0	7.4	-7.4
5	765 kV	GAYA-BALIA	1	0	548	0.0	8.9	-8.9
6	400 kV	PUSAULI-VARANASI	1	0	105	0.0	1.1	-1.1
7	400 kV	PUSAULI-ALLAHABAD	1	11	89	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	219	891	0.0	12.2	-12.2
9	400 kV	PATNA-BALIA	2	0	1024	0.0	16.0	-16.0
10	400 kV	NAUBATPUR-BALIA	2	1	469	0.0	5.0	-5.0
11	400 kV	BIHARSHARIFF-BALIA	2	174	524	0.0	6.0	-6.0
12	400 kV	MOTIHARI-GORAKHPUR	2	136	541	0.0	6.9	-6.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	291	459	0.0	2.4	-2.4
14	220 kV	SAHUPURI-KARMANASA	1	25	48	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	84.9	-84.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	737	859	0.0	5.4	-5.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1499	542	9.8	0.0	9.8
3	765 kV	JHARSUGUDA-DURG	2	0	704	0.0	11.4	-11.4
4	400 kV	JHARSUGUDA-RAIGARH	4	466	120	2.9	0.0	2.9
5	400 kV	RANCHI-SIPAT	2	346	172	2.3	0.0	2.3
6	400 kV	JEYPORE-JACDALPUR	2	577	289	2.8	0.0	2.8
7	220 kV	BUDHIPADAR-RAIGARH	1	69	97	0.0	0.8	-0.8
8	220 kV	BUDHIPADAR-KORBA	2	148	74	0.4	0.0	0.4
ER-WR						18.1	17.6	0.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	614	0.0	9.6	-9.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1621	0.0	37.3	-37.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	3231	0.0	53.4	-53.4
4	400 kV	TALCHER/JC	2	328	1117	0.0	13.6	-13.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	28	0	0.5	0.0	0.5
ER-SR						0.5	100.4	-99.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	147	368	0.0	2.1	-2.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	704	0.0	6.8	-6.8
3	220 kV	ALIPURDUAR-SALAKATI	2	14	129	0.0	1.1	-1.1
ER-NER						0.0	10.0	-10.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	604	0.0	14.5	-14.5
NER-NR						0.0	14.5	-14.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3028	0.0	58.4	-58.4
2	HVDC	VINDHYACHAL B/B	-	200	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	23.0	-23.0
4	765 kV	GWALIOR-AGRA	2	107	1327	0.0	19.6	-19.6
5	765 kV	GWALIOR-PHAGI	2	690	1606	2.4	19.8	-17.3
6	765 kV	JABALPUR-ORAI	2	5	783	0.0	21.6	-21.6
7	765 kV	GWALIOR-ORAI	1	748	0	10.9	0.0	10.9
8	765 kV	SATNA-ORAI	1	0	894	0.0	15.1	-15.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2212	505	25.3	1.4	24.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2094	0.0	26.1	-26.1
11	400 kV	ZERDA-KANKROLI	1	400	0	5.7	0.0	5.7
12	400 kV	ZERDA -BHINMAL	1	276	0	3.9	0.0	3.9
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	670	185	3.9	1.0	2.9
15	400 kV	NEEMUCH-Chittorgarh	2	636	256	3.3	2.0	1.3
16	220 kV	BHANPURA-RANPUR	1	0	95	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	104	7	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	81	16	0.4	0.1	0.3
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						61.2	191.0	-129.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	302	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	4008	0.0	60.5	-60.5
3	765 kV	SOLAPUR-RAICHUR	2	1239	1647	3.3	8.6	-5.3
4	765 kV	WARDHA-NIZAMABAD	2	0	2559	0.0	34.0	-34.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2740	0.0	38.0	-38.0
6	400 kV	KOLHAPUR-KUDGI	2	1357	0	21.0	0.0	21.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	102	2.1	0.0	2.1
WR-SR						33.5	141.0	-107.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1269	644	867	20.82
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	859	-223	512	12.28
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-112	12	-31	-0.74
	NER	132kV GELEPHU-SALAKATI	-29	-7	-19	-0.46
	NER	132kV MOTANGA-RANGIA	36	5	20	0.48
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	61	1.47
	ER	NEPAL IMPORT (FROM BIHAR)	161	0	2	0.05
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	1268	719	808	19.38
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-958	-934	-940	-22.55
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-449	-679	-16.30
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-80	0	-70	-1.67

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 02-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.33
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.18	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.18	0.46	0.00	0.00	0.00	0.00	0.00	0.00	23.64

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	20.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.47
Nepal	0.80	0.12	11.79	0.00	0.00	4.85	0.00	0.00	17.56
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	21.27	0.12	11.79	0.00	0.00	4.85	0.00	0.00	38.03

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	20.47	-0.33	0.00	0.00	0.00	0.00	0.00	0.00	20.14
Nepal	0.80	0.12	11.79	0.00	0.00	4.85	0.00	0.00	17.56
Bangladesh	-23.18	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-23.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-1.91	-0.34	11.79	0.00	0.00	4.85	0.00	0.00	14.39

