



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 01-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 02-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57033	58374	40889	21245	2482	180023
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1209	1378	1106	438	47	4178
Hydro Gen (MU)	97	27	73	13	12	222
Wind Gen (MU)	13	62	114	-	-	190
Solar Gen (MU)*	145.24	95.59	126.36	2.91	0.94	371
Energy Shortage (MU)	0.10	0.00	0.00	0.06	0.00	0.16
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66290	68262	57353	22228	2577	214654
Time Of Maximum Demand Met	10:23	10:26	09:37	09:21	17:45	10:11

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.040	0.00	0.07	3.85	3.92	75.28	20.80

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8705	0	155.2	74.3	-0.7	347	0.00
	Haryana	7151	0	139.8	99.5	-2.5	203	0.00
	Rajasthan	16847	0	305.1	114.7	-2.4	430	0.00
	Delhi	5519	0	87.4	85.5	-0.4	404	0.00
	UP	20152	0	361.2	102.5	-1.3	658	0.00
	Uttarakhand	2451	0	44.6	37.0	-0.3	170	0.00
	HP	2094	0	37.5	31.4	-1.1	69	0.00
	J&K(UT) & Ladakh(UT)	3182	0	68.4	66.1	-2.1	1038	0.10
	Chandigarh	312	0	5.2	5.2	0.0	108	0.00
WR	Railways_NR ISTS	214	0	4.1	3.8	0.3	46	0.00
	Chhattisgarh	5082	0	102.0	57.8	-1.3	176	0.00
	Gujarat	20607	0	389.6	175.7	-2.2	1134	0.00
	MP	14113	0	258.5	156.8	-2.6	469	0.00
	Maharashtra	26880	0	558.8	191.3	1.4	555	0.00
	Goa	684	0	14.0	13.7	-0.2	41	0.00
	DNHDDPDCL	1186	0	25.9	27.0	-1.1	19	0.00
	AMNSIL	740	0	16.9	7.4	0.4	271	0.00
	BALCO	528	0	12.6	12.7	-0.1	3	0.00
SR	RIL JAMNAGAR	0	0	0.0	0.0	0.0	0	0.00
	Andhra Pradesh	10786	0	196.4	54.3	-1.4	550	0.00
	Telangana	14334	0	263.8	170.2	-1.4	659	0.00
	Karnataka	15272	0	259.8	84.0	-0.9	648	0.00
	Kerala	4223	0	83.5	71.0	1.2	511	0.00
	Tamil Nadu	14019	0	294.7	154.2	-3.9	810	0.00
	Puducherry	364	0	8.3	8.2	-0.5	20	0.00
ER	Bihar	5620	101	102.6	92.4	-1.6	402	0.06
	DVC	3191	0	68.2	-38.1	0.4	370	0.00
	Jharkhand	2031	0	37.5	28.1	-0.3	260	0.00
	Odisha	4675	0	90.5	27.4	-3.5	356	0.00
	West Bengal	7006	0	137.7	6.0	-1.4	263	0.00
	Sikkim	97	0	1.4	1.8	-0.4	38	0.00
	Railways_ER ISTS	14	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	171	0	2.5	3.0	-0.7	41	0.00
	Assam	1391	0	25.6	19.5	-0.1	113	0.00
	Manipur	240	0	3.8	3.9	-0.1	25	0.00
	Meghalaya	321	0	6.2	5.6	-0.2	84	0.00
	Mizoram	125	0	1.9	1.7	-0.3	22	0.00
	Nagaland	145	0	2.5	2.5	0.0	17	0.00
	Tripura	246	0	4.1	3.4	-0.1	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.7	-6.1	-20.7	-13.7
Day Peak (MW)	-473.5	-475.7	-989.0	-769.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	271.7	-271.0	144.5	-151.6	6.4	0.0
Actual(MU)	255.9	-262.8	139.6	-145.8	4.5	-8.6
O/D/U/D(MU)	-15.8	8.2	-4.9	5.8	-1.9	-8.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5109	7801	4878	4663	518	22968	42
State Sector	8103	11943	9039	2249	197	31530	58
Total	13212	19743	13917	6911	714	54498	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	704	1488	579	651	9	3430	75
Lignite	24	18	47	0	0	89	2
Hydro	97	27	73	13	12	222	5
Nuclear	28	54	70	0	0	152	3
Gas, Naptha & Diesel	3	11	5	0	25	44	1
RES (Wind, Solar, Biomass & Others)	185	162	266	7	1	621	14
Total	1041	1760	1040	670	47	4558	100

Share of RES in total generation (%)	17.73	9.21	25.64	1.00	2.00	13.62
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.78	13.80	39.38	2.95	28.22	21.83

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.009
Based on State Max Demands	1.028

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	214654	10:11	0
Non-Solar hr	190660	18:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 02-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	5.7	-5.7
3	765 kV	GAYA-VARANASI	2	79	985	0.0	11.0	-11.0
4	765 kV	SASARAM-FATEHPUR	1	5	551	0.0	6.7	-6.7
5	765 kV	GAYA-BALIA	1	0	777	0.0	13.3	-13.3
6	400 kV	PUSAULI-VARANASI	1	0	184	0.0	3.2	-3.2
7	400 kV	PUSAULI -ALLAHABAD	1	21	131	0.0	2.3	-2.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	813	0.0	9.2	-9.2
9	400 kV	PATNA-BALIA	2	0	956	0.0	14.2	-14.2
10	400 kV	NAUBATPUR-BALIA	2	0	314	0.0	4.4	-4.4
11	400 kV	BIHARSHARIFF-BALIA	2	7	447	0.0	3.7	-3.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	579	0.0	8.2	-8.2
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.7	-2.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	84.6	-84.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	385	620	0.0	2.6	-2.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	958	473	2.9	0.0	2.9
3	765 kV	JHARSUGUDA-DURG	2	0	617	0.0	11.5	-11.5
4	400 kV	JHARSUGUDA-RAIGARH	4	0	695	0.0	10.8	-10.8
5	400 kV	RANCHI-SIPAT	2	199	238	1.3	0.0	1.3
6	220 kV	BUDHIPADAR-RAIGARH	1	0	120	0.0	1.9	-1.9
7	220 kV	BUDHIPADAR-KORBA	2	27	134	0.0	1.1	-1.1
ER-WR						4.1	27.9	-23.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1992	0.0	31.9	-31.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2917	0.0	54.2	-54.2
4	400 kV	TALCHER-I/C	2	634	449	7.6	0.0	7.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	91.2	-91.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	414	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	693	0	6.0	0.0	6.0
3	220 kV	ALIPURDUAR-SALAKATI	2	122	0	1.4	0.0	1.4
ER-NER						10.9	0.0	10.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	658	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3019	0.0	49.1	-49.1
2	HVDC	VINDHYACHAL B/B	-	0	56	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1454	0.0	36.2	-36.2
4	765 kV	GWALIOR-AGRA	2	0	2170	0.0	33.3	-33.3
5	765 kV	GWALIOR-PHAGI	2	61	1893	0.0	24.7	-24.7
6	765 kV	JABALPUR-ORAI	2	0	1049	0.0	32.5	-32.5
7	765 kV	GWALIOR-ORAI	1	892	0	14.4	0.0	14.4
8	765 kV	SATNA-ORAI	1	0	1071	0.0	20.1	-20.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1094	149	6.8	0.1	6.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2724	0.0	42.9	-42.9
11	400 kV	ZERDA-KANKROLI	1	255	0	2.1	0.0	2.1
12	400 kV	ZERDA -BHINMAL	1	178	0	1.5	0.0	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	337	327	1.7	1.9	-0.2
15	400 kV	NEEMUCH-Chittorgarh	2	317	301	1.9	1.2	0.8
16	220 kV	BHANPURA-RANPUR	1	0	144	0.0	2.4	-2.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	95	4	1.0	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	65	18	0.4	0.0	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						51.5	247.0	-195.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	23.0	-23.0
2	HVDC	RAIGARH-PUGALUR	2	0	2002	0.0	29.1	-29.1
3	765 kV	SOLAPUR-RAICHUR	2	1207	1015	7.5	6.6	0.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2265	0.0	34.2	-34.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2277	0.0	34.6	-34.6
6	400 kV	KOLHAPUR-KUDGI	2	1644	0	26.9	0.0	26.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	123	2.3	0.0	2.3
WR-SR						36.6	127.4	-90.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	322	8	113	2.70	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-219	145	-47	-1.13	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-253	-132	-198	-4.76	
	NER	132kV GELEPHU-SALAKATI	-33	-11	-18	-0.43	
	NER	132kV MOTANGA-RANGIA	-13	0	-4	-0.10	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-47	-1.13	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-31	-0.74	
	ER	NEPAL IMPORT (FROM BIHAR)	-189	0	-73	-1.75	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-288	23	-105	-2.51	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-932	-642	-814	-19.54	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-769	-409	-570	-13.68	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-57	0	-49	-1.18	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	6.45	0.00	0.00	0.00	0.00	0.00	6.45	
Nepal	1.63	0.00	2.07	0.00	0.00	0.00	0.49	0.00	0.00	4.19
Bangladesh	20.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.78	0.00	8.52	0.00	0.00	0.00	0.49	0.00	0.00	30.79

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.39
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.39

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.39	0.00	-6.45	0.00	0.00	0.00	0.00	0.00	-4.06	
Nepal	-1.63	0.00	-2.07	0.00	0.00	0.00	-0.49	0.00	0.00	-4.19
Bangladesh	-20.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.39	0.00	-8.52	0.00	0.00	0.00	-0.49	0.00	0.00	-28.40

Date of Reporting: 02-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	49.99	147488	5918	10206	72	7197	1766	123916	3068	137210	152143	-1467
0:15	49.94	146686	5916	10115	75	6342	1766	124132	3120	136496	151466	-1428
0:30	49.99	146198	5918	10136	74	6333	1729	123870	3116	135988	151176	-1414
0:45	49.94	145519	5912	10119	73	6335	1731	122979	3113	135327	150262	-1345
1:00	49.94	144696	5905	9968	71	6528	1733	122084	3049	134657	149338	-1214
1:15	49.94	142983	5906	9912	70	6272	1755	120595	3069	133001	147579	-1203
1:30	49.99	141960	5904	9933	72	6172	1745	119604	3094	131955	146524	-1197
1:45	49.99	141408	5915	10048	71	5858	1745	119119	3132	131289	145888	-1116
2:00	50.04	140248	5924	10167	67	5672	1742	117945	3107	130014	144624	-1106
2:15	50.04	139553	5915	10057	67	5629	1907	117433	3095	129429	144103	-1010
2:30	49.99	138892	5923	9780	66	5380	1726	117214	3158	129046	143247	-1067
2:45	49.99	138327	5917	9557	66	5289	1744	117046	3114	128704	142733	-968
3:00	50.04	137744	5929	9495	66	5264	1757	116381	3122	128183	142014	-980
3:15	49.94	138126	5891	9566	71	5475	1751	116484	3128	128489	142366	-986
3:30	49.94	138032	5912	9549	72	5539	1754	116731	3146	128411	142703	-999
3:45	49.99	138264	5917	9320	70	5519	1740	117156	3141	128874	142863	-996
4:00	49.99	138613	5926	9212	71	5701	1745	117478	3114	129330	143247	-1031
4:15	49.94	140713	5922	8996	71	5978	1747	119372	3153	131646	145239	-1025
4:30	49.99	142160	5908	8709	71	6217	1757	120720	3080	133380	146462	-1027
4:45	49.99	144549	5904	8464	72	6601	1762	122688	3075	136013	148566	-1027
5:00	49.99	147141	5918	8266	72	7063	1730	124921	3085	138803	151055	-1025
5:15	49.89	150793	5909	7968	73	7491	1749	128358	3065	142752	154613	-1050
5:30	49.99	154085	5914	7685	75	7764	1751	132117	3086	146325	158392	-1095
5:45	50.04	158403	5908	7494	78	8757	1763	135396	3240	150831	162636	-1159
6:00	50.04	161563	5919	7467	115	9586	1738	137750	3166	153981	165741	-1197
6:15	50.04	165122	5917	7340	754	10297	1736	140705	3179	157028	169928	-1242
6:30	50.04	170202	5910	7292	611	11406	1742	144827	3137	162299	174925	-1274
6:45	50.04	175273	5899	7241	954	12798	1759	148255	3138	167078	180044	-1232
7:00	49.94	179971	5913	7076	783	14393	1744	151103	3150	172112	184162	-1250
7:15	49.94	184348	5924	6947	1391	15599	1750	153648	3144	176010	188403	-1192
7:30	49.99	188179	5917	6836	2795	16361	1741	155703	3145	178548	192498	-1177
7:45	50.04	191682	5909	6727	4454	16731	1754	156951	3164	180501	195690	-1197
8:00	50.04	195020	5914	6513	7373	17046	1769	157068	3196	181134	198879	-1146
8:15	50.04	197966	5912	6440	10457	16275	1745	157035	3204	181069	201068	-1074
8:30	50.04	200994	5915	6306	13867	15713	1740	157347	3247	180821	204135	-977
8:45	50.09	203349	5922	6007	18363	14211	1745	156593	3238	178979	206079	-850
9:00	50.10	205783	5918	5860	23125	12820	1736	156032	3308	176798	208799	-879
9:15	50.05	209431	5907	5793	26990	12630	1753	156006	3354	176648	212433	-1021
9:30	50.05	213303	5913	6077	31609	12477	1738	155114	3317	175617	216245	-1034
9:45	50.05	213972	5900	6084	35002	10748	1730	154205	3353	172886	217022	-1048
10:00	50.05	213800	5918	6053	38113	9107	1745	152539	3353	169634	216828	-1083
10:15	49.95	214542	5909	6290	40875	8239	1736	151298	3366	167377	217713	-1232
10:30	50.05	213935	5904	6584	43314	7290	1717	149330	3325	164037	217464	-1353
10:45	50.00	212863	5908	6825	45826	6557	1718	146750	3310	160212	216894	-1353
11:00	50.00	211883	5907	6995	47893	5902	1722	143968	3302	156995	215689	-1356
11:15	49.95	210369	5901	7099	49967	5526	1722	141046	3297	153303	214558	-1311
11:30	50.00	209849	5901	7139	52304	5625	1708	138686	3248	150406	214611	-1590
11:45	50.00	208646	5899	6989	53378	5852	1710	136152	3246	148279	213226	-1802
12:00	50.00	206147	5696	6906	53689	6255	1721	132910	3247	145552	210424	-1802
12:15	50.00	204103	5677	6696	54068	5833	1711	131141	3216	143339	208342	-1791
12:30	50.00	203073	5698	6346	54844	5915	1700	129541	3287	141883	207331	-1859
12:45	50.00	201586	5695	6086	55515	6123	1713	127799	3235	139985	206166	-1830
13:00	50.10	198435	5689	6086	54869	6013	1690	125621	3220	137480	203188	-1832
13:15	50.05	194067	5683	5984	54209	5762	1715	122105	3315	133874	198773	-1736
13:30	50.10	191762	5687	5790	53846	5502	1713	120386	3255	132126	196179	-1702
13:45	50.10	191270	5685	5681	53589	5423	1692	120281	3229	132000	195580	-1711
14:00	50.20	190196	5688	5574	52293	5491	1840	120291	3215	132329	194392	-1719
14:15	50.10	188864	5702	5517	50920	5562	1701	120136	3201	132427	192739	-1606
14:30	50.00	188170	5683	5382	48835	5572	1697	121334	3216	133953	191719	-1552
14:45	50.00	187950	5687	5296	46621	6026	1715	123424	3176	136033	191945	-1653
15:00	50.00	187564	5684	5126	44421	5887	1697	125306	3180	138017	191301	-1687
15:15	50.00	185274	5690	4891	41669	6011	1755	125810	3160	138714	188986	-1566
15:30	49.95	184107	5688	4922	38363	6247	1721	127536	3135	140822	187612	-1563
15:45	50.00	184301	5676	4883	34733	7396	1726	130205	3186	144685	187805	-1457
16:00	50.05	184051	5674	5033	31383	7823	1722	133047	3170	147635	187852	-1443
16:15	50.00	182329	5685	4962	27243	7524	1713	135841	3157	150124	186125	-1276
16:30	50.05	184158	5659	4978	22286	8256	1746	141325	3128	156894	187378	-1027
16:45	50.05	184321	5771	5023	17016	9298	1737	145398	3174	162282	187417	-995
17:00	50.10	183724	5788	4861	12435	10796	1740	148127	3094	166428	186841	-996
17:15	50.05	182079	5785	4826	8144	12367	1755	149061	3083	169109	185021	-761
17:30	50.05	182650	5805	4786	4829	14334	1768	150986	3100	173035	185608	-613
17:45	50.05	185410	5790	4836	2471	17108	1748	152862	3127	178103	187942	-766
18:00	50.10	186140	5785	5100	1271	18434	1774	153208	3134	179769	188706	-899
18:15	50.00	188549	5797	5455	894	18190	1760	155881	3146	182200	191123	-676
18:30	50.05	190607	5760	5970	1202	18627	1768	156951	3175	183435	193453	-683
18:45	50.05	189426	5770	6615	796	18322	1771	155644	3125	182015	192043	-690
19:00	50.05	187142	5785	7185	808	16295	1762	154806	3122	179149	189763	-700
19:15	50.00	184745	5783	7672	802	14966	1744	153455	3158	176271	187580	-700
19:30	49.89	182076	5806	8012	747	14420	1754	150923	3153	173317	184815	-665
19:45	49.89	178919	5783	8362	746	13690	1756	148177	3126	169811	181640	-695
20:00	49.94	175509	5788	8568	1113	12564	1744	145836	3111	165828	178724	-739
20:15	49.89	172784	5792	8804	447	11847	1755	143861	3116	163533	175622	-936
20:30	49.94	170633	5789	8943	458	11240	1747	142024	3117	161232	173318	-1041
20:45	50.03	168175	5806	9182	422	10923	1737	140118	3100	158571	171288	-1036
21:00	50.03	165335	5818	9517	432	10318	1738	137570	3139	155386	168532	-1077
21:15	50.03	163100	5821	9787	433	9986	1920	135558	3166	152880	166671	-1160
21:30	50.03	160514	5813	9936	180	9617	1735	133693	3115	150398	164089	-1361
21:45	50.03	157443	5806	9949	124	8640	1746	132067	3089	147370	161421	-1520
22:00	50.08	154383	5831	9998	122	8268	1723	129264	3150	144263	158356	-1518
22:15	50.08	154124	5818	9862	124	8576	1718	128471	3143	144138	157712	-1556
22:30	49.98	152295	5834	9813	124	8544	1734	126866				