



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57948	68418	48027	23043	2670	200106
Peak Shortage (MW)	0	111	0	0	37	148
Energy Met (MU)	1252	1637	1292	473	49	4702
Hydro Gen (MU)	95	66	84	24	10	280
Wind Gen (MU)	5	31	63	-	-	99
Solar Gen (MU)*	163.19	122.20	138.46	3.51	0.92	428
Energy Shortage (MU)	0.00	0.84	0.00	0.00	0.15	0.99
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67561	79999	64492	23703	2758	234995
Time Of Maximum Demand Met	10:41	10:37	09:54	18:15	18:13	10:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.046	0.00	1.70	6.42	8.12	74.04	17.83

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9081	0	163.9	69.0	-0.6	424	0.00
	Haryana	9146	0	167.7	102.8	-1.3	340	0.00
	Rajasthan	18294	0	343.1	118.1	-3.0	362	0.00
	Delhi	4179	0	73.9	66.3	-1.8	300	0.00
	UP	19383	0	351.1	90.1	-1.3	478	0.00
	Uttarakhand	2415	0	43.1	32.9	0.5	100	0.00
	HP	2051	0	36.8	30.8	-0.4	143	0.00
	J&K(UT) & Ladakh(UT)	2984	0	64.2	61.2	-0.8	862	0.00
	Chandigarh	249	0	3.8	3.9	-0.1	18	0.00
WR	Railways_NR ISTS	212	0	4.7	3.9	0.8	56	0.00
	Chhattisgarh	5948	0	130.9	67.5	0.2	558	0.00
	Gujarat	23633	0	442.3	211.2	-3.1	587	0.00
	MP	18112	0	349.7	228.8	-0.3	667	0.84
	Maharashtra	29789	0	632.9	231.1	-0.6	715	0.00
	Goa	742	0	14.9	14.0	0.7	67	0.00
	DNHDDPDCL	1333	0	30.2	30.2	0.0	39	0.00
	AMNSIL	839	0	18.5	8.3	0.8	250	0.00
	BALCO	534	0	12.7	12.7	0.0	10	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12450	0	234.5	61.2	0.2	468	0.00
	Telangana	15998	0	302.1	162.0	-0.2	643	0.00
	Karnataka	17466	0	313.2	108.9	-0.5	773	0.00
	Kerala	4476	0	86.2	67.3	0.6	404	0.00
	Tamil Nadu	17344	0	347.2	197.8	-1.2	682	0.00
	Puducherry	379	0	8.5	8.3	-0.3	20	0.00
ER	Bihar	5174	0	99.8	85.1	2.5	280	0.00
	DVC	3355	0	68.3	-46.9	-0.4	454	0.00
	Jharkhand	2035	0	38.5	25.9	-0.3	190	0.00
	Odisha	5286	0	102.3	32.3	-1.0	394	0.00
	West Bengal	7840	0	161.4	29.7	-1.8	154	0.00
	Sikkim	139	0	2.3	2.0	0.3	50	0.00
	Railways_ER ISTS	18	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	190	0	3.5	3.4	0.0	23	0.00
	Assam	1567	0	28.2	21.9	0.3	108	0.00
	Manipur	192	0	3.2	3.2	0.0	34	0.15
	Meghalaya	331	0	5.6	4.4	0.0	58	0.00
	Mizoram	148	0	2.2	1.9	-0.2	13	0.00
	Nagaland	166	0	2.5	2.5	0.0	19	0.00
	Tripura	234	0	4.1	3.3	0.0	24	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-8.3	-11.3	-22.5	-16.3
Day Peak (MW)	-451.0	-641.1	-992.0	-762.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	197.7	-214.4	186.8	-174.2	4.1	0.0
Actual(MU)	190.0	-206.5	182.6	-178.2	2.9	-9.2
O/D/U/D(MU)	-7.7	7.9	-4.3	-3.9	-1.2	-9.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5518	8096	4888	3861	938	23301	48
State Sector	5923	12236	4722	2299	161	25341	52
Total	11441	20331	9610	6160	1099	48641	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	789	1670	729	714	16	3917	77
Lignite	29	13	42	0	0	85	2
Hydro	95	66	84	24	10	280	5
Nuclear	32	53	66	0	0	151	3
Gas, Naptha & Diesel	12	21	12	0	24	70	1
RES (Wind, Solar, Biomass & Others)	195	156	247	7	1	606	12
Total	1152	1979	1182	745	51	5109	100

Share of RES in total generation (%)	16.94	7.88	20.94	0.93	1.84	11.87
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.91	13.93	33.66	4.19	21.87	20.30

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.037

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	234995	10:45	0
Non-Solar hr	205408	18:49	48

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 11-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	49	0.0	0.6	-0.6
3	765 kV	GAYA-VARANASI	2	0	1043	0.0	16.5	-16.5
4	765 kV	SASARAM-FATEHPUR	1	0	605	0.0	10.9	-10.9
5	765 kV	GAYA-BALIA	1	0	624	0.0	9.4	-9.4
6	400 kV	PUSAULI-VARANASI	1	19	57	0.0	0.6	-0.6
7	400 kV	PUSAULI -ALLAHABAD	1	59	27	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	169	513	0.0	5.2	-5.2
9	400 kV	PATNA-BALIA	2	0	595	0.0	10.6	-10.6
10	400 kV	NAUBATPUR-BALIA	2	0	226	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	74	253	0.0	2.8	-2.8
12	400 kV	MOTIHARI-GORAKHPUR	2	0	342	0.0	5.0	-5.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	400 kV	BIHARSARIFF-SAHUPURI	2	51	425	0.0	7.5	-7.5
15	220 kV	SAHUPURI-KARAMNASA	1	0	115	0.0	0.8	-0.8
16	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
17	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
18	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
19	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	72.9	-72.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	662	706	0.3	0.0	0.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	0	1193	0.0	14.2	-14.2
3	765 kV	JHARSUGUDA-DURG	2	0	1098	0.0	21.8	-21.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	886	0.0	16.1	-16.1
5	400 kV	RANCHI-SIPAT	2	0	333	0.0	4.0	-4.0
6	220 kV	BUDHIPADAR-RAIGARH	1	4	103	0.0	1.2	-1.2
7	220 kV	BUDHIPADAR-KORBA	2	68	123	0.0	0.2	-0.2
ER-WR						0.3	57.4	-57.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	364	0.0	7.5	-7.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1588	0.0	31.6	-31.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3150	0.0	56.2	-56.2
4	400 kV	TALCHER-I/C	2	178	277	1.8	0.0	1.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	95.2	-95.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	288	0	3.6	0.0	3.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	547	0	7.1	0.0	7.1
3	220 kV	ALIPURDUAR-SALAKATI	2	114	0	1.6	0.0	1.6
ER-NER						12.4	0.0	12.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	665	0	15.8	0.0	15.8
NER-NR						15.8	0.0	15.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4038	0.0	88.2	-88.2
2	HVDC	VINDHYACHAL B/B	-	190	0	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	32.0	-32.0
4	765 kV	GWALIOR-AGRA	2	560	1642	1.2	13.0	-11.8
5	765 kV	GWALIOR-PHAGI	2	285	1562	0.4	19.8	-19.4
6	765 kV	JABALPUR-ORAI	2	273	847	0.0	14.8	-14.8
7	765 kV	GWALIOR-ORAI	1	811	0	14.6	0.0	14.6
8	765 kV	SATNA-ORAI	1	0	919	0.0	16.8	-16.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1651	4	19.7	0.0	19.7
10	765 kV	VINDHYACHAL-VARANASI	2	51	1660	0.0	17.7	-17.7
11	400 kV	ZERDA-KANKROLI	1	319	0	4.1	0.0	4.1
12	400 kV	ZERDA -BHINMAL	1	225	0	2.9	0.0	2.9
13	400 kV	VINDHYACHAL -RIHAND	1	482	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	733	134	6.8	0.1	6.7
15	400 kV	NEEMUCH-Chittorgarh	2	836	131	7.2	0.1	7.1
16	220 kV	BHANPURA-RANPUR	1	0	208	0.0	3.2	-3.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	145	0	2.1	0.0	2.1
19	220 kV	MALANPUR-AURAIYA	1	112	0	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						70.9	210.5	-139.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	3004	0.0	42.9	-42.9
3	765 kV	SOLAPUR-RAICHUR	2	1416	1337	5.9	9.3	-3.4
4	765 kV	WARDHA-NIZAMABAD	2	61	2544	0.0	36.5	-36.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2786	0.0	43.7	-43.7
6	400 kV	KOLHAPUR-KUDGI	2	1649	0	24.5	0.0	24.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	117	2.1	0.0	2.1
WR-SR						32.5	156.4	-123.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve) Energy Exchange (MU)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	264	-45	46	1.11	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-272	117	-136	-3.27	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-363	-153	-253	-6.07	
	NER	132kV GELEPHU-SALAKATI	0	0	0	0.00	
	NER	132kV MOTANGA-RANGIA	-17	7	-5	-0.11	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-36	-0.87	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-43	-1.04	
	ER	NEPAL IMPORT (FROM BIHAR)	-183	-45	-147	-3.54	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-458	16	-244	-5.85	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-932	-741	-894	-21.45	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-762	-460	-678	-16.27	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-43	-1.04	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	8.95	0.00	0.00	0.14	0.00	0.00	9.44
Nepal	3.64	0.00	4.33	0.00	0.00	1.92	0.00	0.00	9.89
Bangladesh	22.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.89	0.35	13.28	0.00	0.00	2.06	0.00	0.00	41.58

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.83
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.83

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.83	-0.35	-8.95	0.00	0.00	-0.14	0.00	0.00	-8.61
Nepal	-3.64	0.00	-4.33	0.00	0.00	-1.92	0.00	0.00	-9.89
Bangladesh	-22.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.06	-0.35	-13.28	0.00	0.00	-2.06	0.00	0.00	-40.75

Date of Reporting: 11-Feb-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A- (C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	49.99	161194	5976	5274	107	8009	2138	140080	3276	155813	164860	-1884
0:15	49.94	161664	5978	5130	107	6944	2115	141706	3288	156427	165268	-1864
0:30	49.99	161422	5976	5011	107	6576	2007	142008	3246	156304	164931	-1868
0:45	49.94	160563	5975	4855	107	6226	2104	141993	3222	155601	164482	-1877
1:00	50.04	160532	5980	4882	148	6278	2102	141689	3245	155502	164324	-1871
1:15	49.99	159457	5976	4742	147	5542	1976	141574	3240	154568	163197	-1844
1:30	50.04	158961	5969	4827	148	5380	2095	141034	3217	153986	162670	-1832
1:45	49.99	158029	5974	4705	107	5228	2088	140675	3228	153217	162005	-1842
2:00	50.04	157000	5985	4574	107	5031	2130	139837	3241	152319	160905	-1832
2:15	49.99	156493	5987	4546	107	4760	2097	139695	3263	151840	160455	-1739
2:30	49.99	156440	5980	4380	107	4735	1981	139689	3248	151953	160120	-1656
2:45	49.99	155951	5985	4309	107	4713	2094	139378	3197	151535	159783	-1646
3:00	49.99	155720	5991	4182	106	4655	2126	139241	3263	151432	159564	-1661
3:15	49.94	156148	5990	4071	109	4710	1968	139843	3224	151968	159915	-1655
3:30	49.99	155849	5979	4024	107	4668	2118	139806	3209	151718	159911	-1654
3:45	49.99	156347	5984	4060	108	4679	1975	140091	3244	152179	160141	-1682
4:00	50.04	156907	5985	4111	109	4739	1975	140581	3210	152687	160710	-1686
4:15	49.99	159125	5979	4049	109	5187	1972	142472	3208	154967	162976	-1696
4:30	49.99	160595	5968	4105	108	5400	2010	143548	3236	156382	164375	-1711
4:45	49.94	161880	5983	4040	108	5446	1979	145041	3238	157732	165835	-1702
5:00	49.99	164322	5941	3995	107	5834	1977	147283	3222	160220	168359	-1726
5:15	49.99	168482	5976	3903	109	6580	2009	150865	3207	164470	172649	-1718
5:30	49.99	172096	5985	3858	109	6963	2171	153821	3187	168129	176094	-1746
5:45	50.04	176334	5951	3851	110	8266	1972	156975	3224	172373	180349	-1791
6:00	50.04	179616	5994	3736	118	9338	2245	158946	3270	175762	183647	-1833
6:15	49.94	184432	5969	3774	366	10838	2192	162000	3261	180292	188400	-1708
6:30	49.89	191106	5972	3565	376	13850	2449	165249	3270	187165	194731	-1461
6:45	49.94	196662	5977	3356	341	17382	2765	167213	3327	192965	200361	-1313
7:00	49.99	201934	5986	3370	604	20569	3346	168225	3313	197960	205413	-1361
7:15	49.84	206190	5986	3470	1283	22798	3765	168796	3313	201437	209411	-1079
7:30	49.99	209599	5988	3565	2774	23754	3622	169214	3360	203260	212277	-1013
7:45	50.04	211991	5989	3471	5324	24253	3708	168305	3357	203196	214407	-954
8:00	50.14	213114	5981	3318	8453	23694	4101	166236	3416	201343	215199	-928
8:15	50.04	217234	5984	3235	12504	23152	3969	167014	3454	201495	219312	-939
8:30	50.04	219644	5990	2806	16837	21293	4319	167053	3454	200001	221752	-958
8:45	50.04	223010	5989	2533	21134	20829	4161	166604	3511	199343	224761	-932
9:00	50.09	224848	5981	2465	26225	19065	3480	165678	3529	196158	226423	-1050
9:15	49.89	229666	5981	2481	29451	18719	3639	167831	3532	197734	231634	-1056
9:30	49.89	232504	5966	2327	33808	17481	3384	167933	3533	196369	234432	-1266
9:45	49.99	234207	5935	2321	37589	16258	3725	167740	3522	194297	237090	-1336
10:00	49.99	234437	5934	2437	40931	15237	2767	166424	3522	191069	237252	-1491
10:15	49.79	234052	5923	2506	43532	13096	2207	166149	3492	188014	236905	-1478
10:30	49.79	234642	5943	2476	45964	13154	2146	164755	3493	186202	237931	-1762
10:45	50.04	234995	5927	2429	48060	12384	2129	164267	3441	184506	238637	-2085
11:00	50.09	234488	5956	2542	51284	11342	2133	160987	3414	180662	237658	-2186
11:15	50.04	233236	5903	2647	53911	10095	2064	158821	3460	176678	236901	-2161
11:30	50.04	232070	5667	2756	54811	9617	2102	157332	3446	174503	235731	-2158
11:45	50.04	231149	5652	2733	55713	9261	2041	155614	3459	172703	234473	-2133
12:00	50.09	230578	5420	2726	57056	8467	1989	154038	3470	170796	233166	-2137
12:15	50.04	229221	5409	2653	59048	8018	1973	152412	3425	167520	232938	-2115
12:30	50.04	227191	5412	2715	60074	8243	1965	150342	3462	164402	232213	-2115
12:45	50.04	226587	5412	2755	60864	8141	2031	149484	3479	162968	232166	-2091
13:00	50.09	223527	5400	2765	61293	7151	1947	145727	3432	159469	227715	-2147
13:15	49.99	219390	5392	2993	60882	6662	1945	142377	3424	155515	223675	-2142
13:30	50.04	218467	5397	2996	60302	6337	1945	142132	3421	155169	222530	-2162
13:45	49.99	217379	5391	3082	59873	6231	1946	141691	3396	154424	221610	-2158
14:00	49.99	216809	5386	3256	59490	6509	1927	141458	3397	154063	221423	-2136
14:15	49.89	216598	5383	3244	57782	6314	1965	142767	3365	155572	220820	-2156
14:30	49.94	217601	5647	3298	56417	6679	1966	144572	3371	157886	221950	-2167
14:45	49.89	217385	5784	3406	54562	7033	1959	145875	3394	159417	222013	-2154
15:00	49.94	218009	5869	3383	52459	7607	1972	147833	3380	162167	222503	-2172
15:15	49.94	218362	5893	3441	49721	7936	1987	150520	3362	165200	222860	-2145
15:30	50.04	218306	5889	3575	46878	8463	2029	152602	3299	167853	222735	-2165
15:45	50.04	217290	5902	3589	43967	8902	2037	154051	3304	169734	221752	-2151
16:00	50.04	216428	5899	3643	40017	9790	2185	155586	3278	172768	220398	-2163
16:15	49.99	213135	5925	3598	36320	9845	2194	156795	3230	173217	217907	-2132
16:30	49.99	213900	5902	3716	31658	11344	2261	159966	3185	178526	218032	-2119
16:45	49.99	212982	5906	3675	26754	12745	2247	162699	3182	182553	217208	-1754
17:00	50.04	211299	5909	3573	22016	14832	2274	163375	3137	185710	215116	-1426
17:15	50.04	206312	5915	3508	16749	16439	2278	162078	3112	186055	210079	-1024
17:30	50.04	205183	5941	3506	12067	19182	2302	163103	3132	189610	209233	-1018
17:45	49.99	203617	5923	3504	7677	21202	2370	164252	3044	192436	207972	-991
18:00	50.04	203269	5920	3514	4370	22230	2420	165573	3087	195385	207114	-935
18:15	49.94	202850	5936	3549	2306	22049	2572	166840	3118	196995	206370	-886
18:30	49.94	203504	5931	3612	451	23072	2592	168508	3119	199441	207285	-940
18:45	49.94	204647	5930	3756	357	23570	2454	169018	3153	200534	208238	-943
19:00	49.99	204915	5924	3917	301	23289	2422	169016	3140	200697	208009	-931
19:15	50.04	202266	5938	4182	304	21177	2427	168041	3140	197780	205209	-923
19:30	50.04	200328	5937	4544	308	19617	2309	167568	3111	195476	203394	-901
19:45	50.04	198277	5941	4873	366	17940	2287	166903	3115	193038	201425	-942
20:00	50.04	194808	5930	5102	362	16084	2232	165043	3128	189344	197881	-954
20:15	50.04	191884	5943	5376	318	13266	2208	164772	3162	186190	195045	-1011
20:30	49.99	189809	5935	5593	314	12472	2145	163276	3187	183902	192922	-1059
20:45	49.99	187848	5941	5793	322	11288	2147	162494	3193	181733	191178	-1110
21:00	49.94	185345	5938	6032	312	10518	2134	160544	3204	179001	188682	-1177
21:15	50.04	183781	5947	6195	315	10445	2131	159499	3226	177271	187758	-1602
21:30	49.99	182158	5921	6617	276	10297	2146	157766	3199	175265	186222	-1843
21:45	50.04	180068	5915	6886	277	9598	2110	156606	3206	172905	184598	-1882
22:00	50.04	177339	5915	7077	257	8637	2092	154860	3251	170005	182089	-1919
22:15	49.98	178709	5932	7250	275	9568	2103	155320	3227	171184	183675	-1875
22												