



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 30.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 29.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 29-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 29.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 30-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53696	63747	45268	21434	2763	186908
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1224	1517	1071	448	50	4310
Hydro Gen (MU)	122	34	101	28	14	300
Wind Gen (MU)	34	104	58	-	-	196
Solar Gen (MU)*	151.55	129.69	81.35	3.19	1.03	367
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64475	71325	54367	22429	2906	211575
Time Of Maximum Demand Met	10:36	10:22	10:00	17:57	16:58	10:18

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.19	4.91	5.09	77.62	17.29

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9784	0	165.8	82.0	0.2	364	0.00
	Haryana	8505	0	162.0	136.6	-1.4	314	0.00
	Rajasthan	17284	0	338.3	121.9	2.1	801	0.00
	Delhi	4095	0	74.8	67.1	1.5	386	0.00
	UP	17964	0	331.7	92.0	-1.2	382	0.00
	Uttarakhand	2240	0	41.5	32.1	-0.2	160	0.00
	HP	2145	0	37.8	27.5	-0.7	178	0.00
	J&K(UT) & Ladakh(UT)	3082	0	64.0	58.1	-0.8	242	0.00
	Chandigarh	207	0	3.6	3.6	0.0	11	0.00
	Railways_NR ISTS	195	0	3.9	3.9	0.1	27	0.00
WR	Chhattisgarh	4530	0	88.9	28.1	-0.6	196	0.00
	Gujarat	22873	0	448.0	206.4	-5.9	595	0.00
	MP	18090	0	332.8	206.9	0.1	513	0.00
	Maharashtra	26696	0	563.2	186.3	-0.3	462	0.00
	Goa	683	0	14.0	12.3	1.6	26	0.00
	DNHDDPDCL	1332	0	30.6	31.0	-0.4	41	0.00
	AMNSIL	928	0	20.8	13.8	-0.1	288	0.00
	BALCO	558	0	13.0	13.4	-0.4	9	0.00
	RIL JAMNAGAR	252	0	5.9	5.9	0.0	0	0.00
	Andhra Pradesh	10037	0	205.5	58.9	1.6	987	0.00
SR	Telangana	10945	0	201.4	83.7	1.0	772	0.00
	Karnataka	15356	0	276.2	93.0	0.5	1016	0.00
	Kerala	4092	0	79.8	65.6	-1.5	228	0.00
	Tamil Nadu	14624	0	299.8	200.1	-0.9	1044	0.00
	Puducherry	357	0	7.8	7.5	-0.3	31	0.00
	Bihar	4987	0	91.3	76.8	0.1	214	0.00
ER	DVC	3154	0	63.6	-41.3	-0.7	553	0.00
	Jharkhand	2131	0	39.1	26.8	-1.3	482	0.00
	Odisha	5215	0	99.9	18.9	-3.9	239	0.00
	West Bengal	7501	0	152.3	46.2	-2.8	130	0.00
	Sikkim	92	0	1.5	1.6	-0.1	21	0.00
	Railways_ER ISTS	14	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	177	0	2.9	2.8	0.0	38	0.00
	Assam	1661	0	29.1	22.7	-0.1	105	0.00
	Manipur	243	0	3.7	3.5	0.2	40	0.00
	Meghalaya	349	0	6.0	5.1	-0.1	87	0.00
	Mizoram	152	0	2.0	1.1	-0.2	19	0.00
	Nagaland	167	0	2.6	2.6	0.0	25	0.00
	Tripura	234	0	4.0	5.0	0.2	51	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.2	13.7	-21.3	-22.6
Day Peak (MW)	-398.4	788.6	-1017.4	-1324.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	265.6	-199.3	139.6	-211.4	5.5	0.0
Actual(MU)	251.2	-194.2	143.0	-217.7	3.8	-13.9
O/D/U/D(MU)	-14.4	5.1	3.4	-6.2	-1.8	-13.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6103	12805	7188	4050	55	30201	46
State Sector	12909	11256	8842	2827	205	36039	54
Total	19012	24061	16030	6877	260	66240	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	662	1475	655	707	13	3513	75
Lignite	22	19	48	0	0	88	2
Hydro	122	34	101	28	14	300	6
Nuclear	32	53	46	0	0	131	3
Gas, Naptha & Diesel	7	19	5	0	23	55	1
RES (Wind, Solar, Biomass & Others)	206	238	163	5	1	613	13
Total	1051	1838	1018	741	52	4699	100

Share of RES in total generation (%)	19.60	12.93	16.00	0.72	1.98	13.04
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.27	17.66	30.43	4.53	29.65	22.20

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.053

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	211575	10:18	0
Non-Solar hr	198986	17:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 30-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1743	0.0	26.3	-26.3
4	765 kV	SASARAM-FATEHPUR	1	0	718	0.0	11.5	-11.5
5	765 kV	GAYA-BALIA	1	0	846	0.0	9.0	-9.0
6	400 kV	PUSAULI-VARANASI	1	38	42	0.2	0.0	0.2
7	400 kV	PUSAULI-ALLAHABAD	1	0	135	0.0	2.5	-2.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	833	0.0	10.7	-10.7
9	400 kV	PATNA-BALIA	2	0	1265	0.0	21.9	-21.9
10	400 kV	NAUBATPUR-BALIA	2	0	350	0.0	8.2	-8.2
11	400 kV	BIHARSHARIFF-BALIA	2	0	466	0.0	3.5	-3.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	595	0.0	10.5	-10.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	548	0.0	8.1	-8.1
14	220 kV	SAHUPURI-KARMANASA	1	31	6	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	116.8	-116.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1604	0.0	18.1	-18.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	431	667	0.0	3.2	-3.2
3	765 kV	JHARSUGUDA-DURG	2	0	1278	0.0	24.5	-24.5
4	400 kV	JHARSUGUDA-RAIGARH	4	52	401	0.0	3.9	-3.9
5	400 kV	RANCHI-SIPAT	2	70	354	0.0	4.0	-4.0
6	400 kV	JEYPORE-JACDALPUR	2	241	293	1.5	0.0	1.5
7	220 kV	BUDHIPADAR-RAIGARH	1	0	144	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	86	96	0.1	0.0	0.1
ER-WR						1.6	55.7	-54.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	308	0.0	7.3	-7.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1618	0.0	41.2	-41.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2883	0.0	56.7	-56.7
4	400 kV	TALCHER/IC	2	375	275	2.1	0.0	2.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	105.2	-105.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	385	91	2.8	0.1	2.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	685	33	6.2	0.0	6.2
3	220 kV	ALIPURDUAR-SALAKATI	2	130	0	1.5	0.0	1.5
ER-NER						10.4	0.1	10.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	659	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3043	0.0	47.4	-47.4
2	HVDC	VINDHYACHAL B/B	-	242	0	6.2	0.0	6.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	26.1	-26.1
4	765 kV	GWALIOR-AGRA	2	0	1947	0.0	27.6	-27.6
5	765 kV	GWALIOR-PHAGI	2	0	2501	0.0	38.6	-38.6
6	765 kV	JABALPUR-ORAI	2	0	1029	0.0	33.0	-33.0
7	765 kV	GWALIOR-ORAI	1	1038	0	18.4	0.0	18.4
8	765 kV	SATNA-ORAI	1	0	1175	0.0	22.0	-22.0
9	765 kV	BANASKANTHA-CHITORGARH	2	2206	0	24.0	0.0	24.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2267	0.0	35.1	-35.1
11	400 kV	ZERDA-KANKROLI	1	363	0	4.5	0.0	4.5
12	400 kV	ZERDA -BHINMAL	1	250	0	3.1	0.0	3.1
13	400 kV	VINDHYACHAL -RIHAND	1	965	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	403	402	1.4	2.6	-1.2
15	400 kV	NEEMUCH-Chittorgarh	2	450	370	1.7	2.7	-1.0
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	82	11	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	54	20	0.3	0.1	0.3
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						81.8	238.7	-156.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	21.5	-21.5
2	HVDC	RAIGARH-PUGALUR	2	0	2002	0.0	21.9	-21.9
3	765 kV	SOLAPUR-RAICHUR	2	857	1588	1.7	11.6	-9.8
4	765 kV	WARDHA-NIZAMABAD	2	131	1508	0.1	20.0	-19.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2573	0.0	40.5	-40.5
6	400 kV	KOLHAPUR-KUDGI	2	1431	0	23.5	0.0	23.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	104	0.0	2.0	-2.0
WR-SR						27.3	115.4	-88.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-111	51	21	0.49
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	291	24	181	4.33
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-291	-242	-269	-6.45
	NER	132kV GELEPHU-SALAKATI	-62	-47	-55	-1.31
	NER	132kV MOTANGA-RANGIA	-20	-3	-13	-0.30
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	65	0	47	1.13
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	682	314	525	12.60
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-906	-598	-801	-19.23
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1324	-806	-941	-22.57
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-107	0	-85	-2.04

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 30-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.37	2.81	0.00	0.00	0.63	0.00	0.00	3.81
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	20.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.00	0.37	2.81	0.00	0.00	0.63	0.00	0.00	23.81

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	13.08	0.00	0.00	13.08
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	13.08	0.00	0.00	13.08

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.37	-2.81	0.00	0.00	-0.63	0.00	0.00	-3.81
Nepal	0.00	0.00	0.00	0.00	0.00	13.08	0.00	0.00	13.08
Bangladesh	-20.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.00	-0.37	-2.81	0.00	0.00	12.45	0.00	0.00	-10.73

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.03	149592	4625	13045	0	6996	2068	123741	2950	136547	153425	-285
0:15	49.98	148657	4627	13239	0	7025	1990	122618	2860	135418	152359	-334
0:30	49.98	148040	4621	13362	0	6970	1984	121680	2882	134678	151499	-367
0:45	49.98	147508	4623	13276	0	6927	2038	121156	2971	134232	150991	-382
1:00	49.98	146757	4624	13038	0	6876	2094	120820	2874	133719	150326	-376
1:15	49.93	146743	4629	12815	0	6844	2115	120600	2920	133928	149923	-241
1:30	49.93	146275	4633	12690	0	6835	2085	120507	2949	133585	149699	-303
1:45	49.93	145464	4636	12305	0	6893	2081	119832	2873	133159	148620	-282
2:00	50.03	144152	4631	12273	0	6654	2090	118851	2894	131879	147393	-281
2:15	49.98	144226	4637	12259	0	6698	2095	118685	2852	131967	147226	-268
2:30	49.98	143893	4647	12077	0	6702	2096	118642	2849	131816	147013	-284
2:45	49.98	143910	4636	11762	0	7084	2094	118588	2946	132148	147110	-336
3:00	50.03	143232	4631	11376	0	7024	2114	118270	2853	131856	146268	-272
3:15	49.98	143500	4639	11023	0	6245	2106	119595	2875	132477	146483	-235
3:30	49.98	143845	4650	10855	0	6500	2108	119882	2913	132990	146908	-181
3:45	49.98	143936	4653	10325	0	6692	2172	120286	2842	133611	146970	-182
4:00	50.03	144746	4656	10107	0	6754	2152	121049	2953	134639	147671	-204
4:15	50.03	145679	4665	9797	0	7252	2211	122065	2903	135882	148893	-192
4:30	50.03	147347	4671	9471	0	7505	2206	123960	2870	137876	150683	-226
4:45	50.08	148914	4669	9121	0	8335	2209	125256	2911	139793	152501	-180
5:00	50.08	150893	4659	8759	379	9127	2218	127139	2925	141755	155206	-58
5:15	49.98	155222	4673	8450	368	9512	2222	131418	2928	146404	159571	0
5:30	50.03	159251	4664	8190	280	10764	2207	135173	2888	150781	164166	-51
5:45	49.98	163973	4652	7941	323	11392	2192	139625	2877	155709	169002	-43
6:00	50.08	167152	4646	7608	319	11969	2212	142948	2992	159225	172694	-121
6:15	50.03	172199	4650	7429	351	14606	2170	146148	2906	164419	178260	-110
6:30	50.03	176962	4672	7226	319	16928	2163	149114	2918	169417	183340	-98
6:45	49.98	181788	4674	6823	550	18552	2156	152614	2878	174415	188247	-104
7:00	50.03	185371	4677	6781	1135	19268	2141	155269	2861	177455	192132	-183
7:15	49.98	189632	4660	6575	2114	20137	2114	157864	2858	180943	196322	-255
7:30	49.98	193012	4674	6469	3796	20608	2120	158923	2842	182747	199432	-289
7:45	50.03	193901	4674	6392	6451	19076	2104	158185	2851	181058	199733	-275
8:00	50.08	193720	4661	6393	10161	17918	2106	155711	2937	177166	199887	-336
8:15	50.03	196717	4669	6223	14076	15379	2115	157204	2938	176418	202604	-423
8:30	50.03	198977	4664	5839	19025	13759	2109	155838	2877	174113	204111	-388
8:45	50.03	201051	4649	5500	24149	12081	2115	155102	2928	171402	206524	-420
9:00	50.08	202330	4665	4986	28096	10496	2113	153881	2924	169248	207161	-397
9:15	49.88	206167	4652	4454	32543	10003	2120	154462	2858	169170	211092	-405
9:30	49.93	209225	4916	4006	36850	10639	2092	152672	2881	168369	214056	-405
9:45	49.88	210214	4894	3670	40150	10899	2121	150602	2925	166394	215261	-568
10:00	49.98	211213	4897	3541	44095	10556	2117	148320	2874	163577	216400	-772
10:15	50.03	211476	4890	3301	47684	9706	2126	146117	2922	160491	216746	-752
10:30	50.03	210994	4894	3253	49499	8808	2104	145120	2938	158242	216616	-785
10:45	50.03	211047	4906	3239	50861	8688	2110	143529	2915	156947	216248	-746
11:00	50.09	209309	4907	3258	52333	8403	2101	140395	2865	153718	214262	-740
11:15	50.03	207378	4892	3244	53524	7624	2050	138046	2896	150610	212276	-673
11:30	49.93	206959	4907	3321	54614	7571	2022	136371	2848	149024	211654	-677
11:45	49.88	205314	4889	3399	54957	7654	2086	134097	2882	146958	209964	-676
12:00	50.03	203528	4888	3468	55454	8055	2112	131097	2814	144606	207888	-664
12:15	49.98	201321	4890	3531	55874	7650	2114	129439	2833	141916	206331	-714
12:30	49.98	200592	4890	3646	55270	8011	2127	129237	2813	141676	205994	-771
12:45	49.98	199429	4889	3721	55133	8020	2137	128187	2807	140575	204894	-790
13:00	50.03	196747	4886	3772	54609	8019	2084	125826	2782	138366	201978	-817
13:15	50.03	194747	4892	3836	54131	7916	2117	123598	2791	136780	199281	-848
13:30	49.98	193867	4885	3881	52980	7729	2107	124331	2791	137006	198704	-784
13:45	50.03	194585	4880	3912	52677	7781	2164	125260	2871	137996	199545	-798
14:00	50.03	195223	4873	3946	51446	7802	2187	127346	2819	139831	200419	-758
14:15	50.03	196003	4879	3991	49632	8196	2276	129625	2810	142380	201409	-728
14:30	49.98	195591	4822	3959	44683	8036	2226	134406	2884	146949	201016	-725
14:45	49.93	195453	4824	3791	42236	8590	2243	136626	2881	149426	201191	-881
15:00	49.98	195923	4803	3767	39566	8938	2239	139654	2825	152590	201792	-870
15:15	49.98	194760	4837	3749	36224	9292	2301	141446	2888	154787	200737	-890
15:30	50.03	194926	4826	3666	32259	9616	2344	145434	2862	159001	201007	-908
15:45	50.03	195718	4830	3613	28560	10077	2356	149151	2887	163545	201474	-898
16:00	50.03	195169	4820	3741	24370	11330	2414	151389	2904	167058	200968	-821
16:15	50.03	191559	4831	3743	19806	11336	2506	152664	2934	168010	197820	-743
16:30	49.93	191637	4843	3786	15358	13024	2549	155028	2906	172493	197494	-750
16:45	49.78	191730	4828	3886	10711	15398	2248	157722	2854	177133	197647	-607
17:00	49.98	192905	4819	4030	7212	18521	2415	159346	2829	181663	199172	-648
17:15	49.93	191446	4825	4297	4339	19830	2458	158958	2912	182810	197619	-676
17:30	49.98	194381	4830	4634	2244	23147	2503	160756	2905	187503	201019	-769
17:45	49.93	197610	4834	5008	930	26807	2531	161689	2899	191672	204698	-606
18:00	50.03	198465	4837	5116	655	27967	2570	161402	2905	192694	205452	-593
18:15	50.03	197447	4825	5529	382	28079	2569	159773	2857	191536	204014	-470
18:30	50.08	196151	4847	6014	351	27639	2453	158712	2863	189786	202879	-430
18:45	50.08	193760	4849	6575	276	26195	2365	157368	2867	186909	200495	-479
19:00	50.03	189427	4855	7203	285	24815	2310	153832	2907	181939	196207	-473
19:15	49.98	187371	4855	7817	275	23525	2338	152216	2925	179279	193951	-471
19:30	50.03	185374	4839	8281	0	22096	2296	150790	2836	177093	191138	-379
19:45	50.04	181624	4838	8681	0	19263	2259	148941	2859	172943	186841	-343
20:00	50.09	178232	4850	9027	0	18008	2228	145816	2891	169205	182820	-360
20:15	50.04	175291	4855	9455	0	16020	2241	144530	2865	165836	179966	-314
20:30	50.04	172568	4851	9677	0	14579	2222	142453	2884	162891	176666	-313
20:45	50.04	170934	4855	9822	0	13053	2238	141710	2919	161112	174597	-266
21:00	50.04	167702	4854	9891	0	12600	2235	139164	2921	157811	171665	-279
21:15	50.04	165131	4862	9960	0	11794	2124	137168	2879	155171	168787	-240
21:30	50.04	163225	4854	9914	0	11850	2051	135239	2931	153311	166839	-214
21:45	50.04	160676	4872	9884	0	10502	2049	134344	2925	150792	164576	-306
22:00	50.09	157592	4866	9920	0	9882	2041	131824	2937	147672	161470	-355
22:15	49.94	157599	4859	9958	0	9467	2003	132128	2989	147641	161404	-324
22:30	49.99	156478	4865	10086	0	9356	2000	130942	2934	146392	160183	-331
22:45	49.99	154769	4857	10288	0	8818	1990					