



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 12.09.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.09.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 11-सितंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.09.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Sep-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	68198	54808	47779	28764	3412	202961
Peak Shortage (MW)	126	0	0	0	0	126
Energy Met (MU)	1514	1304	1159	629	65	4671
Hydro Gen (MU)	378	115	178	93	31	795
Wind Gen (MU)	13	109	225	-	-	346
Solar Gen (MU)*	151.88	58.71	134.93	3.08	0.73	349
Energy Shortage (MU)	0.25	0.00	0.00	0.00	0.00	0.25
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69099	58073	53927	29396	3441	207171
Time Of Maximum Demand Met	21:20	19:06	10:57	23:01	19:32	19:12

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.020	0.00	0.00	1.24	1.24	86.03	12.73

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14244	0	294.8	180.2	0.6	560	0.00
	Haryana	10297	0	216.4	155.1	-0.3	475	0.00
	Rajasthan	12394	0	279.6	83.0	-2.1	589	0.00
	Delhi	5683	0	121.3	106.4	2.3	447	0.00
	UP	23391	0	449.7	210.0	-3.5	402	0.00
	Uttarakhand	2447	0	51.7	24.6	0.7	266	0.00
	HP	1780	0	36.6	2.2	-0.7	82	0.00
	J&K(UT) & Ladakh(UT)	2618	30	52.6	26.8	0.9	323	0.25
	Chandigarh	344	0	6.8	6.7	0.2	42	0.00
WR	Railways_NR ISTS	214	0	4.4	3.9	0.5	44	0.00
	Chhattisgarh	4710	0	100.0	50.6	-2.3	265	0.00
	Gujarat	17957	0	395.6	177.2	-1.7	570	0.00
	MP	9942	0	205.4	74.1	-5.5	302	0.00
	Maharashtra	23906	0	530.9	177.6	2.1	840	0.00
	Goa	601	0	13.2	11.0	1.9	14	0.00
	DNHDDPDCL	1312	0	30.2	30.3	-0.1	84	0.00
	AMNSIL	722	0	16.2	9.7	0.1	235	0.00
	BALCO	529	0	12.6	12.6	0.0	3	0.00
SR	Andhra Pradesh	9926	0	215.4	51.7	-1.4	499	0.00
	Telangana	12039	0	237.4	98.5	0.6	557	0.00
	Karnataka	12405	0	224.5	55.7	-0.9	519	0.00
	Kerala	4239	0	84.1	53.9	0.6	206	0.00
	Tamil Nadu	17926	0	387.1	165.4	1.4	1160	0.00
	Puducherry	491	0	10.7	10.3	-0.2	37	0.00
	Railways_SR ISTS	32	0	0.2	0.2	0.0	2	0.00
ER	Bihar	7436	0	156.7	147.8	-0.3	260	0.00
	DVC	3452	0	74.3	-28.5	0.9	404	0.00
	Jharkhand	2137	0	44.0	35.7	-0.7	166	0.00
	Odisha	5828	0	120.5	56.9	-2.6	473	0.00
	West Bengal	11045	0	231.7	111.8	-1.1	321	0.00
	Sikkim	75	0	1.2	1.5	-0.3	6	0.00
	Railways_ER ISTS	32	0	0.2	0.2	0.0	2	0.00
NER	Arunachal Pradesh	179	0	1.9	2.7	-1.3	23	0.00
	Assam	2283	0	44.5	36.4	0.3	203	0.00
	Manipur	176	0	2.8	3.0	-0.2	23	0.00
	Meghalaya	272	0	4.6	1.5	-0.4	27	0.00
	Mizoram	116	0	2.0	0.6	-0.4	15	0.00
	Nagaland	158	0	2.4	2.6	-0.6	13	0.00
	Tripura	324	0	6.8	6.3	0.6	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	41.7	16.2	-23.0	-24.5
Day Peak (MW)	2121.0	800.2	-997.0	-1042.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	270.0	-250.2	4.0	-28.9	5.1	0.0
Actual(MU)	267.6	-225.3	-22.7	-28.3	3.2	-5.5
O/D/U/D(MU)	-2.5	24.8	-26.6	0.7	-1.9	-5.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4803	15469	3528	3936	280	28016	45
State Sector	5022	12184	12227	4379	155	33966	55
Total	9824	27653	15755	8315	435	61982	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	717	1238	544	617	15	3132	63
Lignite	24	12	58	0	0	94	2
Hydro	378	115	178	93	31	795	16
Nuclear	30	70	76	0	0	176	4
Gas, Naptha & Diesel	16	34	5	0	23	79	2
RES (Wind, Solar, Biomass & Others)	171	169	388	5	1	734	15
Total	1336	1639	1250	716	69	5010	100

Share of RES in total generation (%)	12.80	10.31	31.05	0.76	1.06	14.66
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.30	21.60	51.41	13.74	45.90	34.04

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.032
Based on State Max Demands	1.079

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	201852	15:35	0
Non-Solar hr	207171	19:12	96

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 12-Sep-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	702	0.0	17.0	-17.0
2	HVDC	PUSAULI B/B	-	0	112	0.0	2.9	-2.9
3	765 kV	GAYA-VARANASI	2	850	378	3.2	0.0	3.2
4	765 kV	SASARAM-FATEHPUR	1	345	210	1.1	0.0	1.1
5	765 kV	GAYA-BALIA	1	0	680	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	153	0.0	3.1	-3.1
7	400 kV	PUSAULI -ALLAHABAD	1	44	15	0.4	0.0	0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	181	472	0.0	5.1	-5.1
9	400 kV	PATNA-BALIA	2	181	523	0.0	6.9	-6.9
10	400 kV	NAUBATPUR-BALIA	2	104	274	0.0	1.9	-1.9
11	400 kV	BIHARSHARIFF-BALIA	2	345	19	3.0	0.0	3.0
12	400 kV	MOTIHARI-GORAKHPUR	2	129	283	0.0	3.2	-3.2
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	68	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						8.4	51.2	-42.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	414	701	0.0	4.9	-4.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2378	0	37.5	0.0	37.5
3	765 kV	JHARSUGUDA-DURG	2	67	439	0.0	4.6	-4.6
4	400 kV	JHARSUGUDA-RAIGARH	4	294	303	0.0	1.2	-1.2
5	400 kV	RANCHI-SIPAT	2	612	0	8.7	0.0	8.7
6	220 kV	BUDHIPADAR-RAIGARH	1	3	85	0.0	1.2	-1.2
7	220 kV	BUDHIPADAR-KORBA	2	91	47	0.4	0.0	0.4
ER-WR						46.6	11.8	34.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	521	0.0	12.1	-12.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	2	0.0	0.0	0.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2350	0.0	33.1	-33.1
4	400 kV	TALCHER-I/C	2	1889	0	38.4	0.0	38.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	45.2	-45.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	363	0.0	5.0	-5.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	507	0.0	6.8	-6.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	118	0.0	1.6	-1.6
ER-NER						0.0	13.5	-13.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	502	0.0	12.0	-12.0
NER-NR						0.0	12.0	-12.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2001	0.0	47.5	-47.5
2	HVDC	VINDHYACHAL B/B	-	0	395	0.0	2.0	-2.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	975	0.0	13.8	-13.8
4	765 kV	GWALIOR-AGRA	2	0	1891	0.0	32.0	-32.0
5	765 kV	GWALIOR-PHAGI	2	1051	2091	4.1	22.3	-18.2
6	765 kV	JABALPUR-ORAI	2	0	1163	0.0	34.3	-34.3
7	765 kV	GWALIOR-ORAI	1	635	138	7.7	0.4	7.3
8	765 kV	SATNA-ORAI	1	0	1027	0.0	17.5	-17.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1273	0	14.0	0.0	14.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	3435	0.0	63.0	-63.0
11	400 kV	ZERDA-KANKROLI	1	238	31	2.7	0.0	2.6
12	400 kV	ZERDA -BHINMAL	1	203	123	0.1	0.9	-0.9
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	403	652	1.8	5.5	-3.7
15	400 kV	NEEMUCH-Chittorgarh	2	349	746	1.3	6.8	-5.4
16	220 kV	BHANPURA-RANPUR	1	0	81	0.0	1.4	-1.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	47	63	0.0	0.2	-0.2
19	220 kV	MALANPUR-AURAIYA	1	31	63	0.1	0.3	-0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						31.7	249.3	-217.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	998	0	13.4	0.0	13.4
2	HVDC	RAIGARH-PUGALUR	2	1358	501	4.9	5.4	-0.5
3	765 kV	SOLAPUR-RAICHUR	2	1992	922	17.1	1.7	15.4
4	765 kV	WARDHA-NIZAMABAD	2	0	2145	0.0	20.0	-20.0
5	765 kV	WARORA-WARANGAL(NEW)	2	86	2139	0.0	19.1	-19.1
6	400 kV	KOLHAPUR-KUDGI	2	2269	0	37.7	0.0	37.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	101	2.1	0.0	2.1
WR-SR						75.2	46.1	29.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	787	619	718	17.22	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	1038	815	852	20.45	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	219	-14	89	2.15	
	NER	132kV GELEPHU-SALAKATI	34	20	25	0.61	
	NER	132kV MOTANGA-RANGIA	71	23	51	1.23	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-26	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	55	1.32	
	ER	NEPAL IMPORT (FROM BIHAR)	17	9	16	0.38	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	714	532	604	14.50	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-906	-714	-878	-21.08	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1042	-996	-1021	-24.51	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-91	0	-81	-1.94	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03
Bangladesh	21.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.90

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.00	0.00	1.87	0.00	0.00	0.04	0.00	0.00	40.91
Nepal	6.44	0.00	10.95	0.00	0.00	0.00	0.00	0.00	17.39
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	45.44	0.00	12.82	0.00	0.00	0.04	0.00	0.00	58.30

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.00	0.00	1.87	0.00	0.00	0.04	0.00	0.00	40.91
Nepal	6.41	0.00	10.95	0.00	0.00	0.00	0.00	0.00	17.36
Bangladesh	-21.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	23.54	0.00	12.82	0.00	0.00	0.04	0.00	0.00	36.40