



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 27.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 26-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52004	55129	41423	26526	31110	178192
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1182	1287	933	575	60	4037
Hydro Gen (MU)	165	39	155	63	26	448
Wind Gen (MU)	31	137	60	-	-	228
Solar Gen (MU)*	179.61	86.88	124.12	3.36	1.00	395
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	55553	57986	43278	26476	3240	185956
Time Of Maximum Demand Met	10:39	18:34	18:34	21:36	17:31	18:29

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.08	4.27	4.35	83.07	12.58

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7933	0	152.0	76.8	-0.7	592	0.00
	Haryana	7261	0	155.3	131.9	-0.4	166	0.00
	Rajasthan	13916	0	277.2	73.6	-3.5	582	0.00
	Delhi	3854	0	78.3	76.5	-0.5	139	0.00
	UP	19106	0	391.8	139.4	-0.7	641	0.00
	Uttarakhand	1995	0	37.6	25.8	0.4	240	0.00
	HP	1737	0	29.9	15.1	-0.5	225	0.00
	J&K(UT) & Ladakh(UT)	2717	0	52.1	40.9	1.5	327	0.00
	Chandigarh	193	0	3.5	3.5	0.0	16	0.00
	Railways_NR ISTS	205	0	4.5	4.0	0.5	36	0.00
WR	Chhattisgarh	4847	0	107.0	54.4	-0.5	267	0.00
	Gujarat	18424	0	382.5	211.6	0.6	1478	0.00
	MP	11682	0	231.6	141.2	0.0	195	0.00
	Maharashtra	22744	0	485.9	170.3	-1.3	737	0.00
	Goa	620	0	13.2	11.0	1.6	175	0.00
	DNHDDPDCL	1286	0	29.8	29.6	0.2	69	0.00
	AMNSIL	849	0	17.7	9.7	1.1	278	0.00
	BALCO	537	0	12.8	12.8	0.0	6	0.00
	RIL JAMNAGAR	255	0	6.1	6.2	-0.1	0	0.00
	Andhra Pradesh	8686	0	182.5	53.1	-0.4	506	0.00
SR	Telangana	8898	0	183.9	77.9	-0.3	547	0.00
	Karnataka	8906	0	191.4	46.9	-1.5	554	0.00
	Kerala	4010	0	77.1	41.5	-0.3	263	0.00
	Tamil Nadu	13879	0	289.8	140.0	-2.6	938	0.00
	Puducherry	389	0	8.8	8.3	-0.1	41	0.00
	Bihar	6597	0	138.5	127.1	0.6	355	0.00
ER	DVC	3204	0	68.5	-27.4	1.6	319	0.00
	Jharkhand	2182	0	42.7	33.2	-0.6	247	0.00
	Odisha	5903	0	118.2	49.3	-3.3	402	0.00
	West Bengal	9932	0	205.8	72.3	-1.2	244	0.00
	Sikkim	67	0	1.0	1.2	-0.2	9	0.00
	Railways_ER ISTS	26	0	0.1	0.1	0.0	10	0.00
NER	Arunachal Pradesh	172	0	3.0	3.2	-0.5	7	0.00
	Assam	1940	0	37.4	29.9	0.5	136	0.00
	Manipur	219	0	3.1	3.2	0.0	36	0.00
	Meghalaya	308	0	5.6	4.5	-0.1	38	0.00
	Mizoram	125	0	1.9	0.8	-0.4	14	0.00
	Nagaland	161	0	2.9	2.5	0.0	12	0.00
	Tripura	319	0	5.9	6.4	0.1	53	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	14.6	23.2	-24.5	-30.6
Day Peak (MW)	695.8	1056.6	-1055.2	-1476.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	184.9	-208.1	72.1	-58.2	9.3	0.0
Actual(MU)	176.9	-197.6	67.9	-64.7	6.8	-10.7
O/D/U/D(MU)	-8.0	10.4	-4.2	-6.6	-2.5	-10.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6657	12306	9948	2370	265	31545	44
State Sector	9794	17109	10633	2467	205	40208	56
Total	16451	29415	20581	4837	470	71753	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	636	1224	484	627	11	2983	68
Lignite	27	14	38	0	0	80	2
Hydro	165	39	155	63	26	448	10
Nuclear	36	65	63	0	0	164	4
Gas, Naptha & Diesel	3	11	5	0	21	40	1
RES (Wind, Solar, Biomass & Others)	218	227	202	5	1	654	15
Total	1086	1580	948	695	59	4369	100

Share of RES in total generation (%)	20.12	14.37	21.34	0.68	1.69	14.96
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	38.67	20.92	44.36	9.77	45.83	28.98

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.003
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	178778	10:52	0
Non-Solar hr	185956	18:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 27-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	7.4	-7.4
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.3	-2.3
3	765 kV	GAYA-VARANASI	2	593	764	0.0	3.9	-3.9
4	765 kV	SASARAM-FATEHPUR	1	227	385	0.0	1.4	-1.4
5	765 kV	GAYA-BALIA	1	0	620	0.0	9.3	-9.3
6	400 kV	PUSAULI-VARANASI	1	0	105	0.0	2.0	-2.0
7	400 kV	PUSAULI -ALLAHABAD	1	9	35	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	190	541	0.0	5.0	-5.0
9	400 kV	PATNA-BALIA	2	257	553	0.0	3.2	-3.2
10	400 kV	NAUBATPUR-BALIA	2	83	265	0.0	0.0	0.0
11	400 kV	BIHARSHARIFF-BALIA	2	433	0	5.2	0.0	5.2
12	400 kV	MOTIHARI-GORAKHPUR	2	90	408	0.0	3.8	-3.8
13	400 kV	BIHARSARIFE SAHUPURI	2	212	281	0.0	0.6	-0.6
14	220 kV	SAHUPURI-KARAMNASA	1	0	61	0.0	1.8	-1.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.8	40.8	-35.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	884	0	9.1	0.0	9.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1688	29	21.4	0.0	21.4
3	765 kV	JHARSUGUDA-DURG	2	181	509	0.0	6.2	-6.2
4	400 kV	JHARSUGUDA-RAIGARH	4	505	89	4.1	0.0	4.1
5	400 kV	RANCHI-SIPAT	2	427	45	4.7	0.0	4.7
6	400 kV	JEYPORE-JAGDALPUR	2	391	159	1.8	0.0	1.8
7	220 kV	BUDHIPADAR-RAIGARH	1	68	117	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	182	53	0.8	0.0	0.8
ER-WR						41.9	7.3	34.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	318	0.0	7.6	-7.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1235	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2462	0.0	37.7	-37.7
4	400 kV	TALCHER-I/C	2	213	385	0.1	0.0	0.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	74.2	-74.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	486	0.0	7.9	-7.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	753	0.0	12.1	-12.1
3	220 kV	ALIPURDUAR-SALAKATI	2	0	132	0.0	2.2	-2.2
ER-NER						0.0	22.2	-22.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	603	0.0	14.6	-14.6
NER-NR						0.0	14.6	-14.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1006	0.0	24.1	-24.1
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	400	0.0	9.8	-9.8
4	765 kV	GWALIOR-AGRA	2	0	1696	0.0	26.7	-26.7
5	765 kV	GWALIOR-PHAGI	2	411	1600	1.4	19.6	-18.2
6	765 kV	JABALPUR-ORAI	2	0	925	0.0	30.1	-30.1
7	765 kV	GWALIOR-ORAI	1	649	0	10.9	0.0	10.9
8	765 kV	SATNA-ORAI	1	0	989	0.0	17.5	-17.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1276	709	12.0	1.1	11.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2134	0.0	41.9	-41.9
11	400 kV	ZERDA-KANKROLI	1	304	0	4.4	0.0	4.4
12	400 kV	ZERDA -BHINMAL	1	209	0	3.1	0.0	3.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	524	305	3.3	2.4	0.9
15	400 kV	NEEMUCH-Chittorgarh	2	651	329	3.9	2.5	1.4
16	220 kV	BHANPURA-RANPUR	1	0	117	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	66	13	0.4	0.0	0.4
19	220 kV	MALANPUR-AURAIYA	1	42	22	0.1	0.1	0.0
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						44.3	179.0	-134.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	497	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1003	0.0	24.2	-24.2
3	765 kV	SOLAPUR-RAICHUR	2	1979	355	16.1	0.4	15.7
4	765 kV	WARDHA-NIZAMABAD	2	629	1661	2.0	17.5	-15.5
5	765 kV	WARORA-WARANGAL(NEW)	2	506	1891	1.5	20.9	-19.5
6	400 kV	KOLHAPUR-KUDGI	2	1776	0	25.4	0.0	25.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	0.0	2.0	-2.0
WR-SR						47.1	75.1	-28.0
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	497	416	455	10.92		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	289	217	249	5.98		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-91	-53	-68	-1.64		
	NER	132kV GELEPHU-SALAKATI	-18	0	-10	-0.25		
	NER	132kV MOTANGA-RANGIA	-31	0	-18	-0.42		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-52	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	37	0	15	0.35		
	ER	NEPAL IMPORT (FROM BIHAR)	194	147	170	4.09		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	815	752	783	18.80		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-963	-934	-944	-22.65		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1476	1027	-1274	-30.58		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-90	0	-78	-1.86		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 27-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.32	0.16	0.00	0.00	0.00	0.00	0.00	0.00	23.48
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.32	0.16	0.00	0.00	0.00	0.00	0.00	0.00	23.48

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.54	0.00	0.12	0.00	0.00	0.00	0.00	0.00	2.66	
Nepal	9.14	4.77	5.01	0.00	0.00	0.00	3.69	0.00	0.00	22.61
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	11.68	4.77	5.13	0.00	0.00	0.00	3.69	0.00	0.00	25.27

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.54	0.00	0.12	0.00	0.00	0.00	0.00	0.00	2.66	
Nepal	9.14	4.77	5.01	0.00	0.00	0.00	3.69	0.00	0.00	22.61
Bangladesh	-23.32	-0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.48
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.64	4.61	5.13	0.00	0.00	0.00	3.69	0.00	0.00	1.79

