



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 22.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 21.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 21-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 21.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 22-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	48698	49880	39161	27296	3283	168318
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1085	1208	927	582	61	3862
Hydro Gen (MU)	195	34	146	70	27	472
Wind Gen (MU)	10	78	46	-	-	134
Solar Gen (MU)*	172.63	134.06	72.68	3.55	1.12	384
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	50534	54588	46432	27739	3440	176506
Time Of Maximum Demand Met	18:31	10:13	09:59	18:40	17:42	10:47

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.25	5.37	5.62	76.85	17.52

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6699	0	129.7	61.5	-0.5	268	0.00
	Haryana	6702	0	137.4	114.1	-0.2	295	0.00
	Rajasthan	11283	0	227.7	62.5	-1.4	1016	0.00
	Delhi	3789	0	81.6	79.4	-0.3	139	0.00
	UP	19077	0	399.5	150.6	0.2	398	0.00
	Uttarakhand	1737	0	30.0	15.4	-0.7	107	0.00
	HP	1141	0	20.4	0.7	-0.5	170	0.00
	J&K(UT) & Ladakh(UT)	2520	0	50.8	42.9	-2.1	142	0.00
	Chandigarh	194	0	3.5	3.5	0.1	15	0.00
	Railways_NR ISTS	226	0	4.6	4.0	0.7	56	0.00
WR	Chhattisgarh	4350	0	92.9	48.1	1.0	447	0.00
	Gujarat	15075	0	310.6	170.9	2.6	1361	0.00
	MP	12083	0	238.0	142.6	-0.3	2919	0.00
	Maharashtra	22197	0	497.2	164.8	1.7	910	0.00
	Goa	712	0	13.9	11.6	1.8	21	0.00
	DNHDDPDCL	804	0	17.6	17.9	-0.3	56	0.00
	AMNSIL	836	0	18.9	11.8	0.3	310	0.00
	BALCO	535	0	12.8	12.8	0.0	532	0.00
	RIL JAMNAGAR	257	0	5.6	6.1	-0.5	0	0.00
	Andhra Pradesh	8547	0	185.7	49.1	-0.6	477	0.00
SR	Telangana	11660	0	219.0	99.1	-0.1	768	0.00
	Karnataka	11173	0	204.4	54.6	-0.7	681	0.00
	Kerala	4329	0	84.7	48.4	-0.6	247	0.00
	Tamil Nadu	11627	0	226.1	134.9	-2.0	1749	0.00
	Puducherry	352	0	7.1	6.8	-0.3	43	0.00
	Bihar	6911	0	141.3	133.7	2.5	459	0.00
ER	DVC	3246	0	67.5	-26.5	0.6	379	0.00
	Jharkhand	2143	0	42.5	31.5	-1.2	161	0.00
	Odisha	6149	0	120.1	45.7	-1.5	311	0.00
	West Bengal	9917	0	209.7	80.4	-2.0	351	0.00
	Sikkim	53	0	0.7	0.9	-0.2	7	0.00
	Railways_ER ISTS	19	0	0.2	0.1	0.0	0	0.00
NER	Arunachal Pradesh	169	0	3.1	3.0	-0.2	17	0.00
	Assam	2055	0	37.5	29.8	0.3	105	0.00
	Manipur	211	0	3.2	3.1	0.1	25	0.00
	Meghalaya	339	0	5.5	3.9	-0.2	32	0.00
	Mizoram	132	0	2.0	0.8	-0.2	15	0.00
	Nagaland	183	0	3.1	2.9	0.0	18	0.00
	Tripura	344	0	6.6	6.7	0.2	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	20.4	25.6	-25.6	30.4
Day Peak (MW)	1042.8	1192.3	-1091.5	1487.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	121.5	-175.0	117.3	-71.3	7.5	0.0
Actual(MU)	123.9	-167.1	109.5	-79.4	5.4	-7.7
O/D/U/D(MU)	2.4	7.9	-7.7	-8.1	-2.1	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6977	14404	9108	2410	265	33163	41
State Sector	11834	21679	9763	3477	179	46932	59
Total	18811	36083	18871	5887	444	80095	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	588	1123	493	643	10	2857	69
Lignite	29	15	40	0	0	85	2
Hydro	195	34	146	70	27	472	11
Nuclear	31	65	65	0	0	160	4
Gas, Naptha & Diesel	3	9	5	0	22	38	1
RES (Wind, Solar, Biomass & Others)	190	214	135	6	1	547	13
Total	1036	1460	884	719	60	4159	100

Share of RES in total generation (%)	18.37	14.64	15.33	0.87	1.87	13.15
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	40.20	21.40	39.18	10.56	47.08	28.36

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.035
Based on State Max Demands	1.075

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	176506	10:47	0
Non-Solar hr	174188	18:33	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 22-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	347	0.0	7.1	-7.1
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	775	948	0.0	3.0	-3.0
4	765 kV	SASARAM-FATEHPUR	1	358	362	0.6	0.0	0.6
5	765 kV	GAYA-BALIA	1	0	579	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	124	0.0	2.3	-2.3
7	400 kV	PUSAULI -ALLAHABAD	1	26	44	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	230	762	0.0	6.1	-6.1
9	400 kV	PATNA-BALIA	2	176	648	0.0	6.1	-6.1
10	400 kV	NAUBATPUR-BALIA	2	44	320	0.0	1.1	-1.1
11	400 kV	BIHARSARIEF-BALIA	2	450	118	4.0	0.0	4.0
12	400 kV	MOTIHARI-CORAKHPUR	2	92	498	0.0	4.6	-4.6
13	400 kV	BIHARSARIEF- SAHUPURI	2	327	293	0.1	0.0	0.1
14	220 kV	SAHUPURI-KARAMNESA	1	0	50	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.3	42.0	-36.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1290	473	3.2	0.0	3.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1440	230	21.1	0.0	21.1
3	765 kV	JHARSUGUDA-DURG	2	81	679	0.0	8.7	-8.7
4	400 kV	JHARSUGUDA-RAIGARH	4	460	282	2.5	0.0	2.5
5	400 kV	RANCHI-SIPAT	2	333	160	3.5	0.0	3.5
6	400 kV	JEYPORE-JAGDALPUR	2	259	244	0.0	0.4	-0.4
7	220 kV	BUDHIPADAR-RAIGARH	1	73	113	0.0	0.4	-0.4
8	220 kV	BUDHIPADAR-KORBA	2	199	83	1.1	0.0	1.1
ER-WR						31.3	9.5	21.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	337	0.0	7.2	-7.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1472	0.0	34.3	-34.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2618	0.0	43.3	-43.3
4	400 kV	TALCHER-I/C	2	732	879	0.0	1.5	-1.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	84.7	-84.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	404	0.0	5.4	-5.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	656	0.0	8.6	-8.6
3	220 kV	ALIPURDUAR-SALAKATI	2	0	129	0.0	1.6	-1.6
ER-NER						0.0	15.7	-15.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	403	0.0	9.6	-9.6
NER-NR						0.0	9.6	-9.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1996	0.0	34.5	-34.5
2	HVDC	VINDHYACHAL B/B	-	489	0	12.2	0.0	12.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	499	0.0	11.7	-11.7
4	765 kV	GWALIOR-AGRA	2	319	1616	0.4	18.1	-17.7
5	765 kV	GWALIOR-PHAGI	2	1159	1627	6.2	19.9	-13.7
6	765 kV	JABALPUR-ORAI	2	196	793	0.0	18.5	-18.5
7	765 kV	GWALIOR-ORAI	1	867	72	13.1	0.1	13.0
8	765 kV	SATNA-ORAI	1	0	721	0.0	12.0	-12.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1897	382	21.4	0.4	21.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2117	0.0	33.5	-33.5
11	400 kV	ZERDA-KANKROLI	1	369	0	5.5	0.0	5.5
12	400 kV	ZERDA -BHINMAL	1	255	0	3.8	0.0	3.8
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	688	305	4.7	2.2	2.5
15	400 kV	NEEMUCH-Chittorgarh	2	692	406	4.7	3.4	1.3
16	220 kV	BHANPURA-RANPUR	1	0	53	0.0	0.7	-0.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	68	4	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	47	16	0.3	0.0	0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						72.8	156.5	-83.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	6.7	-6.7
2	HVDC	RAIGARH-PUGALUR	2	0	1502	0.0	22.4	-22.4
3	765 kV	SOLAPUR-RAICHUR	2	1102	832	5.3	3.9	1.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2051	0.0	27.7	-27.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2129	0.0	30.1	-30.1
6	400 kV	KOLHAPUR-KUDGI	2	1344	0	22.4	0.0	22.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	104	1.8	0.0	1.8
WR-SR						29.5	90.7	-61.2
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	647	469	529	12.69		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	466	345	395	9.49		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-91	-24	-52	-1.24		
	NER	132kV GELEPHU-SALAKATI	-43	0	-32	-0.76		
	NER	132kV MOTANGA-RANGIA	19	0	10	0.24		
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	70	0	63	1.52		
	ER	NEPAL IMPORT (FROM BIHAR)	196	154	171	4.11		
BANGLADESH	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	942	752	830	19.93		
	ER	BHERAMARA B/B HVDC (B'DESH)	-988	-961	-978	-23.48		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	1487	963	1266	30.37		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2		0	0	-2.07		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 22-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.12	0.16	0.00	0.00	0.00	0.00	0.00	0.00	24.28
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.12	0.16	0.00	0.00	0.00	0.00	0.00	0.00	24.28

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	6.76	0.00	1.39	0.00	0.00	0.00	0.00	0.00	8.15	
Nepal	9.14	4.77	5.67	0.00	0.00	0.00	4.05	0.00	0.00	23.63
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	15.90	4.77	7.06	0.00	0.00	0.00	4.05	0.00	0.00	31.78

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	6.76	0.00	1.39	0.00	0.00	0.00	0.00	0.00	8.15	
Nepal	9.14	4.77	5.67	0.00	0.00	0.00	4.05	0.00	0.00	23.63
Bangladesh	-24.12	-0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-24.28
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-8.22	4.61	7.06	0.00	0.00	0.00	4.05	0.00	0.00	7.50

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	149938	6052	4734	0	19087	1681	118303	1426	145204	151283	947
0:15	49.91	149410	6046	4535	0	17683	1658	119527	1385	144875	150834	956
0:30	49.96	148157	6062	4440	0	17459	1658	118578	1339	143717	149536	967
0:45	49.91	147328	6044	4199	0	17384	1661	118249	1378	143129	148915	979
1:00	49.96	145969	6051	4078	0	17318	1659	116935	1422	141891	147463	965
1:15	49.86	145404	6053	4039	0	17121	1668	116565	1364	141365	146810	975
1:30	49.91	144687	6048	3931	0	16802	1667	116362	1355	140756	146165	984
1:45	50.01	144179	6046	3678	0	16939	1659	115745	1373	140501	145440	991
2:00	50.01	143497	6052	3500	0	16398	1643	115823	1339	139997	144755	998
2:15	50.01	143143	6052	3330	0	16331	1660	115794	1384	139813	144551	1006
2:30	50.01	142531	6064	3232	0	16291	1649	115312	1381	139299	143929	1033
2:45	50.01	142357	6067	3180	0	16291	1662	115172	1413	139177	143785	986
3:00	49.96	142248	6059	3052	0	16172	1682	115323	1407	139196	143695	1025
3:15	50.01	141504	6059	2868	0	16399	1710	114872	1361	138636	143269	997
3:30	49.96	141629	6078	2748	0	16424	1698	114859	1401	138881	143208	907
3:45	49.96	141182	6076	2720	0	16297	1722	114668	1390	138462	142873	878
4:00	50.06	141038	6070	2666	0	16523	1722	114449	1374	138372	142804	885
4:15	49.96	142460	6055	2615	0	16507	1721	115790	1404	139845	144092	874
4:30	50.01	142325	6060	2574	0	16547	1715	115995	1361	139751	144252	849
4:45	50.01	143008	6063	2578	0	16687	1712	116424	1350	140430	144814	839
5:00	50.01	145364	6077	2662	50	17088	1709	118143	1437	142652	147166	833
5:15	50.01	147193	6074	2828	50	18010	1704	119119	1382	144315	149167	815
5:30	50.01	148799	6066	2995	54	18638	1719	119730	1450	145750	150652	786
5:45	50.01	150728	6083	3082	65	19478	1714	120449	1477	147581	152348	826
6:00	50.11	151582	6072	3228	63	20819	1699	119667	1475	148291	153023	807
6:15	50.01	154610	6080	3485	95	22583	1668	120596	1451	151030	155958	754
6:30	50.06	157009	6061	3558	318	24159	1632	120577	1537	153133	157842	772
6:45	50.06	158775	6076	3646	864	24341	1610	121488	1459	154265	159484	789
7:00	50.06	160290	6072	3746	2165	23813	1618	121830	1504	154379	160748	832
7:15	50.01	162549	6072	3719	4581	23835	1602	121762	1528	154249	163099	772
7:30	50.01	163763	6088	3552	7844	23145	1618	120531	1464	152367	164242	817
7:45	50.01	164236	6073	3540	11849	20423	1609	119993	1507	148847	164994	825
8:00	50.01	164439	6063	3646	16308	19223	1612	116925	1522	144485	165299	793
8:15	49.90	166365	6062	3799	20888	19113	1594	114597	1571	141678	167624	698
8:30	50.00	168492	6075	3842	25793	18957	1552	111729	1654	138857	169602	711
8:45	50.00	169390	6079	3754	30662	18018	1518	108808	1664	134974	170503	691
9:00	50.00	170927	6074	3549	34811	17341	1518	106820	1647	132567	171760	661
9:15	49.95	173610	6063	3308	37797	17243	1454	106775	1722	132505	174362	672
9:30	50.00	174479	6074	3173	41389	16811	1422	104738	1777	129917	175384	665
9:45	50.11	175446	6056	3166	44231	17156	1441	102472	1718	128049	176240	705
10:00	50.01	175803	6079	3267	46673	16967	1436	100340	1762	125863	176524	726
10:15	50.01	175890	6086	3402	48636	15934	1452	99580	1808	123852	176898	718
10:30	49.95	175465	6063	3615	48809	15467	1429	99002	1742	123041	176127	633
10:45	49.96	176139	6040	3816	49800	15473	1438	98590	1748	122523	176905	656
11:00	50.01	175518	6043	3964	51134	15420	1438	96622	1807	120420	176428	662
11:15	50.06	174853	6073	4128	52629	14999	1438	94961	1806	118096	176034	659
11:30	50.01	175210	6061	4259	52490	14597	1434	95159	1770	118461	175770	664
11:45	50.06	175699	6022	4507	53413	14357	1437	94028	1846	117779	175610	649
12:00	50.10	174289	6032	4640	53232	13922	1419	93207	1736	116417	174188	674
12:15	50.00	173789	6065	4796	53316	13671	1446	92759	1805	115677	173858	660
12:30	50.00	173335	6020	4764	52633	13820	1435	93013	1787	115938	173472	634
12:45	50.05	172741	6039	4595	52368	13834	1422	92731	1796	115778	172785	594
13:00	49.95	170480	6047	4707	50920	13865	1428	92600	1733	114853	171300	616
13:15	49.95	169665	6018	4832	48888	14057	1428	93644	1728	115945	170595	639
13:30	50.00	169818	6022	4886	48857	14357	1439	93532	1733	116075	170826	658
13:45	49.95	169223	6036	5148	48328	14283	1432	93084	1783	115747	170094	744
14:00	50.05	168898	6027	5136	48584	14360	1433	92649	1692	115178	169881	667
14:15	49.95	168548	6030	5023	47099	14550	1419	93660	1695	116426	169476	703
14:30	49.95	169262	6016	5027	45879	15168	1427	94901	1737	118356	170155	713
14:45	49.90	169472	6035	5331	44096	15508	1438	96187	1666	120045	170261	741
15:00	50.00	170192	6032	5413	43097	15615	1430	97993	1585	121682	171165	735
15:15	49.95	169110	6033	5537	40420	15526	1432	99349	1602	123153	169899	752
15:30	50.00	168565	6010	5600	36913	16059	1435	102454	1554	126052	170025	746
15:45	49.95	167573	6031	5528	33055	16178	1429	104938	1522	128990	168681	789
16:00	49.90	166162	6031	5750	28977	16058	1424	107878	1524	131435	167642	751
16:15	49.93	163226	6055	5898	24975	16394	1409	108463	1567	132353	164761	779
16:30	49.93	161790	6024	6062	20604	16080	1423	111722	1496	135124	163411	723
16:45	49.93	161445	6040	6133	16016	17289	1420	114798	1448	139296	163144	706
17:00	50.04	162411	6027	6101	11986	18517	1419	115314	1471	144324	160835	720
17:15	50.04	162253	6047	6387	7826	20129	1435	120987	1383	148040	164194	657
17:30	50.04	164696	6052	6558	4559	21054	1350	125516	1387	153579	166476	632
17:45	50.03	168169	6041	6773	2121	22679	1364	129838	1406	159275	170222	677
18:00	50.03	171398	6047	7114	727	24534	1439	132604	1406	163557	173871	647
18:15	50.09	172942	6051	7336	252	25638	1361	133012	1431	165354	175081	649
18:30	50.09	173993	6055	7707	185	26127	1450	133155	1447	166101	176126	656
18:45	50.09	172969	6062	8329	184	26740	1456	130952	1356	164456	175079	682
19:00	50.04	172079	6046	8836	197	27151	1451	129258	1387	163046	174326	641
19:15	49.99	169640	6052	9070	196	27333	1454	126263	1404	160374	171772	668
19:30	50.04	168510	6063	9213	0	26864	1389	125163	1397	159297	170089	668
19:45	50.04	167066	6059	9155	0	26708	1470	123933	1362	157911	168687	687
20:00	50.04	166205	6049	9439	0	26901	1463	122696	1347	156766	167895	688
20:15	50.08	164698	6060	9638	0	26342	1462	121228	1455	155060	166185	673
20:30	50.03	164035	6057	9727	0	24194	1363	122437	1487	154308	165265	693
20:45	50.03	163537	6055	9806	0	23213	1360	122848	1522	153731	164804	708
21:00	50.08	162113	6060	9547	0	22647	1436	122228	1500	152566	163418	686
21:15	50.03	160630	6070	9411	0	21489	1445	121923	1518	151219	161856	692
21:30	50.08	159559	6065	9210	0	21307	1424	121283	1496	150349	160785	730
21:45	50.03	159371	6062	9122	0	21059	1420	121367	1496	150249	160526	714
22:00	50.03	157884	6080	9065	0	21031	1442	119805	1472	148819	158895	737
22:15	50.03	158212	6071	9056	0	20628	1437	120684	1539	149156	159415	729
22:30	50.03	157518	6068	8925	0	20347	1443	120446	1577	148593	158806	747
22:45	50.03	156925	6057	9221	0	19827						