



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 18-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.05.2024.

महोदय/Dear Sir,

आई०ई०जी०सी०-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 17-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 18-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	73248	64897	46635	28377	3148	216305
Peak Shortage (MW)	318	0	0	0	0	318
Energy Met (MU)	1691	1563	1078	654	65	5050
Hydro Gen (MU)	315	46	38	22	16	437
Wind Gen (MU)	21	95	23	-	-	140
Solar Gen (MU)*	165.31	85.49	92.81	2.95	0.99	348
Energy Shortage (MU)	6.09	0.00	0.00	1.88	0.00	7.97
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	75739	70953	50820	30633	3307	225926
Time Of Maximum Demand Met	10:44	15:10	12:30	23:13	18:43	14:59

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.022	0.00	0.00	3.25	3.25	85.95	10.80

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12857	0	256.1	117.0	-0.9	262	0.00
	Haryana	10362	0	228.2	174.0	-5.1	251	0.00
	Rajasthan	15918	0	335.5	127.6	0.9	431	6.03
	Delhi	6944	0	139.7	115.0	-8.9	209	0.00
	UP	26970	0	575.6	255.5	0.5	821	0.00
	Uttarakhand	2579	0	56.3	31.5	-2.5	205	0.00
	HP	1649	0	34.8	0.9	0.2	109	0.00
	J&K(UT) & Ladakh(UT)	2573	0	54.1	29.5	-1.5	105	0.06
	Chandigarh	358	0	6.9	6.8	0.1	40	0.00
WR	Railways_NR ISTS	211	0	4.2	3.6	0.6	86	0.00
	Chhattisgarh	5189	0	116.3	56.2	-0.6	243	0.00
	Gujarat	23520	0	487.4	160.9	-2.1	694	0.00
	MP	13175	0	291.4	157.8	-5.6	503	0.00
	Maharashtra	26342	0	589.9	196.7	-3.6	727	0.00
	Goa	793	0	16.6	14.6	1.6	36	0.00
	DNHDDPDCL	1274	0	29.8	29.6	0.2	67	0.00
	AMNSIL	842	0	18.9	8.8	0.3	272	0.00
	BALCO	522	0	12.5	12.5	0.0	518	0.00
SR	Andhra Pradesh	9992	0	211.0	61.6	-0.1	1077	0.00
	Telangana	8147	0	176.0	52.0	0.8	582	0.00
	Karnataka	12360	0	238.4	123.2	-3.1	928	0.00
	Kerala	4335	0	90.9	75.0	0.3	686	0.00
	Tamil Nadu	16089	0	352.1	225.8	4.4	802	0.00
	Puducherry	439	0	10.0	9.7	-0.4	23	0.00
	Railways_SR ISTS	13	0	0.1	0.1	0.0	4	0.00
ER	Bihar	6991	0	150.6	133.2	5.8	410	1.64
	DVC	3430	0	78.0	-37.1	0.3	236	0.00
	Jharkhand	2175	0	46.5	33.4	-0.6	262	0.24
	Odisha	6268	0	132.1	52.3	-0.1	512	0.00
	West Bengal	12098	0	244.7	101.8	-0.5	267	0.00
	Sikkim	100	0	1.5	1.5	0.0	39	0.00
NER	Railways_ER ISTS	13	0	0.1	0.1	0.0	4	0.00
	Arunachal Pradesh	150	0	2.7	2.8	-0.3	22	0.00
	Assam	2023	0	41.8	34.5	-0.3	175	0.00
	Manipur	220	0	3.2	3.3	-0.2	54	0.00
	Meghalaya	313	0	5.4	3.4	-0.2	71	0.00
	Mizoram	126	0	2.1	1.8	-0.2	14	0.00
	Nagaland	162	0	2.8	3.0	-0.2	26	0.00
	Tripura	358	0	6.8	6.5	0.4	112	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-1.2	-12.8	-23.5	-15.4
Day Peak (MW)	-198.7	-816.0	-1069.0	-767.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	299.3	-369.2	88.8	-33.5	14.6	0.0
Actual(MU)	285.2	-396.5	117.5	-29.9	15.6	-8.1
O/D/U/D(MU)	-14.1	-27.3	28.7	3.6	1.0	-8.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2197	4150	3252	2606	351	12556	42
State Sector	4418	5562	5228	1981	110	17298	58
Total	6615	9712	8480	4587	461	29855	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	885	1691	740	745	13	4075	74
Lignite	20	21	60	0	0	101	2
Hydro	315	46	38	22	16	437	8
Nuclear	26	65	51	0	0	142	3
Gas, Naptha & Diesel	63	106	9	0	24	203	4
RES (Wind, Solar, Biomass & Others)	194	183	143	4	1	524	10
Total	1504	2112	1040	771	55	5481	100
Share of RES in total generation (%)	12.92	8.66	13.70	0.47	1.85	9.57	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.57	13.93	22.21	3.29	31.32	20.12	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.026
Based on State Max Demands	1.055

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	225926	14:59	0
Non-Solar hr	219041	22:30	2519

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 18-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	637	285	1.1	0.0	1.1
4	765 kV	SASARAM-FATEHPUR	1	81	268	0.0	3.0	-3.0
5	765 kV	GAYA-BALIA	1	0	666	0.0	12.2	-12.2
6	400 kV	PUSAULI-VARANASI	1	5	167	0.0	0.9	-0.9
7	400 kV	PUSAULI -ALLAHABAD	1	78	85	0.9	0.0	0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	389	269	1.2	0.0	1.2
9	400 kV	PATNA-BALIA	2	142	598	0.0	7.7	-7.7
10	400 kV	NAUBATPUR-BALIA	2	106	385	0.0	1.7	-1.7
11	400 kV	BIHARSHARIFF-BALIA	2	414	0	4.7	0.0	4.7
12	400 kV	MOTIHARI-GORAKHPUR	2	52	328	0.0	3.5	-3.5
13	400 kV	BIHARSHARIFF-VARANASI	2	9	6	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	25	73	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						8.2	29.9	-21.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1182	98	14.1	0.0	14.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1788	0	27.2	0.0	27.2
3	765 kV	JHARSUGUDA-DURG	2	0	828	0.0	14.1	-14.1
4	400 kV	JHARSUGUDA-RAIGARH	4	52	254	0.0	3.4	-3.4
5	400 kV	RANCHI-SIPAT	2	547	0	9.3	0.0	9.3
6	220 kV	BUDHIPADAR-RAIGARH	1	63	55	0.0	0.2	-0.2
7	220 kV	BUDHIPADAR-KORBA	2	101	40	0.5	0.0	0.5
ER-WR						51.2	17.7	33.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	516	0.0	12.3	-12.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1487	0.0	30.4	-30.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2443	0.0	41.1	-41.1
4	400 kV	TALCHER-I/C	2	641	0	12.0	0.0	12.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	83.8	-83.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	207	131	0.7	1.0	-0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	400	191	0.2	0.0	0.2
3	220 kV	ALIPURDUAR-SALAKATI	2	86	39	0.1	0.0	0.1
ER-NER						1.0	1.0	0.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	654	0	15.3	0.0	15.3
NER-NR						15.3	0.0	15.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5027	0.0	92.3	-92.3
2	HVDC	VINDHYACHAL B/B	-	246	28	0.9	1.1	-0.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1440	0.0	32.1	-32.1
4	765 kV	GWALIOR-AGRA	2	0	2309	0.0	41.3	-41.3
5	765 kV	GWALIOR-PHAGI	2	284	1435	0.4	16.3	-15.9
6	765 kV	JABALPUR-ORAI	2	0	1025	0.0	34.3	-34.3
7	765 kV	GWALIOR-ORAI	1	652	0	10.5	0.0	10.5
8	765 kV	SATNA-ORAI	1	0	1100	0.0	22.3	-22.3
9	765 kV	BANASKANTHA-CHITORGARH	2	852	1049	4.8	8.3	-3.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3505	0.0	72.5	-72.5
11	400 kV	ZERDA-KANKROLI	1	222	152	1.4	0.9	0.5
12	400 kV	ZERDA -BHINMAL	1	221	151	1.4	0.8	0.6
13	400 kV	VINDHYACHAL -RIHAND	1	963	0	22.4	0.0	22.4
14	400 kV	RAPP-SHUJALPUR	2	389	333	1.6	3.0	-1.3
15	400 kV	NEEMUCH-Chittorgarh	2	414	371	2.0	2.9	-0.9
16	220 kV	BHANPURA-RANPUR	1	0	133	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	69	1	0.5	0.0	0.5
19	220 kV	MALANPUR-AURAIYA	1	44	7	0.5	0.0	0.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						46.3	333.1	-286.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	1501	0.0	31.2	-31.2
3	765 kV	SOLAPUR-RAICHUR	2	369	1260	0.8	9.1	-8.3
4	765 kV	WARDHA-NIZAMABAD	2	0	1674	0.0	22.2	-22.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2080	0.0	28.8	-28.8
6	400 kV	KOLHAPUR-KUDGI	2	1062	0	15.1	0.0	15.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	85	1.7	0.0	1.7
9	220 kV	XELDEM-AMBEWADI	1	0	132	2.4	0.0	2.4
WR-SR						20.0	98.4	-78.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	336	41	131	3.14
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-171	60	-54	-1.29
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-250	-89	-141	-3.38
	NER	132kV GELEPHU-SALAKATI	-61	5	-10	-0.23
	NER	132kV MOTANGA-RANGIA	40	4	24	0.57
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	-25	-0.59
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-52	-1.26
	ER	NEPAL IMPORT (FROM BIHAR)	-315	-17	-154	-3.70
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-501	-26	-303	-7.27
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-947	-651	-872	-20.92
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	44	-643	-15.43
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-122	0	-108	-2.58

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	3.22	0.00	0.00	0.00	0.00	0.00	3.22	
Nepal	0.35	0.00	5.47	0.00	0.00	0.00	0.09	0.00	0.00	5.91
Bangladesh	20.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.97	0.00	8.69	0.00	0.00	0.00	0.09	0.00	0.00	29.75

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	0.00	-3.22	0.00	0.00	0.00	0.00	0.00	-1.86
Nepal	-0.35	0.00	-5.47	0.00	0.00	-0.09	0.00	0.00	-5.91
Bangladesh	-20.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.61	0.00	-8.69	0.00	0.00	-0.09	0.00	0.00	-28.39