



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 04.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 3-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 04-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	62400	63568	51026	25570	3076	205640
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1372	1629	1206	555	56	4818
Hydro Gen (MU)	230	27	76	28	16	377
Wind Gen (MU)	19	182	94	-	-	295
Solar Gen (MU)*	192.68	149.16	140.44	3.77	1.24	487
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	63903	72349	57363	25861	3078	214714
Time Of Maximum Demand Met	22:26	11:47	15:38	00:08	18:51	14:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.00	2.13	2.13	81.76	16.11

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8561	0	188.2	92.6	-2.2	490	0.00
	Haryana	8365	0	177.4	127.9	-0.7	771	0.00
	Rajasthan	14826	0	293.5	113.6	-7.5	686	0.00
	Delhi	4678	0	99.7	93.7	-3.1	83	0.00
	UP	24797	0	469.8	173.7	-1.5	768	0.00
	Uttarakhand	2249	0	47.8	31.5	0.6	148	0.00
	HP	1743	0	34.4	8.4	-0.9	116	0.00
	J&K(UT) & Ladakh(UT)	2537	0	51.5	48.1	-0.5	544	0.00
	Chandigarh	262	0	5.2	5.3	0.0	13	0.00
WR	Railways_NR ISTS	197	0	4.2	3.9	0.3	33	0.00
	Chhattisgarh	5359	0	102.8	51.8	-3.5	451	0.00
	Gujarat	25449	0	507.3	175.0	-2.0	1193	0.00
	MP	13882	0	281.2	167.5	-6.5	528	0.00
	Maharashtra	28511	0	657.9	245.7	-1.5	771	0.00
	Goa	816	0	18.0	17.6	0.3	122	0.00
	DNHDDPDCL	1307	0	30.4	30.3	0.1	45	0.00
	AMNSIL	809	0	17.0	8.0	0.3	303	0.00
	BALCO	532	0	12.6	12.7	-0.1	7	0.00
SR	RIL JAMNAGAR	159	0	1.8	1.8	0.0	0	0.00
	Andhra Pradesh	11654	0	227.5	70.5	-0.9	1513	0.00
	Telangana	10716	0	211.6	90.7	-1.8	434	0.00
	Karnataka	12693	0	250.7	78.1	-0.9	1166	0.00
	Kerala	4841	0	93.1	67.7	-0.5	406	0.00
	Tamil Nadu	19143	0	411.7	256.0	-2.6	590	0.00
	Puducherry	545	0	11.3	11.4	-0.2	40	0.00
ER	Bihar	7341	0	128.6	132.6	-10.4	201	0.00
	DVC	3078	0	65.5	-35.5	0.3	374	0.00
	Jharkhand	1927	0	41.4	33.6	-0.1	255	0.00
	Odisha	5733	0	109.4	29.8	-4.4	418	0.00
	West Bengal	9705	0	208.0	70.8	-1.7	183	0.00
	Sikkim	109	0	1.9	1.3	0.5	53	0.00
NER	Railways_ER ISTS	19	0	0.2	0.2	0.1	5	0.00
	Arunachal Pradesh	170	0	3.0	3.0	-0.1	24	0.00
	Assam	1915	0	34.8	27.5	0.1	107	0.00
	Manipur	222	0	3.1	3.0	0.0	41	0.00
	Meghalaya	332	0	5.6	2.6	-0.2	47	0.00
	Mizoram	123	0	1.9	1.8	-0.3	9	0.00
	Nagaland	162	0	2.4	2.5	-0.3	6	0.00
	Tripura	283	0	5.3	4.4	0.2	63	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.1	-11.4	-22.9	-23.9
Day Peak (MW)	505.0	235.8	-983.0	-1380.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	190.5	-277.2	165.0	-89.3	11.0	0.0
Actual(MU)	165.8	-253.1	161.1	-91.2	8.1	-9.3
O/D/U/D(MU)	-24.8	24.1	-3.9	-1.9	-2.9	-9.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4773	8339	5028	2020	351	20511	46
State Sector	7239	7210	7506	2219	200	24374	54
Total	12012	15549	12534	4239	551	44885	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	774	1539	646	710	12	3681	71
Lignite	24	13	36	0	0	74	1
Hydro	230	27	76	28	16	377	7
Nuclear	31	65	71	0	0	167	3
Gas, Naptha & Diesel	13	53	6	0	23	94	2
RES (Wind, Solar, Biomass & Others)	222	332	265	5	1	826	16
Total	1295	2029	1100	743	52	5219	100

Share of RES in total generation (%)	17.15	16.38	24.14	0.65	2.36	15.83
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.32	20.93	37.50	4.41	32.42	26.25

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.036
Based on State Max Demands	1.097

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	214714	14:56	0
Non-Solar hr	207814	22:56	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 04-May-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	912	999	0.0	6.0	-6.0
4	765 kV	SASARAM-FATEHPUR	1	389	426	0.0	2.5	-2.5
5	765 kV	GAYA-BALIA	1	40	678	0.0	8.3	-8.3
6	400 kV	PUSAULI-VARANASI	1	0	148	0.0	2.1	-2.1
7	400 kV	PUSAULI -ALLAHABAD	1	53	59	0.0	0.4	-0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	624	446	0.0	1.0	-1.0
9	400 kV	PATNA-BALIA	2	351	754	0.0	8.6	-8.6
10	400 kV	NAUBATPUR-BALIA	2	166	232	0.0	1.9	-1.9
11	400 kV	BIHARSHARIFF-BALIA	2	653	72	5.3	0.0	5.3
12	400 kV	MOTIHARI-GORAKHPUR	2	348	448	0.0	4.2	-4.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	181	169	0.0	1.7	-1.7
14	220 kV	SAHUPURI-KARAMNASA	1	9	55	0.5	0.0	0.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.0	0.0	0.0
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.7	39.2	-33.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	651	936	0.0	2.9	-2.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1396	243	13.0	0.0	13.0
3	765 kV	JHARSUGUDA-DURG	2	0	716	0.0	12.2	-12.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	664	0.0	8.3	-8.3
5	400 kV	RANCHI-SIPAT	2	340	156	0.0	1.4	-1.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	104	0.0	1.5	-1.5
7	220 kV	BUDHIPADAR-KORBA	2	124	81	0.1	0.0	0.1
ER-WR						13.0	26.2	-13.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	207	208	0.0	1.7	-1.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1763	0.0	40.3	-40.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2925	0.0	50.0	-50.0
4	400 kV	TALCHER-I/C	2	305	549	1.2	0.0	1.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	92.0	-92.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	247	157	1.2	0.0	1.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	392	225	1.7	0.0	1.7
3	220 kV	ALIPURDUAR-SALAKATI	2	85	25	0.7	0.0	0.7
ER-NER						3.5	0.0	3.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	471	0	11.2	0.0	11.2
NER-NR						11.2	0.0	11.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1025	0.0	23.8	-23.8
2	HVDC	VINDHYACHAL B/B	-	0	105	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	980	0.0	24.0	-24.0
4	765 kV	GWALIOR-AGRA	2	0	2300	0.0	26.7	-26.7
5	765 kV	GWALIOR-PHAGI	2	742	1655	2.8	16.7	-14.0
6	765 kV	JABALPUR-ORAI	2	59	939	0.0	23.3	-23.3
7	765 kV	GWALIOR-ORAI	1	738	0	10.6	0.0	10.6
8	765 kV	SATNA-ORAI	1	0	1059	0.0	18.3	-18.3
9	765 kV	BANASKANTHA-CHITORGARH	2	606	1338	1.3	9.3	-8.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2462	0.0	41.0	-41.0
11	400 kV	ZERDA-KANKROLI	1	167	205	1.0	0.8	0.2
12	400 kV	ZERDA -BHINMAL	1	116	142	0.7	0.6	0.1
13	400 kV	VINDHYACHAL -RIHAND	1	966	0	20.4	0.0	20.4
14	400 kV	RAPP-SHUJALPUR	2	485	345	3.3	2.4	0.9
15	400 kV	NEEMUCH-Chittorgarh	2	468	235	2.9	1.9	1.0
16	220 kV	BHANPURA-RANPUR	1	0	157	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	72	13	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	50	28	0.4	0.0	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						43.9	196.2	-152.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	514	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	5012	0.0	82.4	-82.4
3	765 kV	SOLAPUR-RAICHUR	2	1490	1196	10.3	4.1	6.2
4	765 kV	WARDHA-NIZAMABAD	2	0	2273	0.0	26.4	-26.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2598	0.0	31.0	-31.0
6	400 kV	KOLHAPUR-KUDGI	2	1861	0	29.4	0.0	29.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	127	2.7	0.0	2.7
WR-SR						42.4	155.8	-113.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	449	163	287	6.89	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	143	-67	-2	-0.04	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-143	-101	-120	-2.89	
	NER	132kV GELEPHU-SALAKATI	19	0	-7	-0.17	
	NER	132kV MOTANGA-RANGIA	20	0	13	0.30	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-72	0	-35	-0.83	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-72	0	-50	-1.19	
	ER	NEPAL IMPORT (FROM BIHAR)	-219	0	-124	-2.98	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	455	14	-267	-6.41	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-943	-886	-930	-22.32	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1380	-807	-995	-23.89	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-40	0	-26	-0.62	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	2.99	0.00	3.91	0.00	0.00	2.72	0.00	0.00	9.62
Bangladesh	23.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.14	0.00	3.91	0.00	0.00	2.72	0.00	0.00	32.77

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	4.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.56
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	4.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.56

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	4.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.56
Nepal	-2.99	0.00	-3.91	0.00	0.00	-2.72	0.00	0.00	-9.62
Bangladesh	-23.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.58	0.00	-3.91	0.00	0.00	-2.72	0.00	0.00	-28.21

Date of Reporting: 04-May-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	50.06	206461	6351	14107	81	19064	5125	163014	1683	192273	209425	-1039
0:15	50.01	205046	6356	14310	88	18234	4964	162143	1773	190648	207868	-933
0:30	50.01	203656	6350	14258	85	18502	4863	160489	1725	189313	206272	-922
0:45	50.01	201557	6359	13957	90	18113	4813	159147	1680	187510	204159	-926
1:00	49.96	199570	6368	13743	58	17947	4791	157755	1703	185769	202365	-911
1:15	49.96	197974	6325	13506	59	16850	4747	157545	1698	184409	200730	-850
1:30	49.96	196537	6338	12901	69	16408	4726	157192	1749	183567	199383	-841
1:45	49.96	195328	6356	12482	98	15997	4699	157022	1727	182748	198381	-901
2:00	50.01	193864	6343	12058	108	15438	4698	156800	1719	181698	197164	-916
2:15	50.01	192847	6338	12141	100	14913	4691	156218	1781	180606	196182	-1123
2:30	50.01	192173	6341	12178	104	14631	4704	156057	1718	179891	195733	-1182
2:45	50.01	190963	6368	12184	40	14242	4697	155125	1707	178739	194363	-1095
3:00	50.01	189263	6366	11896	99	14153	4602	154114	1694	177268	192924	-1127
3:15	50.01	188704	6351	11476	80	13951	4558	153910	1765	177148	192091	-1143
3:30	50.06	187724	6339	11340	66	13701	4436	153407	1705	176318	190994	-1124
3:45	50.01	186884	6372	11197	62	13513	4431	153041	1702	175625	190318	-1144
4:00	50.06	185890	6344	11606	82	13308	4440	151989	1772	174202	189541	-1167
4:15	49.96	185699	6300	11809	73	13001	3825	152607	1746	173817	189361	-1154
4:30	50.01	185667	6376	12295	110	12746	3691	152645	1711	173262	189574	-1168
4:45	49.96	186436	6344	12340	42	12776	3600	153331	1700	174054	190133	-1087
5:00	50.06	185902	6354	12446	93	12879	3524	152851	1768	173363	189915	-1142
5:15	50.01	187071	6286	12555	108	12933	3447	153627	1724	174408	190680	-1104
5:30	50.01	187903	6312	12527	83	12966	3329	154862	1720	175293	191799	-1100
5:45	50.01	188331	6314	12366	136	13276	3199	155026	1755	175829	192072	-1054
6:00	50.06	188419	6360	12059	167	13322	3215	155180	1729	176193	192032	-1076
6:15	50.01	188977	6354	11938	1038	13281	3215	155122	1705	176001	192653	-1089
6:30	50.06	188674	6385	11817	2325	13472	3211	153300	1705	174532	192215	-1086
6:45	49.96	187710	6360	11719	4264	14017	3167	150330	1777	171727	191634	-1113
7:00	49.96	186953	6360	11615	6690	13750	3150	146969	1771	168648	190305	-1107
7:15	49.96	187102	6375	11209	9367	13098	3189	145174	1845	166526	190257	-1032
7:30	50.01	186727	6392	10698	12702	12981	3178	141839	1804	163327	189594	-1045
7:45	49.96	186461	6372	10218	16195	12921	3143	138576	1815	160048	189240	-1139
8:00	49.96	186854	6379	9758	20156	12729	3061	135784	1818	156940	189685	-1087
8:15	49.91	189672	6352	9449	24288	12601	2977	134963	1880	155935	192510	-1144
8:30	50.01	191470	6365	9388	28172	12593	2977	132486	1916	153910	193897	-1144
8:45	49.96	194080	6358	9301	31996	12756	2976	130962	1908	152783	196257	-1154
9:00	50.01	195997	6352	8218	35760	12987	2977	130310	1920	152019	198524	-1161
9:15	49.96	200239	6318	8040	39482	12358	2969	131492	1951	152717	202610	-1171
9:30	50.01	203651	6351	7469	43386	12085	2989	131300	1971	152796	205551	-1183
9:45	50.06	205714	6358	7278	46907	11885	2956	130182	2004	151529	207570	-1168
10:00	50.06	206038	6348	7064	49608	11825	2972	128665	1997	149366	208479	-1237
10:15	50.06	206204	6355	6874	52017	10702	2983	128068	1979	147313	208978	-1223
10:30	50.06	207420	6349	6616	54308	10314	2981	127661	2019	146496	210248	-1246
10:45	50.01	207915	6340	6311	56352	10442	2982	126249	2012	145252	210688	-1251
11:00	50.06	207831	6382	6137	58055	10777	2986	124943	2035	143639	211315	-1242
11:15	49.96	208217	6343	6035	59292	11042	2988	124290	2024	142890	212014	-1230
11:30	49.96	208812	6333	5945	60110	11187	2995	124335	1984	142757	212889	-1228
11:45	50.01	209862	6335	6120	61250	10915	2985	124255	2031	142492	213891	-1316
12:00	50.01	208862	6350	6289	61139	10821	2973	123254	2018	141434	212844	-1342
12:15	50.01	209101	6329	6623	61842	10809	2992	122549	2018	140636	213162	-1430
12:30	50.01	209311	6152	6987	61665	11045	3009	122432	2087	140659	213377	-1404
12:45	50.01	209917	6132	7335	61814	11081	2988	122202	2027	140768	213579	-1422
13:00	50.16	208893	6139	7629	61837	10759	2988	120866	2026	139427	212244	-1420
13:15	49.96	206903	6121	8071	61214	10000	2979	120011	1987	137618	210383	-1542
13:30	50.01	207626	6132	8318	60471	10472	2988	120923	1981	138837	211285	-1477
13:45	49.96	209204	6121	8541	59965	10470	2975	122992	1981	140698	213045	-1523
14:00	50.06	210025	6119	8821	58890	10630	2960	124214	1975	142314	213609	-1493
14:15	50.01	210638	6134	9281	56827	10697	2984	126334	1989	144530	214246	-1460
14:30	50.11	212925	6096	9725	55820	11421	2974	128793	1913	147380	216742	-1506
14:45	50.11	213592	6145	10062	53667	11063	2941	131308	1904	149863	217090	-1503
15:00	50.06	214208	6106	10395	51369	11698	2989	133635	1921	152444	218113	-1498
15:15	50.01	212954	6123	10783	48652	11798	3029	134613	1913	153519	216911	-1472
15:30	49.91	212841	6130	11037	45468	12409	3066	136451	1909	156336	216470	-1493
15:45	50.01	211023	6089	11625	42772	13251	3060	136297	1850	156626	214944	-1460
16:00	50.06	207852	6126	12288	39952	13145	3054	135787	1794	155612	212146	-1458
16:15	50.01	206705	6081	12830	37134	13384	3080	136522	1821	156741	210852	-1426
16:30	49.96	206606	6136	13226	33104	14152	3120	138871	1825	160276	210434	-1395
16:45	50.01	204670	6121	13688	29518	14719	3400	139253	1850	161464	208549	-1370
17:00	50.01	202722	6147	14025	25821	15171	3952	139863	1799	162876	206778	-1334
17:15	50.01	199581	6121	14336	21329	15350	4453	140181	1750	163916	203520	-1049
17:30	50.01	197944	6087	14652	17138	15856	4504	142089	1716	166154	202042	-1030
17:45	50.06	196215	6017	14835	13340	16368	4561	143190	1713	168040	200024	-1070
18:00	50.06	193541	6008	15325	9818	16961	4590	142846	1699	168398	197247	-1087
18:15	50.01	190814	5945	15455	6992	17577	4694	142336	1654	168367	194653	-982
18:30	50.01	192585	5902	15438	4677	18828	4636	144844	1630	172470	195955	-955
18:45	50.01	196103	6107	15483	2899	20620	4874	147948	1662	177721	199593	-997
19:00	50.01	198697	6100	15409	1428	22190	4875	150353	1666	181860	202021	-904
19:15	50.01	202843	6084	15353	544	23410	4893	154040	1639	186946	205963	-924
19:30	49.96	205032	6110	15444	345	23683	4920	155957	1695	189243	208154	-914
19:45	50.01	205847	6073	15642	368	23580	4795	156646	1671	189837	208775	-913
20:00	50.06	204947	6138	16058	437	22866	4793	155971	1670	188452	207933	-932
20:15	50.01	204472	6133	16329	230	22034	4783	156032	1668	187913	207209	-1022
20:30	50.01	204079	6127	16491	213	21183	4752	156304	1752	187375	206822	-1001
20:45	49.96	203239	6141	16748	212	20181	4741	156319	1706	186279	206048	-1018
21:00	50.01	202686	6115	16893	145	20497	4755	155234	1694	185648	205333	-1014
21:15	50.01	202239	6146	17226	147	20018	4735	154963	1772	184866	205007	-1006
21:30	49.96	202267	6147	16735	111	20359	4754	155082	1672	185421	204860	-1012
21:45	49.96	203020	6099	16221	182	20837	4768	155913	1684	186617	205704	-1002
22:00	50.07	203755	6132	16143	67	20551	4768	156834	1721	187545	206216	-1028
22:15	49.91	206535	6126	16243	153	20989	4739	159				