



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 08.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 7-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	77748	57498	49017	28233	3576	216072
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1709	1315	1195	616	71	4905
Hydro Gen (MU)	390	45	181	93	39	748
Wind Gen (MU)	22	218	313	-	-	552
Solar Gen (MU)*	172.86	76.05	116.07	1.83	0.98	368
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79533	58018	57283	28683	3593	216440
Time Of Maximum Demand Met	22:20	19:50	09:57	20:51	19:37	21:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.085	1.47	4.34	9.30	15.11	72.17	12.72

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15131	0	318.8	203.5	-1.8	761	0.00
	Haryana	11988	0	249.9	189.2	-3.3	376	0.00
	Rajasthan	13283	0	286.9	127.9	-9.1	324	0.00
	Delhi	6855	0	136.4	125.1	-1.3	242	0.00
	UP	29264	0	565.5	271.4	0.8	491	0.00
	Uttarakhand	2487	0	51.4	21.7	1.1	176	0.00
	HP	1748	0	37.2	-1.6	-0.9	162	0.00
	J&K(UT) & Ladakh(UT)	2648	0	51.4	28.3	-0.5	183	0.00
	Chandigarh	383	0	7.5	7.2	0.3	96	0.00
	Railways_NR ISTS	209	0	4.0	3.8	0.2	41	0.00
WR	Chhattisgarh	4388	0	94.0	58.3	-3.3	361	0.00
	Gujarat	18120	0	387.6	132.3	-0.1	1212	0.00
	MP	10415	0	223.0	97.9	-0.1	595	0.00
	Maharashtra	23745	0	528.2	157.7	-3.2	665	0.00
	Goa	564	0	14.2	11.5	2.2	75	0.00
	DNHDDPDCL	1387	0	31.6	31.5	0.1	60	0.00
	AMNSIL	835	0	18.2	8.8	0.0	297	0.00
	BALCO	526	0	12.5	12.7	-0.2	12	0.00
	RIL JAMNAGAR	247	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	10190	0	213.6	8.9	-1.7	634	0.00
SR	Telangana	12209	0	233.1	121.7	0.4	631	0.00
	Karnataka	13580	0	244.4	40.4	1.5	894	0.00
	Kerala	4028	0	78.7	32.4	-1.9	179	0.00
	Tamil Nadu	19335	0	414.2	143.2	0.3	804	0.00
	Puducherry	525	0	10.9	10.3	0.1	53	0.00
	Bihar	8255	0	161.7	158.5	-7.4	284	0.00
ER	DVC	3104	0	66.2	-43.7	-0.2	290	0.00
	Jharkhand	1923	0	41.9	32.5	0.3	143	0.00
	Odisha	6057	0	129.4	55.5	-0.6	777	0.00
	West Bengal	9672	0	214.9	91.9	-2.3	164	0.00
	Sikkim	83	0	1.3	1.2	0.0	19	0.00
	Railways_ER ISTS	26	0	0.3	0.1	0.1	5	0.00
NER	Arunachal Pradesh	214	0	3.7	3.5	-0.2	18	0.00
	Assam	2442	0	47.7	40.1	1.0	170	0.00
	Manipur	190	0	3.1	3.2	-0.1	13	0.00
	Meghalaya	330	0	5.8	0.3	0.0	54	0.00
	Mizoram	132	0	2.0	0.8	-0.2	4	0.00
	Nagaland	173	0	3.1	2.8	-0.1	9	0.00
	Tripura	281	0	5.8	4.1	0.1	38	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	47.7	15.6	-23.6	-27.9
Day Peak (MW)	2457.0	707.8	-1000.0	-1417.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	409.5	-295.4	-46.6	-68.6	1.1	0.0
Actual(MU)	384.7	-276.7	-34.6	-80.3	0.6	-6.4
O/D/U/D(MU)	-24.8	18.7	11.9	-11.8	-0.5	-6.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3974	15544	8638	4530	582	33267	50
State Sector	8374	11919	10832	2309	199	33633	50
Total	12348	27462	19470	6839	781	66900	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	750	1282	517	665	13	3226	62
Lignite	21	10	34	0	0	65	1
Hydro	390	45	181	93	39	748	14
Nuclear	37	56	65	0	0	157	3
Gas, Naptha & Diesel	21	25	4	0	21	72	1
RES (Wind, Solar, Biomass & Others)	202	296	462	4	1	966	18
Total	1421	1714	1263	763	74	5235	100

Share of RES in total generation (%)	14.19	17.30	36.56	0.51	1.34	18.45
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.28	23.16	56.03	12.76	53.92	35.76

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.049
Based on State Max Demands	1.094

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	211676	10:57	0
Non-Solar hr	216440	21:48	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 08-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	348	0.0	7.2	-7.2
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	578	751	0.0	7.5	-7.5
4	765 kV	SASARAM-FATEHPUR	1	243	335	0.0	3.5	-3.5
5	765 kV	GAYA-BALIA	1	0	871	0.0	13.1	-13.1
6	400 kV	PUSAULI-VARANASI	1	0	126	0.0	1.7	-1.7
7	400 kV	PUSAULI -ALLAHABAD	1	25	91	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	928	0.0	14.4	-14.4
9	400 kV	PATNA-BALIA	2	133	786	0.0	10.3	-10.3
10	400 kV	NAUBATPUR-BALIA	2	147	510	0.0	2.9	-2.9
11	400 kV	BIHARSHARIFF-BALIA	2	287	249	0.0	0.9	-0.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	584	0.0	7.9	-7.9
13	400 kV	BIHARSARIEFF-SAHUPURI	2	117	416	0.0	4.8	-4.8
14	220 kV	SAHUPURI-KARMANASA	1	0	123	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	79.5	-78.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	795	580	2.6	0.0	2.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1591	401	20.7	0.0	20.7
3	765 kV	JHARSUGUDA-DURG	2	150	353	0.0	2.2	-2.2
4	400 kV	JHARSUGUDA-RAIGARH	4	308	84	2.8	0.0	2.8
5	400 kV	RANCHI-SIPAT	2	422	122	5.3	0.0	5.3
6	400 kV	JEYPORE-JAGDALPUR	2	136	528	0.0	5.3	-5.3
7	220 kV	BUDHIPADAR-RAIGARH	1	68	98	0.2	0.0	0.2
8	220 kV	BUDHIPADAR-KORBA	2	121	70	1.3	0.0	1.3
ER-WR						32.9	7.6	25.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	479	0	10.2	0.0	10.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1189	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2527	0.0	32.8	-32.8
4	400 kV	TALCHER-I/C	2	213	365	2.6	0.0	2.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						10.2	61.8	-51.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	176	243	0.6	1.5	-0.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	485	0.0	6.4	-6.4
3	220 kV	ALIPURDUAR-SALAKATI	2	15	76	0.0	0.9	-0.9
ER-NER						0.6	8.8	-8.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	370	0.0	8.5	-8.5
NER-NR						0.0	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4052	0.0	97.4	-97.4
2	HVDC	VINDHYACHAL B/B	-	292	0	5.5	0.0	5.5
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1171	0.0	27.9	-27.9
4	765 kV	GWALIOR-AGRA	2	0	2936	0.0	40.0	-40.0
5	765 kV	GWALIOR-PHAGI	2	774	1979	2.4	25.0	-22.6
6	765 kV	JABALPUR-ORAI	2	0	1438	0.0	37.1	-37.1
7	765 kV	GWALIOR-ORAI	1	588	0	9.9	0.0	9.9
8	765 kV	SATNA-ORAI	1	0	1144	0.0	20.3	-20.3
9	765 kV	BANASKANTHA-CHITORGARH	2	738	777	2.8	4.2	-1.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	3337	0.0	57.0	-57.0
11	400 kV	ZERDA-KANKROLI	1	157	148	0.9	0.5	0.4
12	400 kV	ZERDA-BHINMAL	1	108	103	0.6	0.4	0.3
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	392	726	1.6	6.4	-4.9
15	400 kV	NEEMUCH-Chittorgarh	2	257	820	0.8	7.7	-6.9
16	220 kV	BHANPURA-RANPUR	1	0	143	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	82	36	0.4	0.2	0.3
19	220 kV	MALANPUR-AURAIYA	1	57	51	0.0	0.0	0.0
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						24.9	328.7	-303.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1010	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	771	802	0.0	6.4	-6.4
3	765 kV	SOLAPUR-RAICHUR	2	2362	258	24.0	0.2	23.8
4	765 kV	WARDHA-NIZAMABAD	2	714	2197	0.5	16.7	-16.2
5	765 kV	WARORA-WARANGAL(NEW)	2	852	2072	1.0	14.2	-13.2
6	400 kV	KOLHAPUR-KUDGI	2	2153	0	38.4	0.0	38.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	2.1	0.0	2.1
WR-SR						90.0	37.5	52.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1353	524	1151	27.63		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	878	532	694	16.65		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	127	60	89	2.15		
	NER	132kV GELEPHU-SALAKATI	24	6	17	0.40		
	NER	132kV MOTANGA-RANGIA	50	19	37	0.89		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-63	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-63	0	-5	-0.11		
	ER	NEPAL IMPORT (FROM BIHAR)	128	83	123	2.96		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	560	384	533	12.78		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-954	-948	-950	-22.80		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1417	-577	-1163	-27.91		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-46	0	-35	-0.84		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 08-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.53	0.09	0.00	0.00	0.00	0.00	0.00	0.00	23.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.53	0.09	0.00	0.00	0.00	0.00	0.00	0.00	23.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	46.42	0.00	1.47	0.00	0.00	0.15	0.00	0.00	48.04
Nepal	8.43	0.09	4.97	0.00	0.00	2.19	0.00	0.00	15.68
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	54.85	0.09	6.44	0.00	0.00	2.34	0.00	0.00	63.72

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	46.42	0.00	1.47	0.00	0.00	0.15	0.00	0.00	48.04
Nepal	8.43	0.09	4.97	0.00	0.00	2.19	0.00	0.00	15.68
Bangladesh	-23.53	-0.09	0.00	0.00	0.00	0.00	0.00	0.00	-23.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	31.32	0.00	6.44	0.00	0.00	2.34	0.00	0.00	40.10

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	200600	5904	22716	0	30512	2442	137324	1511	177884	200409	1914
0:15	50.00	199545	5901	22886	0	29828	2426	137543	1515	176659	200099	1875
0:30	50.00	198866	5911	22721	0	29833	2424	137121	1509	176145	199519	1859
0:45	50.01	197558	5914	22771	0	29301	2426	136243	1521	174787	198176	1891
1:00	50.06	195320	5915	22609	0	28644	2429	134965	1513	172711	196075	1957
1:15	50.01	193990	5919	22769	0	28456	2411	133861	1516	171221	194932	1950
1:30	49.95	192378	5899	23084	0	28139	2421	132263	1535	169294	193341	1951
1:45	49.95	191132	5893	23058	0	27858	2368	131294	1558	168074	192029	1945
2:00	49.95	190174	5907	23131	0	27814	2339	130328	1533	167043	191052	1973
2:15	50.00	189612	5924	23469	0	27976	2333	129366	1542	166143	190610	1926
2:30	50.00	188580	5921	23300	0	28207	2333	128368	1490	165280	189619	1919
2:45	50.00	187711	5920	23140	0	27855	2334	127857	1488	164571	188594	1961
3:00	50.04	187419	5921	23049	0	27466	2336	127966	1509	164370	188247	1944
3:15	50.04	186243	5916	22884	0	27279	2333	127140	1516	163359	187068	1939
3:30	49.99	185760	5913	22615	0	27290	2334	126797	1489	163145	186438	1962
3:45	49.94	185042	5917	22116	0	26750	2337	127490	1473	162926	186083	1956
4:00	50.04	184729	5923	21477	0	27026	2342	127446	1490	163252	185704	1967
4:15	49.99	185793	5943	21304	0	27140	2332	128588	1490	164489	186797	1966
4:30	50.04	185940	5933	20973	0	27332	2343	128701	1495	164967	186777	1991
4:45	49.99	186419	5918	20894	0	27643	2354	129060	1568	165525	187437	1998
5:00	50.09	185246	5922	20970	63	26874	2378	128823	1498	164213	186528	1998
5:15	49.94	185086	5917	20863	62	26575	2379	129036	1506	164161	186338	1972
5:30	49.94	186557	5915	20876	63	26699	2386	130163	1482	165618	187584	1991
5:45	49.99	187331	5922	20710	82	27257	2342	130741	1536	166539	188590	1972
6:00	49.99	189502	5925	20721	322	27080	2429	132534	1514	168459	190525	1970
6:15	49.84	191463	5918	20324	1008	27740	2471	133866	1508	170131	192835	1963
6:30	49.89	193978	5928	19977	1966	28142	2513	134918	1545	172035	194989	1885
6:45	49.99	194631	5923	19847	3327	28263	2343	134447	1521	171457	195671	1929
7:00	49.99	195912	5932	19982	5158	28224	2353	134344	1524	170772	196607	1956
7:15	49.94	196920	5923	20005	7505	27889	2338	132137	1579	169410	197376	1974
7:30	49.99	197098	5941	20382	10083	27567	2354	130176	1579	166633	198082	1978
7:45	50.04	196267	5921	20674	12674	26890	2350	127471	1598	162919	197578	2029
8:00	50.09	196455	5935	21143	15641	26582	2354	124926	1643	159671	198224	1980
8:15	50.04	197546	5931	21180	19183	26598	2345	122894	1612	156983	199943	1774
8:30	50.09	199059	5935	21901	22024	26321	2338	121251	1624	155134	201394	1692
8:45	50.04	201896	5928	22394	24791	26019	2378	120960	1593	154711	204063	1766
9:00	50.04	203686	5918	22759	27630	25938	2432	119518	1612	153297	205807	1758
9:15	49.99	206739	5905	23029	30617	26077	2468	118748	1609	153093	208453	1761
9:30	49.99	208318	5912	23504	33382	26246	2462	117611	1585	151432	210702	1740
9:45	49.99	209676	5904	23600	36392	26131	2455	115348	1602	149684	211432	1632
10:00	50.04	210068	5896	23870	39712	25801	2479	112331	1628	146486	211717	1648
10:15	50.09	210140	5894	24189	42716	25519	2450	108717	1626	143235	211111	1598
10:30	50.04	210596	5905	24335	44533	25540	2469	107475	1730	141728	211987	1627
10:45	49.99	210818	5906	24629	43903	25250	2524	108084	1698	142286	211994	1619
11:00	50.04	211560	5926	25050	45719	25122	2527	107160	1739	140791	213243	1541
11:15	49.99	210811	5889	25738	45712	23984	2478	107157	1718	139361	212676	1559
11:30	50.09	210896	5915	25536	47757	24254	2478	105018	1712	137603	212670	1557
11:45	50.04	210277	5918	25641	48636	24126	2527	103859	1765	136000	212472	1650
12:00	49.99	210613	5932	25752	48480	24556	2489	103574	1721	136381	212504	1630
12:15	49.94	209806	5923	25573	47727	24967	2509	103477	1741	136506	211917	1641
12:30	49.94	209724	5902	25856	47723	25204	2485	102949	1757	136145	211876	1681
12:45	49.94	209082	5915	25958	47800	25122	2510	102216	1759	135324	211280	1674
13:00	50.04	207860	5915	25396	47451	25038	2468	101602	1741	135013	209611	1678
13:15	49.94	205175	5930	25210	45676	24629	2485	101175	1701	134289	206806	1634
13:30	49.94	204987	5908	24951	44802	24683	2519	101755	1793	135234	206411	1638
13:45	49.79	206197	5901	24915	43270	25090	2491	104050	1742	138012	207459	1668
14:00	49.99	207289	5921	25270	43110	25466	2497	104828	1723	138909	208815	1638
14:15	49.94	207672	5894	25331	41126	25246	2422	107369	1730	141215	209118	1641
14:30	49.99	210131	5890	25263	40779	25743	2482	109899	1653	144089	211709	1642
14:45	49.94	210636	5907	25356	39877	26223	2437	111240	1674	145403	212714	1003
15:00	49.99	210825	5891	25441	37554	27007	2417	112815	1735	147830	212860	894
15:15	49.74	209526	5896	25601	34836	27177	2423	113810	1676	149089	211419	895
15:30	49.94	209752	5895	26010	33341	27397	2367	115523	1653	150401	212186	866
15:45	49.89	209010	5927	25987	30354	27693	2392	117346	1689	152669	211388	893
16:00	49.89	207928	5907	26027	27353	27985	2459	118935	1690	154548	210356	895
16:15	49.89	206962	5905	26170	25756	28126	2444	119383	1641	155036	209425	872
16:30	49.89	208480	5908	25712	22218	28116	2478	124877	1626	160550	210935	925
16:45	49.89	208473	5925	25150	20702	27293	2425	127217	1626	162621	210338	878
17:00	49.89	208803	5930	24806	19016	27545	2382	128950	1678	164981	210307	848
17:15	49.89	207372	5922	24789	16230	27642	2370	129886	1583	166353	208422	884
17:30	49.89	206846	5922	24515	14938	28208	2370	130544	1570	167393	208067	896
17:45	49.94	206659	5913	24219	11953	29306	2408	132305	1629	170487	207733	882
18:00	50.09	205704	5905	24131	9700	29364	2523	133443	1613	171873	206679	870
18:15	49.99	203258	5923	24020	7407	28730	2569	134206	1617	171831	204472	828
18:30	49.99	204974	5898	23463	4477	29814	2714	138434	1595	177034	206395	815
18:45	49.94	206580	5920	22896	2503	31218	2826	141033	1652	181181	208048	796
19:00	49.89	208079	5916	22183	1076	32203	2986	142794	1712	184820	208870	716
19:15	49.84	210482	5902	21543	440	33904	3010	144597	1745	188499	211141	654
19:30	49.58	211163	5906	21054	50	34553	3037	145508	1676	190059	211784	679
19:45	49.79	213259	5902	20966	-39	35736	3082	146573	1743	192332	213963	698
20:00	49.79	213959	5926	20683	-50	35554	3160	147143	1925	193326	214341	1006
20:15	49.79	214105	5918	20383	0	35458	3618	147218	1826	193722	214421	1127
20:30	49.84	214226	5895	20418	0	34915	3999	147243	1921	193808	214391	1252
20:45	49.79	214433	5925	20221	0	34753	4508	147179	1840	194212	214426	1412
21:00	49.79	215092	5907	20303	0	35176	4820	147144	1838	194789	215188	1420
21:15	49.99	215226	5921	20150	0	35180	4968	146885	1857	195076	214961	1402
21:30	49.89	215490	5925	20058	0	34980	5106	147421	1852	195432	215342	1373
21:45	49.99	216181	5926	20574	0	35308	5150	147152	1850	195607	215960	1404
22:00	50.04	215737	5929	20923	0	35199	5191	146245	1840	194814	215327	1383
22:15	49.99	215905	5927	21022	0	35294	5134	146324	1844	194883	215545	