



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57298	70452	55925	27349	3137	214161
Peak Shortage (MW)	0	343	0	228	0	571
Energy Met (MU)	1204	1647	1458	595	59	4963
Hydro Gen (MU)	140	58	88	26	11	324
Wind Gen (MU)	23	105	33	-	-	161
Solar Gen (MU)*	226.43	148.57	135.77	4.14	0.76	516
Energy Shortage (MU)	0.00	0.36	0.00	0.66	0.00	1.02
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	57851	72460	69695	28112	3257	221062
Time Of Maximum Demand Met	19:52	16:50	15:32	20:50	18:09	09:58

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.12	3.19	3.31	81.31	15.38

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7573	0	156.3	67.6	-1.0	624	0.00
	Haryana	7354	0	154.3	107.1	-3.0	142	0.00
	Rajasthan	13282	0	277.8	61.3	-8.8	253	0.00
	Delhi	4254	0	86.5	78.7	0.2	268	0.00
	UP	20920	0	397.3	99.9	-2.6	1066	0.00
	Uttarakhand	2072	0	42.9	32.8	-0.7	80	0.00
	HP	1800	0	33.7	21.2	-1.2	322	0.00
	J&K(UT) & Ladakh(UT)	2723	0	47.5	42.0	-3.0	82	0.00
	Chandigarh	195	0	3.9	4.0	-0.1	8	0.00
	Railways_NR ISTS	204	0	4.3	3.9	0.4	36	0.00
WR	Chhattisgarh	6508	0	151.2	90.8	1.0	540	0.36
	Gujarat	22488	0	461.8	184.6	-9.3	565	0.00
	MP	14209	0	279.3	153.3	-3.2	576	0.00
	Maharashtra	29366	0	671.4	237.9	0.6	500	0.00
	Goa	762	0	16.4	15.7	0.1	73	0.00
	DNHDDPDCL	1310	0	30.5	30.9	-0.4	41	0.00
	AMNSIL	760	0	17.0	9.9	0.0	201	0.00
	BALCO	533	0	12.7	12.7	0.0	271	0.00
	RIL JAMNAGAR	269	0	6.4	6.5	-0.1	0	0.00
	Andhra Pradesh	13110	0	257.2	81.9	0.8	614	0.00
SR	Telangana	16107	0	326.0	178.8	-0.6	745	0.00
	Karnataka	17110	0	338.7	136.2	-1.4	531	0.00
	Kerala	5181	0	100.7	77.5	1.3	554	0.00
	Tamil Nadu	19939	0	425.1	278.3	0.9	1497	0.00
	Puducherry	473	0	10.4	9.9	0.0	53	0.00
ER	Bihar	6305	213	124.5	115.3	2.8	217	0.51
	DVC	3279	0	72.3	-35.0	-0.2	277	0.00
	Jharkhand	2159	0	42.4	31.5	0.8	315	0.15
	Odisha	5904	0	123.2	40.3	-0.6	488	0.00
	West Bengal	10702	0	231.1	82.8	-1.6	427	0.00
	Sikkim	100	0	1.7	1.8	-0.1	9	0.00
	Railways_ER ISTS	13	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	171	0	3.1	3.0	0.0	25	0.00
	Assam	1990	0	36.4	30.2	0.7	136	0.00
	Manipur	203	0	2.6	2.7	0.0	31	0.00
	Meghalaya	352	0	6.2	4.9	0.0	92	0.00
	Mizoram	130	0	2.1	1.8	-0.1	24	0.00
	Nagaland	163	0	2.6	2.6	0.0	32	0.00
	Tripura	312	0	5.8	4.5	0.3	73	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-2.7	-12.8	-23.2	-29.6
Day Peak (MW)	-235.9	-834.5	-976.0	-1380.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	49.6	-272.9	286.9	-80.9	17.4	0.0
Actual(MU)	12.3	-262.2	296.1	-78.5	17.5	-14.8
O/D/UD(MU)	-37.3	10.7	9.2	2.4	0.2	-14.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3533	7084	2288	2735	586	16227	42
State Sector	7839	8230	4366	1592	139	22165	58
Total	11372	15314	6654	4327	725	38392	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	805	1624	791	738	10	3967	71
Lignite	27	12	47	0	0	86	2
Hydro	140	58	88	26	11	324	6
Nuclear	32	64	76	0	0	172	3
Gas, Naptha & Diesel	9	36	7	0	25	78	1
RES (Wind, Solar, Biomass & Others)	266	257	212	6	1	741	17
Total	1279	2051	1221	770	47	5368	100

Share of RES in total generation (%)	20.82	12.52	17.32	0.75	1.66	13.81
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.23	18.49	30.78	4.15	25.93	23.05

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.046
Based on State Max Demands	1.086

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	221062	9:58	0
Non-Solar hr	213880	19:20	571

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 29-Mar-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	1323	192	6.4	0.0	6.4
4	765 kV	SASARAM-FATEHPUR	1	3	346	0.0	3.1	-3.1
5	765 kV	GAYA-BALIA	1	274	392	0.0	1.1	-1.1
6	400 kV	PUSAULI-VARANASI	1	0	190	0.0	2.8	-2.8
7	400 kV	PUSAULI-ALLAHABAD	1	93	16	0.6	0.0	0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	933	202	5.0	0.0	5.0
9	400 kV	PATNA-BALIA	2	343	607	0.0	7.4	-7.4
10	400 kV	NAUBATPUR-BALIA	2	273	387	0.0	1.7	-1.7
11	400 kV	BIHARSHARIEF-BALIA	2	679	0	6.1	0.0	6.1
12	400 kV	MOTIHARI-GORAKHPUR	2	312	310	0.0	2.1	-2.1
13	400 kV	BIHARSARIEF-SAHUPURI	2	0	0	1.4	0.0	1.4
14	220 kV	SAHUPURI-KARAMANASA	1	30	62	0.0	0.3	-0.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						20.1	19.9	0.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1567	246	12.4	0.0	12.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1239	517	8.2	0.0	8.2
3	765 kV	JHARSUGUDA-DURG	2	0	1114	0.0	20.4	-20.4
4	400 kV	JHARSUGUDA-RAIGARH	4	0	637	0.0	11.2	-11.2
5	400 kV	RANCHI-SIPAT	2	317	192	0.7	0.0	0.7
6	220 kV	BUDHIPADAR-RAIGARH	1	50	101	0.0	0.9	-0.9
7	220 kV	BUDHIPADAR-KORBA	2	35	136	0.0	1.1	-1.1
ER-WR						21.2	33.5	-12.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	732	0.0	11.2	-11.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1767	0.0	42.4	-42.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	3340	0.0	59.7	-59.7
4	400 kV	TALCHER-I/C	2	1029	971	0.0	1.7	-1.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	113.3	-113.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	234	174	2.1	0.9	1.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	421	149	2.9	0.0	2.9
3	220 kV	ALIPURDUAR-SALAKATI	2	71	30	0.6	0.0	0.6
ER-NER						5.6	0.9	4.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	955	0	23.0	0.0	23.0
NER-NR						23.0	0.0	23.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1009	0.0	23.8	-23.8
2	HVDC	VINDHYACHAL B/B	-	0	56	0.0	1.3	-1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1456	0.0	29.6	-29.6
4	765 kV	GWALIOR-AGRA	2	887	1352	3.7	10.6	-6.9
5	765 kV	GWALIOR-PHAGI	2	1679	1159	9.4	10.6	-1.1
6	765 kV	JABALPUR-ORAI	2	713	621	0.0	2.4	-2.4
7	765 kV	GWALIOR-ORAI	1	666	0	9.6	0.0	9.6
8	765 kV	SATNA-ORAI	1	0	856	0.0	14.5	-14.5
9	765 kV	BANASKANTHA-CHITTOORGARH	2	2197	0	25.8	0.0	25.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2543	0.0	40.6	-40.6
11	400 kV	ZERDA-KANKROLI	1	496	0	6.0	0.0	6.0
12	400 kV	ZERDA-BHIMMAL	1	343	0	4.1	0.0	4.1
13	400 kV	VINDHYACHAL-BIHAND	1	968	0	21.0	0.0	21.0
14	400 kV	RAPP-SHUJALPUR	2	699	15	7.0	0.0	7.0
15	400 kV	NEEMUCH-Chittorgarh	2	841	66	7.4	0.1	7.3
16	220 kV	BHANPURA-RANPUR	1	0	139	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.0	-1.0
18	220 kV	MEHGAON-AURAIYA	1	104	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	80	0	0.9	0.0	0.9
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						96.1	136.6	-40.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	21.7	-21.7
2	HVDC	RAIGARH-PUGALUR	2	0	6628	0.0	124.9	-124.9
3	765 kV	SOLAPUR-RAICHUR	2	981	1364	2.4	14.7	-12.3
4	765 kV	WARDHA-NIZAMABAD	2	0	3152	0.0	45.7	-45.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3468	0.0	52.1	-52.1
6	400 kV	KOLHAPUR-KUDGI	2	1458	0	20.5	0.0	20.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.3	0.0	2.3
WR-SR						25.3	259.1	-233.8

INTERNATIONAL EXCHANGES						Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	292	58	180	4.32	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-271	55	-116	-2.78	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-220	-98	-173	-4.16	
	NER	132kV GELEPHU-SALAKATI	-18	-1	-10	-0.24	
	NER	132kV MOTANGA-RANGIA	21	-5	8	0.18	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-43	-1.04	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-40	-0.96	
	ER	NEPAL IMPORT (FROM BIHAR)	-271	-15	-165	-3.95	
BANGLADESH	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-563	14	-287	-6.89	
	ER	BHERAMARA B/B HVDC (B'DESH)	-938	-912	-933	-22.40	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1380	-997	-1232	-29.56	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-38	0	-33	-0.78	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Mar-2025

Export From India (in MU)

Export From India (in M\$)		T-GNA							TOTAL
Country	GNA (ISGS/PPA)	BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	5.89	0.00	0.00	0.00	0.00	0.00	6.28
Nepal	4.16	0.00	4.36	0.00	0.00	3.27	0.00	0.00	11.79
Bangladesh	23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.26	0.39	10.25	0.00	0.00	3.27	0.00	0.00	41.17

Import by India(in MU)

Import by India (in M€)									
Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.42
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.42

Net from India(in MU)

-ve : Export / +ve : Import

Net from India (in M€)			T-GNA						-ve. Export / +ve. Import
Country	GNA (ISGS/PPA)	BILATERAL TOTAL	COLLECTIVE						TOTAL
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.42	-0.39	-5.89	0.00	0.00	0.00	0.00	0.00	-2.86
Nepal	-4.16	0.00	-4.36	0.00	0.00	-3.27	0.00	0.00	-11.79
Bangladesh	-23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.84	-0.39	-10.25	0.00	0.00	-3.27	0.00	0.00	-37.75

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.06	199359	6487	7656	179	12977	3175	169217	2161	191524	201852	-1091
0:15	49.91	198654	6539	7672	182	10821	3141	170978	2050	190800	201383	-1218
0:30	50.06	198667	6539	7713	184	10898	3090	170549	2107	190770	201080	-1220
0:45	50.01	197453	6533	7927	146	10748	3028	169878	2086	189380	200346	-1252
1:00	50.06	196797	6562	8140	149	9872	2886	169077	2097	188508	198783	-1274
1:15	50.06	195335	6538	8540	149	8808	2811	169263	2099	186646	198208	-1277
1:30	50.06	194521	6588	8893	156	7687	2778	169195	2101	185472	197398	-1256
1:45	50.06	193176	6557	8967	158	7272	2794	168464	2134	184051	196346	-1406
2:00	50.06	191896	6608	9070	158	6857	2802	167231	2094	182668	194820	-1473
2:15	50.01	191008	6581	9142	163	6564	2799	166613	2089	181703	193951	-1440
2:30	50.01	190560	6596	9361	162	6583	2798	165721	2102	181037	193323	-1549
2:45	50.01	189695	6619	9598	159	6643	2791	165064	2134	179938	193008	-1631
3:00	50.01	189119	6583	9763	158	6574	2791	164266	2098	179198	192233	-1637
3:15	49.96	188923	6616	10076	163	6624	2795	163765	2100	178684	192139	-1581
3:30	50.01	188839	6598	10153	163	6710	2800	163544	2053	178523	192021	-1526
3:45	50.01	188878	6592	10080	164	7110	2826	163020	2080	178634	191872	-1522
4:00	50.01	189174	6632	9979	165	7311	2841	163207	2041	179030	192176	-1536
4:15	49.96	190408	6643	9630	164	7234	2902	164802	2057	180614	193432	-1404
4:30	50.01	191483	6642	9538	164	7598	2906	165228	2037	181781	194113	-1373
4:45	50.01	191766	6628	9394	166	8130	2907	165828	2088	182206	195141	-1335
5:00	50.06	192407	6628	9295	166	8330	2934	166013	2101	182946	195467	-1267
5:15	50.01	193995	6637	9258	166	9126	3035	166759	2036	184571	197017	-1291
5:30	49.96	196428	6641	9190	158	9789	3098	167822	2073	187080	198771	-1011
5:45	50.01	197825	6641	9235	151	11308	3115	168197	2050	188439	200697	-1049
6:00	50.06	198822	6685	9317	137	12070	3204	168124	2044	189368	201581	-1081
6:15	50.01	200882	6691	9166	252	14295	3237	168459	2057	191464	204157	-1490
6:30	50.01	204205	6698	8800	454	17188	3177	169153	2069	194951	207539	-1586
6:45	50.06	205873	6690	8602	1320	18883	3084	168663	2062	195951	209304	-1572
7:00	50.06	206822	6695	8391	3282	18599	2965	167902	2071	195149	209905	-1603
7:15	50.01	208163	6738	8078	6510	18306	2935	166790	2098	193575	211455	-1644
7:30	50.06	208789	6759	7823	10724	18135	2946	163202	2099	190242	211688	-1817
7:45	50.06	208276	6760	7392	15723	16966	2938	159624	2161	185161	211564	-1862
8:00	50.06	207926	6756	6691	21061	14198	2929	156661	2169	180174	210465	-1822
8:15	50.01	210204	6770	5974	27065	13236	2944	154930	2197	177165	213116	-1827
8:30	50.06	210902	6733	5452	32514	12430	2930	151750	2256	172936	214065	-1943
8:45	50.01	212264	6732	4923	37374	11512	2941	149640	2255	169967	215377	-1874
9:00	50.06	213928	6753	4692	41860	10765	2928	147482	2251	167376	216731	-1886
9:15	50.06	217335	6746	4688	45877	10947	2919	146874	2304	166770	220355	-1955
9:30	50.04	218762	6766	4885	40819	9784	2917	145191	2283	164058	221645	-1961
9:45	50.03	220291	6702	5114	53396	9363	2921	143184	2344	161781	223024	-1778
10:00	50.09	220733	6709	5502	56302	8860	2919	141022	2323	158929	223637	-1821
10:15	50.03	220302	6731	5809	59004	8210	2943	138520	2314	155489	223531	-1893
10:30	50.03	220268	6706	5758	60997	8084	2936	136767	2348	153513	223596	-1999
10:45	50.03	219445	6712	5787	61291	8184	2932	135800	2268	153267	222974	-1900
11:00	49.98	218894	6715	5344	62169	8248	2933	133707	2331	151381	221447	-1844
11:15	49.98	216888	6703	4954	62897	8426	2947	131869	2336	149037	220132	-1809
11:30	49.98	216963	6544	4667	63328	8600	2936	131006	2311	148968	219392	-1808
11:45	49.98	216359	6704	4288	63727	8816	2939	130736	2301	148344	219511	-1734
12:00	49.98	215002	6704	4052	63633	8716	2946	129642	2264	147317	217957	-1796
12:15	49.98	214126	6720	1148	45569	8565	2788	129874	1936	167409	196600	-1739
12:30	49.98	213283	6714	3622	63984	8384	3065	127932	2378	145677	196079	-1733
12:45	49.98	212023	6694	3331	63815	9040	2996	126925	2304	144877	215105	-1776
13:00	50.09	211426	6668	3083	63691	9173	2946	124628	2336	144652	212525	-1797
13:15	50.19	208811	6672	2814	63143	8819	2930	123103	2409	142854	209890	-1790
13:30	50.14	206724	6683	2781	62873	8699	2932	123281	2340	141070	209589	-1824
13:45	50.04	206701	6679	2700	61850	8182	2943	124975	2339	142151	209668	-1846
14:00	49.99	207519	6660	2667	61071	8141	2989	126867	2326	143781	210721	-1830
14:15	49.94	209515	6674	2729	60338	8139	3063	128927	2334	146448	212204	-1713
14:30	49.99	211397	6688	2741	59260	8690	3053	131670	2315	149396	214417	-1727
14:45	49.99	213384	6692	2790	57927	9059	3061	134492	2306	152667	216327	-1699
15:00	49.99	213970	6707	2867	55806	9778	3061	136608	2297	155297	217124	-1754
15:15	49.94	214843	6708	3038	54403	10090	3071	138275	2274	157402	217859	-1733
15:30	49.94	216270	6673	3210	51724	10995	3052	141620	2282	161336	219556	-1705
15:45	49.89	215901	6726	3399	48582	12027	2965	143263	2240	163920	219202	-1780
16:00	49.89	215108	6721	3481	45167	12461	2978	145554	2206	166460	218568	-1759
16:15	49.99	214882	6679	3569	41445	12375	2992	148826	2155	169868	218041	-1759
16:30	49.99	215905	6718	3658	37370	12826	3066	153334	2158	174877	219130	-1731
16:45	49.99	215437	6704	3637	33200	13028	2983	157048	2138	178600	218738	-1761
17:00	49.99	214481	6679	3770	28850	13988	2952	159311	2087	181861	217637	-1752
17:15	49.94	211171	6720	3904	23871	14918	2954	159845	2033	183396	214245	-1372
17:30	49.99	210077	6692	3955	18819	15756	2984	162658	2126	187303	212990	-1413
17:45	49.94	208756	6665	4051	13414	17256	3017	165161	2070	191291	211634	-1388
18:00	50.04	208506	6659	3994	9079	19327	3100	167370	2041	195433	211570	-1274
18:15	50.00	207847	6680	3989	5206	21252	3198	168036	2094	198652	210455	-877
18:30	50.05	209494	6694	4101	2247	23640	3222	169884	2116	203146	212004	-921
18:45	49.90	211600	6696	4329	1094	25713	3384	171048	2118	206177	214382	-915
19:00	49.80	212908	6714	4573	271	26518	3397	172072	2087	208064	215632	-1018
19:15	49.90	213341	6710	4950	159	27095	3374	172070	2094	208232	216452	-885
19:30	50.05	213453	6717	5315	138	26948	3371	171496	2109	208000	216094	-921
19:45	50.00	213312	6728	5613	127	26422	3343	171639	2071	207572	215943	-914
20:00	50.05	212099	6723	5918	128	25630	3513	170618	2092	206053	214622	-915
20:15	50.05	209460	6708	6095	154	23587	3495	170116	2091	203211	212246	-977
20:30	50.05	208284	6740	6301	152	21715	3489	170401	2076	201831	210874	-958
20:45	50.00	207998	6709	6529	155	20819	3506	170559	2118	201314	210395	-959
21:00	50.05	206149	6735	6656	154	19476	3343	170192	2096	199339	208652	-957
21:15	50.00	205587	6761	6881	156	17916	3516	170594	2171	198550	207995	-1016
21:30	50.00	204989	6686	6933	101	17771	3518	170556	2109	197955	207674	-1007
21:45	50.00	204795	6679	7091	101	18021	3354	169793	2103	197603	207142	-1010
22:00	50.05	203979	6662	7144	99	17780	3318	169264	2073	196736	206340	-1045
22:15	49.90	206086	6662	7207	130	18076	3341	171039	2088	198749	208543	-1000
22:30	50.00	206348	6675	7226								